

BALLINA, Australia

WMO: 945960

Lat: 28.8353S

Lon: 153.5586E

Elev: 2

StdP: 101.30

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	6.9	0.0	3.8	13.9	1.6	4.3	13.5	10.4	16.8	9.3	17.0	0.7	280	0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.3	30.8	23.8	29.3	23.4	28.2	22.8	25.3	28.9	24.5	27.9	23.8	27.0	6.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.2	27.1	23.5	18.3	26.5	22.8	17.5	25.9	77.6	29.2	74.4	28.0	71.6	27.1	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.9	8.1	DB	3.0	34.9	0.9	2.5	2.4	36.7	1.9	38.2	1.4	39.6	0.7	41.5	(4)
(5)			WB	2.3	26.8	1.1	1.2	1.5	27.6	0.9	28.3	0.3	29.0	-0.5	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	23.7	23.6	22.6	20.0	17.1	15.2	14.2	14.9	17.3	19.2	21.0	22.6	(6)	
	DBStd	3.90	1.89	1.73	1.67	1.72	2.04	1.93	1.99	2.17	2.30	2.23	2.34	2.13	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	450	0	0	0	4	48	95	128	108	47	16	3	0	(9)	
	CDD10.0	3383	425	381	391	300	221	156	132	153	219	286	328	392	(10)	
	CDD18.3	792	167	148	132	54	11	1	1	3	16	43	82	134	(11)	
	CDH23.3	4444	1101	947	658	181	30	1	6	32	88	208	402	791	(12)	
	CDH26.7	741	215	170	78	11	1	0	0	5	12	30	71	147	(13)	
(14) Wind	WSAvg	3.8	4.5	4.3	3.7	3.5	3.0	3.3	3.2	3.4	3.8	4.2	4.4	4.3	(14)	
(15) Precipitation	PrecAvg	1686	147	196	204	178	176	143	104	95	61	120	116	148	(15)	
	PrecMax	2654	476	710	629	476	526	368	381	207	189	636	281	471	(16)	
	PrecMin	909	25	46	22	27	18	21	5	5	0	6	25	26	(17)	
	PrecStd	457	108	140	152	117	118	103	100	65	53	129	65	113	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	32.2	30.8	28.1	25.9	23.2	24.2	26.2	28.1	29.4	31.1	32.0	(19)	
		MCWB	24.3	25.3	24.4	21.9	18.8	17.1	16.9	16.2	18.3	19.5	22.2	24.3	(20)	
	2%	DB	30.2	29.9	28.5	26.3	24.0	21.7	22.0	23.7	25.6	27.2	28.6	29.9	(21)	
		MCWB	24.2	24.5	23.3	20.7	17.9	16.4	15.4	16.0	18.2	20.4	22.1	23.5	(22)	
	5%	DB	28.7	28.5	27.3	25.2	22.7	20.6	20.4	21.8	24.0	25.6	26.8	28.2	(23)	
		MCWB	23.6	23.6	22.3	20.2	17.6	16.0	15.1	15.3	17.9	19.6	21.5	22.6	(24)	
	10%	DB	27.7	27.5	26.4	24.3	21.7	19.5	19.1	20.3	22.6	24.1	25.4	26.9	(25)	
		MCWB	23.0	22.8	21.8	19.6	17.3	15.6	14.6	14.9	17.2	19.1	20.6	22.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.5	25.2	23.4	21.0	19.1	19.2	19.1	20.7	22.7	24.2	25.8	(27)	
		MCDB	29.3	30.1	29.1	26.3	23.3	21.0	22.1	23.5	25.0	26.5	28.8	30.0	(28)	
	2%	WB	25.1	25.4	24.1	21.9	19.9	18.0	17.7	17.6	19.8	21.6	23.0	24.5	(29)	
		MCDB	28.7	28.8	27.2	24.7	22.3	20.0	19.9	21.0	23.6	25.2	26.9	28.3	(30)	
	5%	WB	24.3	24.5	23.4	21.1	18.9	17.2	16.4	16.7	19.0	20.7	22.1	23.6	(31)	
		MCDB	27.6	27.6	26.2	24.1	21.5	19.4	18.9	20.1	22.5	24.0	25.5	27.1	(32)	
	10%	WB	23.6	23.7	22.7	20.3	18.0	16.5	15.4	15.9	18.2	19.8	21.4	22.7	(33)	
		MCDB	26.7	26.5	25.4	23.3	20.6	18.7	18.0	19.4	21.5	23.2	24.6	25.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.2	7.4	8.2	9.3	8.7	10.1	11.1	10.5	9.1	8.3	7.9	(35)	
		MCDBR	9.0	9.0	9.0	9.8	10.9	10.2	12.5	14.1	12.5	11.8	10.0	9.8	(36)	
	5% WB	MCWBR	4.3	4.4	4.5	5.0	5.8	5.8	7.0	7.5	6.6	6.2	4.8	4.7	(37)	
		MCWBR	8.1	8.0	7.8	8.4	8.7	8.0	9.3	11.3	10.5	9.7	9.0	8.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.389	0.374	0.357	0.344	0.319	0.313	0.304	0.317	0.354	0.384	0.382	0.392	(40)	
		taud	2.507	2.561	2.607	2.614	2.645	2.650	2.663	2.606	2.499	2.443	2.490	2.487	(41)	
	Ebn at Noon		953	950	936	900	881	863	889	915	923	930	953	953	(42)	
		Edh at Noon	114	105	95	86	75	71	73	85	104	117	115	117	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.50	5.91	5.00	4.20	3.46	2.86	3.33	4.22	5.26	5.89	6.40	6.45	(44)	
	RadStd		0.51	0.46	0.27	0.21	0.21	0.18	0.27	0.32	0.41	0.51	0.51	0.64	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (19 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-58	+171	+105	(47)

Nomenclature: See separate page