

CAPE LEEUWIN, Australia

WMO: 946010

Lat: 34.3728S

Lon: 115.1358E

Elev: 46

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	49.5	51.0	35.8	30.8	55.1	37.6	33.1	55.5	48.6	60.0	45.5	59.2	16.9	30	0.773

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.6	78.6	66.8	75.9	66.7	74.2	65.9	70.3	74.6	68.8	73.3	67.6	72.2	14.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.7	105.8	72.6	67.2	100.0	71.5	65.8	95.5	70.7	34.3	74.8	33.1	73.4	32.1	72.3	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.4	37.0	33.4	46.0	91.2	1.5	4.3	44.9	94.3	44.0	96.8	43.2	99.3	42.1	102.4
			41.7	74.0	0.9	3.0	41.1	76.1	40.5	77.9	40.0	79.6	39.3	81.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	67.9	68.7	67.8	65.7	62.8	59.7	58.0	58.1	58.6	60.5	63.5	65.8	(6)
	DBStd	4.90	2.74	2.84	3.50	3.42	3.19	2.81	2.67	2.68	2.82	2.81	3.32	3.08	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	1144	4	2	9	30	82	159	218	214	193	144	65	24	(9)
	CDD50	4765	555	522	552	471	397	291	248	252	258	324	405	490	(10)
	CDD65	433	94	104	96	50	14	1	0	0	1	3	21	49	(11)
	CDH74	523	92	117	143	63	13	0	0	0	3	7	39	46	(12)
	CDH80	84	8	11	33	9	1	0	0	0	0	1	14	7	(13)
(14) Wind	WSAvg	18.8	19.1	19.2	18.3	16.6	17.3	19.4	20.4	19.9	20.3	18.4	18.2	18.2	(14)
(15) Precipitation	PrecAvg	40.0	0.7	0.6	1.1	2.5	5.5	7.4	7.4	5.6	3.9	2.5	1.7	0.8	(15)
	PrecMax	57.6	2.8	3.4	3.6	6.9	12.4	14.5	13.2	12.5	7.1	5.5	3.6	2.2	(16)
	PrecMin	30.5	0.0	0.1	0.1	0.4	2.7	3.5	4.1	2.9	1.3	0.4	0.3	0.0	(17)
	PrecStd	6.2	0.7	0.7	0.9	1.7	2.2	2.6	2.0	2.0	1.3	1.2	1.0	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.4	80.7	83.9	80.1	75.4	68.9	67.6	68.2	69.9	72.7	78.5	78.7	(19)
		MCWB	69.4	69.1	66.4	63.6	61.5	60.0	60.0	59.1	58.4	61.4	61.9	67.1	(20)
	2%	DB	76.1	77.1	77.1	75.1	71.5	67.1	65.4	65.6	66.4	68.8	72.6	74.4	(21)
		MCWB	68.1	68.5	67.1	65.1	62.0	59.7	58.6	58.3	59.4	61.4	64.2	66.0	(22)
	5%	DB	74.1	74.9	74.4	72.4	69.4	65.7	63.8	63.9	64.7	66.8	70.2	72.3	(23)
		MCWB	66.4	67.1	66.1	64.5	61.6	59.0	57.3	57.5	58.1	60.0	62.7	64.5	(24)
	10%	DB	72.5	73.3	72.5	70.7	67.9	64.5	62.6	62.6	63.2	65.2	68.4	70.6	(25)
		MCWB	65.0	66.0	65.3	63.6	60.7	58.0	56.4	56.4	57.0	58.7	61.2	63.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	72.3	71.0	69.5	66.5	63.8	62.5	62.3	62.9	64.7	67.3	69.8	(27)
		MCDB	76.4	76.0	76.2	73.4	69.9	66.0	65.5	65.3	66.4	69.2	72.5	74.3	(28)
	2%	WB	69.8	70.2	69.2	67.7	64.8	61.9	60.3	60.3	60.8	62.9	65.4	67.5	(29)
		MCDB	74.3	74.7	73.7	72.0	68.9	65.2	63.7	63.8	64.9	67.2	70.2	72.3	(30)
	5%	WB	67.9	68.7	67.9	66.1	63.3	60.4	58.7	58.9	59.3	61.2	64.0	66.1	(31)
		MCDB	72.5	73.2	72.3	70.6	67.8	64.3	62.6	62.8	63.5	65.6	68.7	70.8	(32)
	10%	WB	66.4	67.3	66.7	64.8	61.9	59.1	57.3	57.4	57.8	59.7	62.5	64.7	(33)
		MCDB	71.2	71.9	71.3	69.6	66.6	63.4	61.6	61.7	62.4	64.4	67.6	69.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	8.6	8.6	8.5	8.5	7.8	7.6	7.5	7.6	8.2	8.8	8.5	(35)
		MCDBR	10.2	10.4	11.8	11.6	11.0	9.6	9.4	9.8	10.0	10.8	11.2	10.4	(36)
	5% WB	MCWBR	6.9	6.9	7.9	8.4	8.4	7.8	7.5	7.3	7.5	7.8	7.6	6.9	(37)
		MCWBR	9.7	9.6	10.5	9.7	9.0	8.1	8.2	8.4	9.2	9.9	10.9	9.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.336	0.338	0.327	0.321	0.317	0.310	0.308	0.319	0.333	0.329	0.332	0.332	(40)
		taud	2.600	2.606	2.636	2.647	2.630	2.628	2.633	2.590	2.532	2.561	2.576	2.592	(41)
	Ebn at Noon		318	310	303	287	271	264	271	283	295	310	317	320	(42)
		Edh at Noon	33	31	28	25	23	21	22	26	31	32	33	33	(43)
(44) All-Sky Solar Radiation	RadAvg		2390	2124	1682	1202	874	699	756	1027	1387	1820	2187	2383	(44)
	RadStd		126	94	107	63	56	46	34	54	73	109	116	121	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page