

CAPE LEEUWIN, Australia

WMO: 946010

Lat: 34.3728S

Lon: 115.1358E

Elev: 14

StdP: 101.16

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	10.5	2.1	4.4	12.8	3.1	4.7	13.1	21.7	15.6	20.3	15.1	7.5	30	0.773

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.8	25.9	19.4	24.4	19.3	23.4	18.8	21.3	23.7	20.5	22.9	19.8	22.3	6.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.1	22.6	19.5	14.3	21.9	18.8	13.6	21.5	61.9	23.8	59.0	23.0	56.8	22.4	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.5	14.9	DB	7.8	32.9	0.8	2.4	7.2	34.6	6.7	36.0	6.2	37.4	5.6	39.1	(4)
(5)			WB	5.4	23.3	0.5	1.7	5.0	24.5	4.7	25.5	4.4	26.4	4.1	27.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	20.0	20.4	19.9	18.7	17.1	15.4	14.4	14.5	14.8	15.8	17.5	18.8	(6)
(7)		DBStd	2.72	1.52	1.58	1.94	1.90	1.77	1.56	1.48	1.49	1.57	1.56	1.84	1.71	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	636	2	1	5	17	46	88	121	119	107	80	36	13	(9)
(10)		CDD10.0	2647	308	290	307	262	221	162	138	140	143	180	225	272	(10)
(11)		CDD18.3	241	52	58	53	28	8	1	0	0	1	2	12	27	(11)
(12)		CDH23.3	291	51	65	79	35	7	0	0	0	2	4	22	26	(12)
(13)		CDH26.7	47	4	6	18	5	1	0	0	0	0	1	8	4	(13)
(14)	Wind	WSAvg	8.4	8.5	8.6	8.2	7.4	7.8	8.7	9.1	8.9	9.1	8.2	8.1	8.1	(14)
(15)	Precipitation	PrecAvg	1017	17	15	28	63	139	188	189	143	99	63	42	20	(15)
(16)		PrecMax	1464	71	87	92	176	314	368	335	317	181	139	92	56	(16)
(17)		PrecMin	774	0	2	2	11	69	88	105	74	32	9	8	1	(17)
(18)		PrecStd	158	17	18	22	42	55	65	50	50	34	31	25	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.9	27.1	28.8	26.7	24.1	20.5	19.8	20.1	21.1	22.6	25.8	26.0	(19)
(20)			MCWB	20.8	20.6	19.1	17.6	16.4	15.6	15.5	15.1	14.6	16.3	16.6	19.5	(20)
(21)		2%	DB	24.5	25.0	25.1	23.9	21.9	19.5	18.5	18.7	19.1	20.5	22.6	23.6	(21)
(22)			MCWB	20.1	20.3	19.5	18.4	16.7	15.4	14.8	14.6	15.2	16.3	17.9	18.9	(22)
(23)		5%	DB	23.4	23.8	23.6	22.4	20.8	18.7	17.7	17.7	18.1	19.3	21.2	22.4	(23)
(24)			MCWB	19.1	19.5	19.0	18.1	16.4	15.0	14.1	14.2	14.5	15.5	17.1	18.0	(24)
(25)		10%	DB	22.5	22.9	22.5	21.5	19.9	18.1	17.0	17.0	17.4	18.5	20.2	21.5	(25)
(26)			MCWB	18.3	18.9	18.5	17.6	16.0	14.4	13.5	13.6	13.9	14.8	16.2	17.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	22.4	21.7	20.8	19.1	17.7	17.0	16.8	17.2	18.2	19.6	21.0	(27)
(28)			MCDWB	24.7	24.5	24.5	23.0	21.1	18.9	18.6	18.5	19.1	20.7	22.5	23.5	(28)
(29)		2%	WB	21.0	21.2	20.7	19.8	18.2	16.6	15.7	15.7	16.0	17.2	18.6	19.7	(29)
(30)			MCDWB	23.5	23.7	23.2	22.2	20.5	18.4	17.6	17.7	18.3	19.6	21.2	22.4	(30)
(31)		5%	WB	20.0	20.4	20.0	19.0	17.4	15.8	14.8	14.9	15.1	16.2	17.8	19.0	(31)
(32)			MCDWB	22.5	22.9	22.4	21.4	19.9	17.9	17.0	17.1	17.5	18.7	20.4	21.6	(32)
(33)		10%	WB	19.1	19.6	19.3	18.2	16.6	15.0	14.1	14.1	14.4	15.4	17.0	18.2	(33)
(34)			MCDWB	21.8	22.2	21.8	20.9	19.2	17.5	16.5	16.5	16.9	18.0	19.8	20.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	4.8	4.8	4.7	4.7	4.3	4.2	4.2	4.6	4.9	4.7	(35)	
(36)			MCDBR	5.6	5.8	6.6	6.4	6.1	5.3	5.2	5.4	5.5	6.0	6.2	5.8	(36)
(37)			MCWBR	3.8	3.8	4.4	4.7	4.7	4.4	4.2	4.1	4.1	4.3	4.2	3.8	(37)
(38)		5% WB	MCDWR	5.4	5.3	5.8	5.4	5.0	4.5	4.6	4.7	5.1	5.5	6.1	5.5	(38)
(39)			MCWBR	4.4	4.1	4.5	4.6	4.8	4.6	4.5	4.3	4.6	4.5	4.6	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.338	0.327	0.321	0.317	0.310	0.308	0.319	0.333	0.329	0.332	0.332	(40)	
(41)		taud	2.600	2.606	2.636	2.647	2.630	2.628	2.633	2.590	2.532	2.561	2.576	2.592	(41)	
(42)		Ebn at Noon	1001	978	954	904	853	832	854	892	930	976	998	1008	(42)	
(43)		Edh at Noon	103	99	89	79	71	67	70	82	97	102	105	105	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.54	6.70	5.30	3.79	2.76	2.20	2.38	3.24	4.37	5.74	6.89	7.51	(44)	
(45)		RadStd	0.40	0.29	0.34	0.20	0.18	0.14	0.11	0.17	0.23	0.34	0.36	0.38	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page