

BADGINGARRA, AustraliaWMO: **946030**Lat: **30.338S**Lon: **115.539E**Elev: **275**StdP: **98.06**Time Zone: **8.00 (E08)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	5.9	-3.8	2.8	22.1	-1.9	3.3	21.3	11.8	15.3	10.9	14.1	3.4	150	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.7	38.2	19.3	36.4	19.0	34.7	18.7	22.2	30.9	21.2	30.4	20.4	29.8	5.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.2	24.1	18.8	14.1	23.2	17.9	13.2	22.2	66.5	30.8	62.7	30.3	59.9	29.7	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.8	10.0	DB	3.3	41.7	0.9	1.6	2.6	42.8	2.1	43.8	1.7	44.7	1.0	45.9	(4)
(5)			WB	2.1	23.3	0.7	1.4	1.5	24.3	1.1	25.1	0.7	25.9	0.1	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	25.2	25.5	23.7	20.2	16.6	13.7	12.2	12.6	13.5	16.8	20.3	23.1	(6)	
	DBStd	5.73	3.52	3.48	3.71	3.32	2.71	2.06	1.93	2.14	2.68	3.40	3.76	3.96	(7)	
	HDD10.0	9	0	0	0	0	0	1	4	3	2	0	0	0	(8)	
	HDD18.3	843	1	1	3	17	67	139	190	179	148	73	21	5	(9)	
	CDD10.0	3139	472	433	425	306	206	112	72	82	106	210	310	406	(10)	
	CDD18.3	931	214	201	169	73	14	0	0	0	2	24	81	152	(11)	
	CDH23.3	9937	2399	2242	1663	558	92	2	0	3	39	288	906	1745	(12)	
(13)	CDH26.7	4969	1323	1214	802	194	15	0	0	1	5	93	412	911	(13)	
(14)	Wind	WSAvg	5.5	6.9	6.6	6.3	5.3	4.7	4.5	4.3	4.6	5.3	6.1	6.7	(14)	
(15) Precipitation	PrecAvg	499	15	13	22	25	62	84	98	79	53	22	16	9	(15)	
	PrecMax	746	79	82	135	72	162	179	182	148	90	55	75	44	(16)	
	PrecMin	342	0	0	0	2	18	22	44	10	10	1	0	0	(17)	
	PrecStd	103	22	20	28	18	35	39	39	28	21	15	18	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.5	39.9	38.2	33.9	28.5	23.3	21.2	23.1	27.2	32.6	36.7	40.1	(19)	
		MCWB	19.5	19.9	18.9	17.0	15.1	13.0	12.3	13.9	15.0	16.8	17.8	18.8	(20)	
	2%	DB	38.0	37.5	35.8	31.2	25.9	21.3	19.0	20.6	24.0	29.2	33.9	37.2	(21)	
		MCWB	19.6	19.9	18.8	16.6	14.6	12.6	12.6	13.6	14.6	16.0	17.0	18.7	(22)	
	5%	DB	35.9	35.5	33.4	28.9	23.7	19.5	17.4	18.6	21.2	26.5	31.4	34.7	(23)	
		MCWB	19.2	19.4	18.5	16.4	14.2	12.9	12.6	13.4	14.1	15.5	16.6	18.2	(24)	
	10%	DB	33.7	33.6	31.3	26.6	21.7	17.8	16.2	17.0	18.9	24.0	28.9	32.1	(25)	
		MCWB	18.8	19.2	18.1	16.1	14.1	12.7	12.4	13.1	13.6	15.0	16.2	17.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.6	22.5	20.3	18.7	17.0	16.1	16.7	17.1	18.5	20.0	21.2	(27)	
		MCDB	32.2	31.0	30.0	26.9	21.2	18.7	17.5	19.6	22.6	26.9	30.9	33.1	(28)	
	2%	WB	22.4	22.2	21.1	19.1	17.6	15.7	14.8	15.5	15.8	17.5	18.9	20.1	(29)	
		MCDB	30.8	31.4	28.7	25.0	20.5	18.0	16.4	17.9	20.2	25.3	28.6	31.5	(30)	
	5%	WB	21.2	21.2	20.3	18.3	16.7	14.7	13.9	14.5	15.0	16.7	18.0	19.4	(31)	
		MCDB	30.2	31.1	28.3	23.8	20.0	16.9	15.7	17.1	19.2	23.7	27.0	30.5	(32)	
	10%	WB	20.2	20.3	19.4	17.5	15.8	13.8	13.1	13.5	14.1	15.9	17.2	18.6	(33)	
		MCDB	29.3	30.5	27.5	23.0	19.4	16.2	15.2	16.2	17.9	22.0	25.5	29.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	14.7	13.1	11.8	9.8	8.8	8.5	9.4	11.1	13.5	14.4	14.9	(35)	
		MCDBR	18.1	16.6	15.3	14.1	12.3	10.7	10.1	11.5	14.3	16.8	17.9	18.1	(36)	
		MCWBR	5.6	5.2	4.8	5.1	5.1	5.5	6.0	6.6	7.2	6.6	5.8	5.6	(37)	
	5% WB	MCDBR	14.6	14.7	13.2	11.5	8.9	8.3	8.1	9.4	12.0	14.4	15.5	15.9	(38)	
		MCWBR	5.4	5.1	4.8	4.9	5.2	5.7	6.1	6.4	7.1	6.7	5.6	5.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.335	0.338	0.320	0.308	0.294	0.286	0.287	0.293	0.311	0.315	0.317	0.324	(40)	
	taud		2.544	2.551	2.582	2.604	2.616	2.628	2.609	2.585	2.516	2.528	2.547	2.543	(41)	
	Ebn at Noon		1005	984	970	932	900	886	899	935	964	996	1017	1019	(42)	
	Edh at Noon		110	106	96	85	75	70	74	85	101	107	109	111	(43)	
(44) All-Sky Solar Radiation	RadAvg		8.26	7.51	6.28	4.74	3.64	3.03	3.18	4.07	5.33	6.78	7.89	8.49	(44)	
	RadStd		0.45	0.28	0.33	0.25	0.23	0.20	0.18	0.15	0.26	0.31	0.27	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page