

PERTH JANDAKOT, Australia

WMO: 946090

Lat: 32.1011S

Lon: 115.8794E

Elev: 101

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.6	38.1	29.6	23.7	67.3	32.3	26.8	58.9	27.4	60.6	24.9	61.0	2.3	110	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.0	97.8	67.7	94.5	67.2	91.1	66.5	73.3	86.0	71.1	84.8	69.6	83.3	12.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.8	110.0	77.4	67.3	100.6	75.2	65.4	94.3	74.2	37.0	85.9	35.0	85.3	33.7	83.5	96.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.7	18.8	31.1	105.1	2.2	2.3	29.5	106.8	28.2	108.1	26.9	109.4	25.3	111.0		
(5)			31.2	80.6	1.8	6.8	29.9	85.5	28.8	89.5	27.8	93.3	26.5	98.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	75.0	75.3	72.1	65.8	59.8	55.6	54.2	54.8	56.8	61.0	66.9	71.3	(6)
(7)		DBStd	9.47	6.30	6.30	6.56	5.77	4.85	4.22	4.44	4.17	4.40	5.61	6.21	6.85	(7)
(8)		HDD50	29	0	0	0	0	1	5	14	7	2	0	0	0	(8)
(9)		HDD65	1649	3	3	13	59	172	281	336	318	250	151	47	16	(9)
(10)		CDD50	5133	774	709	686	473	304	175	143	155	205	342	508	659	(10)
(11)		CDD65	1274	312	292	234	81	11	0	0	0	3	27	105	209	(11)
(12)		CDH74	13165	3317	3100	2288	670	107	2	0	6	50	306	1110	2209	(12)
(13)		CDH80	5785	1590	1478	978	188	12	0	0	0	8	85	437	1009	(13)
(14)	Wind	WSAvg	9.6	11.6	11.2	10.3	8.3	7.7	7.9	8.2	8.4	9.3	9.9	10.9	11.3	(14)
(15)	Precipitation	PrecAvg	29.9	0.5	0.5	0.9	1.5	3.8	5.7	5.9	5.0	3.1	1.5	1.1	0.4	(15)
(16)		PrecMax	38.2	4.0	5.1	2.6	3.9	7.1	9.9	8.9	7.4	6.4	4.1	2.7	2.2	(16)
(17)		PrecMin	20.0	0.0	0.0	0.0	0.2	1.2	2.0	1.9	1.3	1.0	0.2	0.0	0.0	(17)
(18)		PrecStd	4.6	0.9	1.0	0.8	1.1	1.4	2.2	1.7	1.3	1.2	0.9	0.8	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.5	101.1	99.3	90.4	81.3	73.2	70.7	73.9	79.8	88.1	96.0	100.5	(19)
(20)			MCWB	70.4	69.0	67.2	63.5	60.1	55.9	56.3	56.9	59.0	62.3	63.8	67.0	(20)
(21)		2%	DB	96.7	96.5	93.6	85.1	76.9	69.8	67.6	69.6	73.6	81.7	89.9	95.3	(21)
(22)			MCWB	67.7	68.8	66.7	63.2	59.6	57.0	56.2	57.6	58.6	61.6	63.4	66.5	(22)
(23)		5%	DB	92.9	92.9	89.3	81.2	73.4	67.4	65.2	66.6	69.8	76.8	84.7	90.6	(23)
(24)			MCWB	67.9	68.4	65.9	63.0	59.4	56.5	56.0	56.6	58.4	60.7	62.6	65.7	(24)
(25)		10%	DB	88.8	89.1	85.3	77.4	70.6	65.1	63.0	64.4	66.6	72.9	80.3	85.5	(25)
(26)			MCWB	66.9	67.4	65.4	62.7	59.0	56.0	55.2	56.0	57.1	59.6	62.1	65.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.2	79.5	73.8	69.7	66.7	63.2	62.1	62.9	65.0	68.2	69.4	73.4	(27)
(28)			MADB	89.9	86.4	82.8	76.9	71.3	66.9	65.1	66.8	70.2	74.1	82.8	87.8	(28)
(29)		2%	WB	72.7	73.4	71.0	67.8	64.5	61.2	59.8	60.6	61.9	64.5	67.0	69.6	(29)
(30)			MADB	86.8	86.4	82.6	75.4	69.7	65.1	63.3	65.0	68.1	75.0	80.2	85.4	(30)
(31)		5%	WB	70.5	71.0	69.3	66.3	62.8	59.5	58.2	59.0	60.0	62.8	65.3	68.0	(31)
(32)			MADB	85.2	85.8	80.4	74.7	69.2	63.7	62.1	63.8	66.6	72.7	78.4	84.0	(32)
(33)		10%	WB	68.8	69.3	67.7	64.7	61.0	57.9	56.7	57.4	58.3	61.2	63.7	66.4	(33)
(34)			MADB	83.4	84.1	80.2	73.7	67.4	62.5	61.2	62.4	65.0	69.9	76.1	80.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.7	24.0	23.3	22.4	21.8	19.6	18.7	19.6	20.0	22.0	22.5	22.9	(35)
(36)			MCDBR	29.4	28.5	28.2	26.5	26.3	22.8	21.1	23.7	26.2	27.5	29.8	29.9	(36)
(37)			MCWBR	10.9	10.7	10.2	11.2	13.2	13.0	12.6	13.8	14.2	12.6	11.5	11.2	(37)
(38)		5% WB	MCDBR	23.8	24.1	21.8	20.4	18.7	17.0	15.5	17.4	20.6	22.4	24.2	25.2	(38)
(39)			MCWBR	10.8	11.1	10.6	10.9	11.8	12.0	11.3	11.9	13.1	12.4	11.3	11.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.339	0.324	0.317	0.308	0.302	0.302	0.308	0.327	0.327	0.328	0.328	(40)	
(41)		taud	2.582	2.599	2.634	2.640	2.638	2.632	2.628	2.606	2.529	2.548	2.568	2.591	(41)	
(42)		Ebn at Noon	317	311	305	291	278	272	277	290	299	312	318	322	(42)	
(43)		Edh at Noon	33	32	29	26	23	22	23	26	31	33	34	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2594	2335	1925	1398	1040	846	896	1170	1565	2046	2444	2655	(44)	
(45)		RadStd	121	82	94	83	68	58	57	60	92	89	108	109	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.56	N/A	N/A	+1.19	N/A	+0.85	N/A	N/A	N/A	+115
(47) Regional (20 neighbors)		N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page