

PERTH AP, Australia

WMO: 946100

Lat: 31.9275S

Lon: 115.9764E

Elev: 66

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.9	41.0	27.5	21.5	74.5	30.9	25.2	71.6	25.0	61.1	22.5	61.0	3.7	30	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.6	99.4	66.9	96.2	66.6	92.9	66.2	72.3	87.3	70.6	86.0	69.2	84.5	12.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.1	103.4	76.8	66.2	96.8	75.5	64.5	91.2	74.3	36.1	86.8	34.5	85.9	33.4	84.5	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.7	22.1	20.1	DB	34.2	106.6	2.2	2.1	32.6	108.1	31.4	109.3	30.1	110.4	28.6	111.9
			WB	33.7	75.4	2.2	2.1	32.1	77.0	30.8	78.2	29.6	79.4	28.0	80.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	76.3	76.8	73.5	67.4	61.5	57.2	55.4	56.1	58.2	62.5	68.4	72.8	(6)
	DBStd	9.42	6.36	6.23	6.46	5.83	4.81	3.99	3.96	3.88	4.28	5.50	6.23	6.80	(7)
	HDD50	10	0	0	0	0	0	2	6	2	0	0	0	0	(8)
	HDD65	1358	2	1	7	39	130	236	297	277	210	118	31	10	(9)
	CDD50	5641	816	749	729	521	355	217	174	191	246	386	551	706	(10)
	CDD65	1512	352	331	271	110	20	1	0	1	5	39	132	250	(11)
	CDH74	15913	3916	3629	2688	888	162	4	1	10	74	417	1399	2725	(12)
	CDH80	7351	1982	1829	1212	274	24	0	0	0	12	120	585	1313	(13)
(14) Wind	WSAvg	10.4	12.5	12.4	11.5	9.4	8.5	8.6	8.6	8.9	9.7	10.7	12.0	12.6	(14)
(15) Precipitation	PrecAvg	29.4	0.3	0.6	0.7	1.5	3.7	5.8	5.9	4.6	3.0	1.6	1.0	0.4	(15)
	PrecMax	41.0	2.5	5.9	2.5	5.1	9.0	12.5	9.8	7.6	6.7	4.9	3.3	2.6	(16)
	PrecMin	18.2	0.0	0.0	0.0	0.0	0.6	0.9	1.2	0.7	0.5	0.0	0.1	0.0	(17)
	PrecStd	5.5	0.5	1.0	0.7	1.1	1.9	2.6	1.9	1.5	1.3	0.9	0.8	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.0	103.3	101.0	91.8	82.9	73.8	71.8	75.1	80.8	89.7	97.6	102.5	(19)
		MCWB	67.8	69.0	66.3	62.7	60.0	56.8	56.4	57.4	59.1	62.6	62.9	66.4	(20)
	2%	DB	98.5	98.3	95.2	86.6	78.4	70.7	68.2	70.8	75.4	82.7	91.5	97.1	(21)
		MCWB	67.0	68.0	66.6	63.0	59.4	56.9	56.1	57.2	58.2	61.0	63.4	65.7	(22)
	5%	DB	94.8	94.6	91.0	82.7	74.8	68.2	66.0	67.8	71.3	78.6	86.5	92.5	(23)
		MCWB	67.4	67.4	65.7	62.7	59.3	56.6	55.7	56.3	57.7	60.3	62.6	65.0	(24)
	10%	DB	90.7	90.8	86.6	79.0	71.6	66.0	64.0	65.2	68.0	74.3	82.3	87.5	(25)
		MCWB	66.5	67.1	65.0	62.2	58.6	55.9	55.0	55.5	56.7	59.6	61.9	64.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	75.2	72.6	69.3	66.7	63.1	61.9	62.7	63.3	66.3	68.8	71.0	(27)
		MCDB	88.9	90.6	85.4	78.0	71.7	67.3	65.6	67.6	72.9	79.4	84.0	88.8	(28)
	2%	WB	72.2	72.7	70.5	67.5	64.5	61.2	59.7	60.3	61.3	64.1	66.9	69.2	(29)
		MCDB	87.8	87.5	83.2	76.5	70.2	65.9	63.5	65.2	69.3	76.5	81.9	87.2	(30)
	5%	WB	70.3	70.7	69.0	66.1	62.8	59.5	58.1	58.8	59.7	62.5	65.4	67.5	(31)
		MCDB	86.5	86.9	81.7	76.0	69.5	64.2	62.3	64.5	67.4	74.1	79.6	85.0	(32)
	10%	WB	68.7	69.1	67.5	64.6	61.0	58.0	56.8	57.1	58.2	61.0	63.8	66.1	(33)
		MCDB	84.5	85.1	80.8	74.6	68.2	62.8	61.4	62.9	65.7	70.8	77.0	82.2	(34)
(35) Mean Daily Temperature Range	MDBR		24.5	24.6	23.6	22.2	20.5	18.2	18.0	19.0	19.9	22.1	23.3	24.2	(35)
	5% DB	MCDBR	30.4	29.5	28.9	25.9	24.5	20.7	19.8	22.7	25.6	28.2	30.9	31.4	(36)
		MCWBR	10.5	9.9	9.8	10.4	11.2	11.1	11.0	12.1	12.3	12.2	11.5	10.7	(37)
	5% WB	MCDBR	24.8	24.6	22.2	20.0	18.4	16.7	15.8	17.3	20.4	23.1	25.2	26.4	(38)
		MCWBR	10.2	10.1	9.5	10.2	10.7	10.8	10.8	10.8	11.4	11.2	11.0	10.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.341	0.341	0.326	0.318	0.308	0.301	0.300	0.307	0.328	0.328	0.329	0.329	(40)
	taud		2.569	2.584	2.619	2.627	2.626	2.628	2.627	2.599	2.517	2.535	2.556	2.577	(41)
	Ebn at Noon		317	310	305	291	278	272	278	290	299	311	318	321	(42)
	Edh at Noon		34	32	29	26	23	22	23	26	32	34	34	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2598	2341	1934	1412	1055	862	913	1184	1580	2058	2453	2660	(44)
	RadStd		122	82	95	83	70	59	57	58	90	92	106	112	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.88	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page