

PERTH AP, Australia

WMO: 946100

Lat: 31.9275S

Lon: 115.9764E

Elev: 20

StdP: 101.08

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	5.0	-2.5	3.1	23.6	-0.6	3.6	22.0	11.2	16.2	10.1	16.1	1.7	30	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.6	37.5	19.4	35.7	19.2	33.8	19.0	22.4	30.7	21.5	30.0	20.7	29.2	5.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	14.8	24.9	19.0	13.8	24.2	18.1	13.0	23.5	66.1	30.4	62.5	29.9	59.7	29.2	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.9	9.0	DB	1.2	41.4	1.2	1.2	0.3	42.3	-0.4	42.9	-1.0	43.6	-1.9	44.4	(4)
(5)			WB	0.9	24.1	1.2	1.2	0.1	25.0	-0.7	25.7	-1.3	26.3	-2.2	27.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	24.6	24.9	23.1	19.7	16.4	14.0	13.0	13.4	14.5	16.9	20.2	22.6	(6)	
	DBStd	5.23	3.54	3.46	3.59	3.24	2.67	2.22	2.20	2.16	2.38	3.06	3.46	3.78	(7)	
	HDD10.0	6	0	0	0	0	0	1	3	1	0	0	0	0	(8)	
	HDD18.3	754	1	1	4	22	72	131	165	154	117	66	17	6	(9)	
	CDD10.0	3134	453	416	405	289	197	121	97	106	137	214	306	392	(10)	
	CDD18.3	840	196	184	151	61	11	1	0	1	3	22	73	139	(11)	
	CDH23.3	8841	2176	2016	1493	493	90	2	1	6	41	232	777	1514	(12)	
	CDH26.7	4084	1101	1016	673	152	13	0	0	0	7	67	325	729	(13)	
(14) Wind	WSAvg	4.7	5.6	5.5	5.1	4.2	3.8	3.8	3.9	4.0	4.3	4.8	5.3	5.6	(14)	
(15) Precipitation	PrecAvg	747	8	15	18	39	94	148	151	116	75	40	25	10	(15)	
	PrecMax	1041	63	150	63	130	229	318	248	193	169	125	85	66	(16)	
	PrecMin	463	0	0	0	0	15	22	31	18	12	1	2	0	(17)	
	PrecStd	140	12	25	19	29	48	67	48	39	33	23	21	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.0	39.6	38.3	33.2	28.3	23.2	22.1	23.9	27.1	32.1	36.4	39.2	(19)	
		MCWB	19.9	20.6	19.1	17.1	15.6	13.8	13.6	14.1	15.0	17.0	17.1	19.1	(20)	
	2%	DB	36.9	36.9	35.1	30.4	25.8	21.5	20.1	21.6	24.1	28.2	33.1	36.2	(21)	
		MCWB	19.5	20.0	19.2	17.2	15.2	13.8	13.4	14.0	14.6	16.1	17.4	18.7	(22)	
	5%	DB	34.9	34.8	32.8	28.2	23.8	20.1	18.9	19.9	21.8	25.9	30.3	33.6	(23)	
		MCWB	19.7	19.6	18.7	17.0	15.1	13.7	13.2	13.5	14.3	15.7	17.0	18.3	(24)	
	10%	DB	32.6	32.7	30.3	26.1	22.0	18.9	17.8	18.5	20.0	23.5	27.9	30.8	(25)	
		MCWB	19.2	19.5	18.4	16.8	14.8	13.3	12.8	13.0	13.7	15.3	16.6	18.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	24.0	22.5	20.7	19.3	17.3	16.6	17.1	17.4	19.0	20.5	21.7	(27)	
		MCDB	31.6	32.6	29.7	25.6	22.0	19.6	18.7	19.8	22.7	26.3	28.9	31.6	(28)	
	2%	WB	22.3	22.6	21.4	19.7	18.0	16.2	15.4	15.7	16.3	17.8	19.4	20.7	(29)	
		MCDB	31.0	30.8	28.4	24.7	21.2	18.8	17.5	18.5	20.7	24.7	27.7	30.7	(30)	
	5%	WB	21.3	21.5	20.6	18.9	17.1	15.3	14.5	14.9	15.4	17.0	18.5	19.7	(31)	
		MCDB	30.3	30.5	27.6	24.4	20.9	17.9	16.9	18.0	19.6	23.4	26.5	29.5	(32)	
	10%	WB	20.4	20.6	19.7	18.1	16.1	14.4	13.8	14.0	14.6	16.1	17.7	18.9	(33)	
		MCDB	29.2	29.5	27.1	23.6	20.1	17.1	16.3	17.1	18.7	21.6	25.0	27.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	13.6	13.1	12.4	11.4	10.1	10.0	10.6	11.0	12.3	12.9	13.4	(35)	
		MCDBR	16.9	16.4	16.0	14.4	13.6	11.5	11.0	12.6	14.2	15.7	17.1	17.4	(36)	
	5% WB	MCWBR	5.8	5.5	5.4	5.8	6.2	6.2	6.1	6.7	6.9	6.8	6.4	5.9	(37)	
		MCDWR	13.8	13.7	12.3	11.1	10.2	9.3	8.8	9.6	11.3	12.8	14.0	14.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.341	0.341	0.326	0.318	0.308	0.301	0.300	0.307	0.328	0.328	0.329	0.329	(40)	
		taud	2.569	2.584	2.619	2.627	2.626	2.628	2.627	2.599	2.517	2.535	2.556	2.577	(41)	
	Ebn at Noon	Ebn at Noon	998	978	961	917	877	859	877	915	942	981	1003	1013	(42)	
		Edh at Noon	107	102	92	82	73	69	72	83	100	106	108	107	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	8.19	7.38	6.10	4.45	3.33	2.72	2.88	3.73	4.98	6.49	7.73	8.38	(44)	
	RadStd	RadStd	0.39	0.26	0.30	0.26	0.22	0.19	0.18	0.18	0.28	0.29	0.34	0.35	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page