

PERTH SWANBOURNE, Australia

WMO: 946140

Lat: 31.9558S

Lon: 115.7619E

Elev: 41

StdP: 100.83

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	7.6	0.4	3.9	17.4	1.9	4.4	15.9	16.4	16.2	14.4	15.8	3.8	80	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.0	35.0	19.9	32.7	19.7	30.7	19.4	23.1	28.4	22.2	27.2	21.5	26.4	4.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	16.5	24.9	20.8	15.5	24.0	20.0	14.8	23.7	68.6	28.3	65.2	27.1	62.8	26.3	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	10.5	9.3	DB	4.4	39.7	0.9	1.6	3.8	40.9	3.3	41.8	2.8	42.8	2.1	44.0	
			WB	3.5	24.4	0.9	1.3	2.9	25.3	2.3	26.0	1.8	26.7	1.2	27.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	23.5	23.9	22.6	19.9	17.1	14.9	13.9	14.1	15.1	16.9	19.7	21.8
	DBStd	4.48	3.14	3.25	3.26	2.74	2.31	2.00	2.03	1.96	2.18	2.59	2.99	3.47
	HDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0
	HDD18.3	623	1	1	3	13	52	105	138	131	101	60	16	4
	CDD10.0	3131	417	389	389	297	220	146	121	128	152	214	291	365
	CDD18.3	710	159	156	133	61	13	1	0	1	3	16	57	111
	CDH23.3	4988	1214	1263	949	272	43	1	0	2	14	96	345	788
Wind	WSAvg	4.9	5.3	5.1	5.0	4.4	4.5	4.7	4.9	4.8	5.0	4.9	5.3	5.4
	PrecAvg	731	11	12	23	39	93	143	144	124	73	36	24	10
	PrecMax	926	107	115	74	110	168	256	231	194	156	100	64	46
	PrecMin	530	0	0	0	7	43	48	64	30	23	2	0	0
	PrecStd	107	22	22	21	26	32	57	43	33	30	22	19	11
	DB	37.3	37.1	36.6	31.7	26.9	22.7	21.4	22.6	24.9	29.9	33.9	36.6	
	MCWB	20.4	21.0	20.6	18.3	15.9	14.2	13.9	14.7	15.2	17.1	18.0	19.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	33.8	34.3	32.7	28.5	24.4	21.0	19.6	20.4	22.0	26.0	30.1	33.1	
	2% MCWB	20.1	20.5	19.6	17.7	16.3	14.6	14.3	14.8	15.3	16.1	17.7	19.2	
	5% DB	31.2	32.0	30.3	26.2	22.7	19.8	18.6	19.1	20.3	23.2	27.1	30.2	
	5% MCWB	19.9	20.5	19.0	17.8	16.0	14.4	14.1	14.5	15.3	16.3	17.1	18.8	
	10% DB	28.9	29.7	28.0	24.4	21.4	18.7	17.6	18.1	19.0	21.4	24.7	27.5	
	10% MCWB	19.8	20.1	18.8	17.7	15.9	14.3	13.8	14.2	14.8	16.0	17.3	18.4	
	WB	24.1	24.8	23.2	21.7	20.2	18.0	17.5	17.9	18.6	19.6	21.0	22.6	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	29.3	30.9	27.0	24.3	22.2	19.4	18.6	19.6	20.6	23.7	25.1	29.1	
	2% WB	22.9	23.4	22.2	20.7	18.9	17.1	16.2	16.7	17.2	18.5	20.0	21.6	
	2% MCDB	28.4	28.6	26.4	23.8	21.2	18.8	17.7	18.4	19.6	22.3	24.3	27.1	
	5% WB	21.9	22.3	21.4	19.9	18.0	16.2	15.4	15.7	16.3	17.7	19.3	20.8	
	5% MCDB	27.0	27.7	25.9	23.2	20.6	18.1	17.1	17.7	18.9	21.1	23.7	26.2	
	10% WB	21.2	21.5	20.7	19.1	17.0	15.3	14.6	14.9	15.5	16.8	18.5	20.0	
	10% MCDB	26.3	26.9	25.5	22.6	20.1	17.5	16.6	17.1	18.2	20.4	23.0	25.2	
Mean Daily Temperature Range	MDBR	9.7	10.0	9.8	8.9	8.5	7.7	7.4	7.8	7.9	8.6	8.9	9.3	
	5% DB	13.7	13.7	13.2	11.5	10.3	9.0	8.5	9.1	10.1	11.9	13.5	13.7	
	MCWBR	6.1	5.9	5.6	5.7	5.6	5.3	5.2	5.6	5.9	6.3	6.4	6.2	
	5% WB	10.1	10.0	9.2	8.1	7.5	6.7	6.3	6.9	8.0	9.1	9.5	10.4	
	MCWBR	5.4	5.3	5.1	5.3	5.5	5.2	5.1	5.3	5.7	5.6	5.5	5.5	
Clear-Sky Solar Irradiance	taub	0.339	0.339	0.324	0.317	0.307	0.302	0.300	0.308	0.326	0.326	0.327	0.328	
	taud	2.592	2.606	2.643	2.646	2.646	2.640	2.641	2.614	2.541	2.558	2.579	2.598	
	Ebn at Noon	1000	981	963	918	878	858	877	914	944	983	1005	1015	
	Edh at Noon	104	100	90	81	72	68	71	82	98	103	105	104	
All-Sky Solar Radiation	RadAvg	8.19	7.38	6.10	4.45	3.31	2.70	2.86	3.73	4.99	6.50	7.75	8.39	
	RadStd	0.37	0.25	0.29	0.26	0.21	0.19	0.18	0.18	0.29	0.27	0.32	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-1.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page