

DWELLINGUP, Australia

WMO: 946200

Lat: 32.7103S

Lon: 116.0594E

Elev: 879

StdP: 14.23

Time Zone: 8.00 (E08)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.9	36.9	31.4	26.6	55.8	33.4	28.9	52.0	22.6	60.7	20.4	58.3	7.9	110	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.8	94.7	66.0	91.5	65.4	88.5	64.7	69.9	84.7	68.2	84.0	66.8	82.2	8.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	97.7	72.9	63.7	91.1	72.1	61.9	85.6	71.2	34.4	83.8	33.0	83.8	31.9	82.3	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.3	16.5	30.8	101.0	1.3	2.7	29.8	102.9	29.1	104.5	28.3	106.0	27.4	108.0		
(5)			30.2	72.4	1.4	2.2	29.2	74.0	28.4	75.3	27.6	76.6	26.6	78.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	72.1	72.3	68.7	62.4	56.2	52.3	50.8	51.3	53.2	57.8	64.2	68.9		
	DBStd	9.44	5.72	5.70	6.00	5.33	4.28	3.94	3.86	3.84	4.33	5.28	6.18	6.44		
	HDD50	110	0	0	0	0	4	20	38	30	16	2	0	0		
	HDD65	2392	9	9	32	112	275	381	442	426	353	231	90	32		
	CDD50	4048	686	625	581	372	196	89	61	69	114	245	425	585		
	CDD65	853	231	214	147	34	2	0	0	0	0	9	64	152		
	CDH74	9135	2539	2193	1368	286	17	0	0	1	17	146	786	1782		
	CDH80	3812	1172	972	518	57	1	0	0	0	2	31	273	786		
(14) Wind	WSAvg	9.3	10.9	10.6	10.2	8.9	7.7	8.1	8.3	8.8	8.7	9.2	10.2	10.2		
(15) Precipitation	PrecAvg	49.2	0.6	0.9	1.1	2.8	6.1	9.5	9.3	7.3	5.1	3.3	1.8	0.7		
	PrecMax	72.0	4.0	4.4	4.4	6.1	12.8	23.6	19.5	12.0	11.8	8.4	4.7	2.3		
	PrecMin	31.4	0.0	0.0	0.0	0.0	1.3	1.8	3.7	2.0	0.5	0.1	0.0	0.0		
	PrecStd	8.8	0.9	1.2	1.2	1.8	2.9	4.1	3.3	2.6	2.3	1.8	1.1	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.2	98.1	95.7	85.4	76.2	68.1	66.2	69.6	76.1	84.3	92.6	97.6		
		MCWB	65.9	67.2	65.7	62.8	58.9	55.3	54.6	54.9	57.6	61.7	62.4	64.0		
	2%	DB	94.2	93.0	89.8	81.1	71.4	65.2	63.0	65.3	70.4	77.9	87.4	92.9		
		MCWB	66.1	66.7	65.3	61.9	57.7	55.2	54.6	55.3	56.7	60.3	62.5	65.2		
	5%	DB	90.8	89.9	85.7	77.0	68.1	62.9	60.7	62.3	66.1	73.4	82.5	88.7		
		MCWB	65.6	65.8	64.3	61.3	57.1	55.1	54.0	54.9	55.6	58.9	61.5	63.9		
	10%	DB	86.9	86.6	81.8	73.3	65.4	60.7	58.7	59.9	62.5	69.2	78.3	84.0		
		MCWB	64.8	65.0	63.4	60.3	57.2	54.3	53.5	53.8	54.5	57.4	60.4	62.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.9	73.1	70.0	66.7	64.2	60.5	59.5	60.9	60.9	64.5	67.0	69.2		
		MCDB	86.4	87.2	83.6	74.5	68.0	63.3	62.1	63.6	68.8	77.4	83.4	88.1		
	2%	WB	70.0	69.9	68.0	64.9	61.8	58.6	57.4	58.3	58.8	62.0	64.9	67.2		
		MCDB	83.6	85.7	82.0	73.2	66.0	61.6	59.7	61.2	65.9	73.7	80.2	85.8		
	5%	WB	68.1	68.1	66.5	63.4	60.0	57.0	55.7	56.6	57.1	60.1	63.2	65.6		
		MCDB	84.0	84.6	79.4	71.9	64.8	60.2	58.3	60.0	63.3	70.3	76.8	83.8		
	10%	WB	66.3	66.5	65.0	61.9	58.4	55.5	54.3	54.8	55.6	58.5	61.5	63.8		
		MCDB	83.1	81.6	77.5	70.5	63.4	59.2	57.4	58.7	60.9	67.0	73.9	80.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	25.8	25.4	23.5	21.0	19.5	17.2	16.4	17.4	18.4	20.5	22.8	25.1		
		MCDBR	32.1	30.5	29.2	26.6	24.3	20.5	19.1	22.2	26.1	28.1	31.1	32.0		
		MCWBR	10.6	10.0	9.9	11.1	12.8	12.4	12.2	13.6	13.9	13.0	11.3	10.6		
		MCDBR	25.6	25.7	22.8	20.4	17.0	15.0	13.8	15.6	20.0	23.5	25.8	27.6		
	5% WB	MCWBR	10.2	9.8	9.0	10.0	10.8	11.0	10.7	11.8	12.0	12.1	11.0	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.324	0.313	0.304	0.300	0.294	0.292	0.300	0.320	0.317	0.320	0.317		
	taud		2.594	2.618	2.641	2.661	2.634	2.631	2.635	2.602	2.517	2.552	2.569	2.599		
	Ebn at Noon		321	316	309	295	280	273	280	292	301	314	321	325		
	Edh at Noon		33	31	29	25	23	22	23	26	32	33	34	33		
(44) All-Sky Solar Radiation	RadAvg		2570	2304	1880	1347	992	804	854	1117	1500	1973	2381	2615		
	RadStd		130	87	94	86	67	52	54	62	89	94	125	121		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page