

DWELLINGUP, Australia

WMO: 946200

Lat: 32.7103S

Lon: 116.0594E

Elev: 268

StdP: 98.15

Time Zone: 8.00 (E08)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.6	2.7	-0.3	3.8	13.2	0.8	4.1	11.1	10.1	16.0	9.1	14.6	3.5	110	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	34.8	18.9	33.1	18.6	31.4	18.2	21.0	29.3	20.1	28.9	19.4	27.9	3.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	14.0	22.7	17.6	13.0	22.3	16.6	12.2	21.8	62.1	28.8	58.8	28.8	56.2	27.9	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	8.2	7.4	-0.7	38.3	0.7	1.5	-1.2	39.4	-1.6	40.3	-2.0	41.1	-2.6	42.2		
			-1.0	22.5	0.8	1.2	-1.5	23.4	-2.0	24.1	-2.4	24.8	-3.0	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	22.3	22.4	20.4	16.9	13.4	11.3	10.4	10.7	11.8	14.4	17.9	20.5
	DBStd	5.24	3.18	3.16	3.33	2.96	2.38	2.19	2.14	2.13	2.40	2.93	3.44	3.58
	HDD10.0	61	0	0	0	0	2	11	21	17	9	1	0	0
	HDD18.3	1329	5	5	18	62	153	212	246	237	196	128	50	18
	CDD10.0	2249	381	347	323	207	109	49	34	38	63	136	236	325
	CDD18.3	474	128	119	82	19	1	0	0	0	5	36	84	
	CDH23.3	5075	1411	1218	760	159	9	0	0	1	9	81	437	990
CDH26.7	2118	651	540	288	32	1	0	0	0	1	17	152	437	
Wind	WSAvg	4.2	4.9	4.7	4.6	4.0	3.5	3.6	3.7	3.9	3.9	4.1	4.6	4.6
Precipitation	PrecAvg	1250	15	23	28	70	155	242	236	185	130	83	45	19
	PrecMax	1829	102	113	113	154	325	599	495	306	299	213	119	59
	PrecMin	798	0	0	0	0	32	45	94	52	12	3	0	0
	PrecStd	223	24	31	31	46	74	103	84	66	58	45	29	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	36.7	35.4	29.7	24.6	20.0	19.0	20.9	24.5	29.0	33.7	36.4
		MCWB	18.8	19.6	18.7	17.1	14.9	12.9	12.5	12.7	14.2	16.5	16.9	17.8
	2%	DB	34.5	33.9	32.1	27.3	21.9	18.5	17.2	18.5	21.3	25.5	30.8	33.9
		MCWB	19.0	19.3	18.5	16.6	14.3	12.9	12.6	13.0	13.7	15.7	17.0	18.4
	5%	DB	32.7	32.2	29.9	25.0	20.0	17.2	15.9	16.8	18.9	23.0	28.1	31.5
		MCWB	18.7	18.8	17.9	16.3	14.0	12.8	12.2	12.7	13.1	14.9	16.4	17.7
	10%	DB	30.5	30.3	27.7	23.0	18.6	16.0	14.8	15.5	17.0	20.7	25.7	28.9
		MCWB	18.2	18.3	17.4	15.7	14.0	12.4	11.9	12.1	12.5	14.1	15.8	17.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	22.8	21.1	19.3	17.9	15.8	15.3	16.0	16.1	18.1	19.4	20.7
		MCDB	30.2	30.7	28.7	23.6	20.0	17.4	16.7	17.6	20.5	25.2	28.6	31.2
	2%	WB	21.1	21.1	20.0	18.3	16.5	14.8	14.1	14.6	14.9	16.7	18.3	19.6
		MCDB	28.6	29.8	27.8	22.9	18.9	16.4	15.4	16.2	18.8	23.2	26.8	29.9
	5%	WB	20.0	20.0	19.2	17.4	15.6	13.9	13.2	13.7	14.0	15.6	17.4	18.7
		MCDB	28.9	29.2	26.3	22.2	18.2	15.7	14.6	15.6	17.4	21.3	24.9	28.8
	10%	WB	19.1	19.2	18.4	16.6	14.6	13.1	12.4	12.7	13.1	14.7	16.4	17.6
		MCDB	28.4	27.5	25.3	21.4	17.4	15.1	14.1	14.8	16.1	19.4	23.3	26.9
Mean Daily Temperature Range	5% DB	MDBR	14.4	14.1	13.1	11.7	10.8	9.6	9.1	9.7	10.2	11.4	12.7	13.9
		MCDBR	17.9	16.9	16.2	14.8	13.5	11.4	10.6	12.3	14.5	15.6	17.3	17.8
		MCWBR	5.9	5.6	5.5	6.2	7.1	6.9	6.8	7.6	7.7	7.2	6.3	5.9
	5% WB	MCDBR	14.2	14.3	12.7	11.3	9.4	8.3	7.7	8.7	11.1	13.1	14.3	15.3
		MCWBR	5.7	5.4	5.0	5.5	6.0	6.1	6.0	6.5	6.6	6.7	6.1	5.8
Clear-Sky Solar Irradiance	taub	0.326	0.324	0.313	0.304	0.300	0.294	0.292	0.300	0.320	0.317	0.320	0.317	
	taud	2.594	2.618	2.641	2.661	2.634	2.631	2.635	2.602	2.517	2.552	2.569	2.599	
	Ebn at Noon	1012	995	973	930	882	862	882	919	948	991	1012	1025	
	Edh at Noon	104	98	90	79	72	68	71	82	100	104	106	104	
All-Sky Solar Radiation	RadAvg	8.10	7.26	5.93	4.25	3.13	2.53	2.69	3.52	4.73	6.22	7.50	8.24	
	RadStd	0.41	0.27	0.30	0.27	0.21	0.16	0.17	0.20	0.28	0.30	0.39	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page