

NEWDEGATE, Australia

WMO: 946280

Lat: 33.1131S

Lon: 118.8400E

Elev: 321

StdP: 97.53

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.4	1.6	-4.1	2.8	17.4	-2.2	3.3	14.9	12.9	14.8	11.8	14.0	0.7	130	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.0	37.0	18.0	34.8	17.7	32.7	17.2	20.5	29.2	19.5	29.1	18.6	28.5	5.5	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.6	22.5	16.9	12.5	21.2	15.8	11.7	20.4	60.5	28.9	56.8	29.2	54.0	28.3	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	10.0	9.0	-2.0	41.5	0.9	1.8	-2.7	42.8	-3.2	43.8	-3.7	44.8	-4.3	46.1
			-2.5	22.7	0.9	2.0	-3.2	24.2	-3.7	25.3	-4.2	26.5	-4.9	28.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	22.1	21.9	20.0	16.9	13.2	10.7	9.6	10.1	11.5	15.0	18.4	20.3	(6)
	DBStd	5.43	3.44	3.35	3.52	3.20	2.56	2.13	2.03	2.13	2.75	3.28	3.63	3.57	(7)
	HDD10.0	93	0	0	0	0	3	17	33	25	14	1	0	0	(8)
	HDD18.3	1403	6	7	23	66	162	230	270	256	207	114	45	19	(9)
	CDD10.0	2192	376	332	308	206	101	37	21	28	58	156	251	319	(10)
	CDD18.3	462	123	106	73	21	2	0	0	0	1	10	46	80	(11)
	CDH23.3	6056	1532	1227	823	242	18	1	0	2	32	258	728	1194	(12)
	CDH26.7	2855	802	602	357	67	2	0	0	0	5	91	321	609	(13)
(14) Wind	WSAvg	4.4	5.5	5.3	4.8	3.9	3.4	3.7	4.0	3.9	4.2	4.4	4.8	4.9	(14)
(15) Precipitation	PrecAvg	360	21	13	27	24	37	39	49	42	31	24	23	17	(15)
	PrecMax	549	162	41	90	106	81	92	82	117	61	67	66	115	(16)
	PrecMin	201	0	0	1	0	5	8	14	13	3	1	0	0	(17)
	PrecStd	81	40	12	27	22	22	19	19	22	15	18	16	24	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.6	38.6	36.3	32.0	25.4	21.4	19.0	21.8	26.9	32.7	36.3	39.8	(19)
		MCWB	19.5	19.6	17.8	16.2	14.2	12.3	11.4	13.1	14.0	15.5	17.1	18.0	(20)
	2%	DB	36.8	35.5	33.7	28.5	22.9	19.2	17.0	19.0	23.2	29.4	33.5	36.1	(21)
		MCWB	18.2	18.5	17.3	15.8	13.5	11.7	11.2	12.3	13.3	15.1	16.1	17.7	(22)
	5%	DB	34.0	33.2	30.7	26.1	20.8	17.4	15.5	17.0	20.4	26.1	30.6	32.9	(23)
		MCWB	17.6	18.1	17.1	15.2	13.0	11.3	11.1	11.9	12.6	14.3	15.5	16.6	(24)
	10%	DB	31.3	30.4	27.9	23.8	19.0	15.7	14.2	15.4	18.2	23.3	27.8	29.9	(25)
		MCWB	17.6	17.5	16.5	14.9	12.8	11.1	10.7	11.3	11.9	13.4	14.9	16.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	23.5	20.2	18.9	16.9	14.8	13.9	14.7	15.7	17.4	18.7	20.0	(27)
		MCDB	31.3	29.7	26.8	24.1	19.9	17.7	16.3	18.5	23.3	26.7	29.7	30.6	(28)
	2%	WB	20.6	20.7	19.2	17.7	15.6	13.5	12.7	13.6	14.2	16.0	17.5	18.5	(29)
		MCDB	30.3	28.8	27.4	23.7	19.3	16.7	15.1	17.2	20.9	25.6	28.9	31.6	(30)
	5%	WB	19.4	19.5	18.4	16.8	14.6	12.5	11.8	12.6	13.3	15.0	16.6	17.6	(31)
		MCDB	30.5	28.6	26.6	22.8	18.4	15.6	14.3	16.0	18.7	24.0	27.0	30.2	(32)
	10%	WB	18.3	18.5	17.6	15.8	13.6	11.7	10.9	11.6	12.4	14.1	15.7	16.7	(33)
		MCDB	28.6	28.0	25.4	21.6	17.5	14.7	13.7	14.6	17.3	22.0	25.4	27.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	15.1	14.0	12.9	11.8	10.6	9.6	10.8	13.2	15.1	15.8	16.5	(35)
		MCDBR	21.0	19.9	18.3	16.4	14.8	13.9	11.6	14.3	17.9	20.4	21.0	22.1	(36)
	5% WB	MCWBR	6.0	5.7	5.8	6.4	7.6	8.0	7.3	8.7	9.2	8.1	6.6	6.4	(37)
		MCWBR	17.4	16.2	14.2	12.2	10.4	10.3	9.4	11.6	14.7	17.1	17.6	19.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.335	0.328	0.315	0.303	0.290	0.283	0.285	0.289	0.308	0.317	0.321	0.325	(40)
		taud	2.514	2.551	2.575	2.599	2.606	2.602	2.591	2.582	2.502	2.501	2.512	2.521	(41)
	Ebn at Noon		1003	990	969	927	890	871	886	930	960	990	1010	1017	(42)
		Edh at Noon	113	105	95	83	73	69	73	83	101	109	112	113	(43)
(44) All-Sky Solar Radiation	RadAvg		7.87	6.97	5.72	4.22	3.15	2.63	2.81	3.63	4.87	6.29	7.33	8.06	(44)
	RadStd		0.49	0.39	0.31	0.27	0.21	0.12	0.15	0.16	0.21	0.36	0.45	0.45	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page