

ROCKY GULLY, Australia

WMO: 946310

Lat: 34.5712S

Lon: 117.0106E

Elev: 822

StdP: 14.26

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.1	40.6	33.6	29.1	57.4	35.7	31.6	51.2	22.5	54.0	20.3	53.8	5.1	0	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.0	90.4	64.4	86.1	64.2	82.2	63.0	67.9	81.2	66.4	78.9	65.0	76.7	10.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	93.5	69.8	62.8	88.0	68.8	61.3	83.6	67.6	32.7	81.0	31.4	78.7	30.4	77.1	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	17.6	15.9	35.1	99.4	1.6	3.0	34.0	101.6	33.0	103.3	32.1	105.0	30.9	107.2
			34.5	71.8	1.7	2.6	33.3	73.6	32.3	75.1	31.4	76.6	30.2	78.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.4	66.5	66.9	64.7	60.4	56.2	52.6	50.5	51.2	52.4	55.7	60.5	63.5	(6)
	DBStd	7.71	5.61	5.74	6.06	5.54	4.33	3.61	3.38	3.75	4.38	5.19	6.07	6.08	(7)
	HDD50	110	0	0	0	0	3	14	35	28	23	6	1	0	(8)
	HDD65	2787	48	41	79	160	275	371	449	427	379	293	163	102	(9)
	CDD50	3171	510	472	457	313	196	94	51	67	94	183	316	418	(10)
	CDD65	372	94	93	71	23	2	0	0	0	0	5	29	55	(11)
	CDH74	3665	936	836	613	167	14	0	0	0	4	72	356	667	(12)
	CDH80	1315	347	305	230	37	1	0	0	0	0	13	124	258	(13)
(14) Wind	WSAvg	8.2	8.7	8.8	8.5	7.4	7.2	8.0	8.2	8.3	8.5	8.1	8.3	8.1	(14)
(15) Precipitation	PrecAvg	31.1	0.9	0.6	1.6	2.0	3.6	4.1	4.8	4.3	3.9	2.4	1.7	1.3	(15)
	PrecMax	39.2	4.0	1.9	4.1	6.3	6.4	12.3	7.6	6.5	7.1	4.6	5.0	3.1	(16)
	PrecMin	22.5	0.2	0.1	0.2	0.7	1.9	2.0	2.5	1.9	1.7	1.1	0.4	0.2	(17)
	PrecStd	4.5	0.9	0.5	1.0	1.3	1.1	1.9	1.3	1.1	1.4	0.9	1.1	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.5	94.1	93.7	85.1	75.4	66.7	63.8	67.5	72.6	81.5	90.3	95.8	(19)
		MCWB	65.7	66.0	64.0	61.1	56.9	55.5	54.7	55.9	57.7	60.2	61.5	65.2	(20)
	2%	DB	88.1	88.2	86.5	78.7	70.4	63.5	60.8	63.3	67.1	74.4	83.3	86.7	(21)
		MCWB	65.4	65.1	64.1	60.5	57.1	54.4	54.0	54.8	56.3	59.1	61.9	64.2	(22)
	5%	DB	83.2	83.4	80.8	74.1	66.8	61.2	58.7	60.6	63.7	69.3	77.4	81.0	(23)
		MCWB	64.4	64.0	62.8	59.9	56.8	53.9	53.0	53.8	55.2	57.8	61.0	63.0	(24)
	10%	DB	78.9	79.0	75.8	70.0	64.0	59.1	57.0	58.3	60.7	65.3	72.5	76.2	(25)
		MCWB	62.9	63.1	61.7	59.1	56.2	53.2	52.1	52.6	54.0	56.4	59.4	61.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	71.0	68.3	65.3	63.0	59.2	57.6	58.9	60.6	63.7	66.6	68.5	(27)
		MCDB	86.2	84.0	81.8	75.0	67.7	62.5	60.3	63.4	68.0	75.3	79.6	85.0	(28)
	2%	WB	67.8	67.5	66.5	63.3	60.8	57.4	55.5	56.5	57.8	61.1	64.1	65.7	(29)
		MCDB	82.2	79.4	77.4	71.6	64.7	60.9	58.5	61.2	64.4	70.9	76.9	80.9	(30)
	5%	WB	65.7	65.9	65.1	61.8	58.9	55.7	54.1	54.7	55.9	59.0	62.1	63.9	(31)
		MCDB	79.3	77.7	74.4	69.3	63.9	59.1	57.5	58.8	62.2	67.0	73.8	77.8	(32)
	10%	WB	63.9	64.4	63.6	60.3	57.3	54.2	52.7	53.3	54.5	57.3	60.2	61.9	(33)
		MCDB	76.2	75.6	71.8	67.2	61.9	57.6	56.1	57.3	60.0	64.1	71.0	74.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.7	22.0	19.9	17.4	15.0	12.4	12.2	13.3	15.2	17.9	21.0	22.7	(35)
		MCDBR	31.2	30.1	28.4	23.8	19.3	15.1	14.2	16.6	19.8	25.2	30.3	32.3	(36)
	5% WB	MCWBR	11.0	9.7	9.0	8.7	9.4	9.0	8.8	9.7	10.6	11.9	11.7	11.8	(37)
		MCWBR	26.7	24.6	21.2	19.0	15.2	12.4	12.4	14.1	17.8	21.8	25.9	27.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.332	0.331	0.317	0.309	0.297	0.296	0.295	0.300	0.323	0.322	0.329	0.325	(40)
		taud	2.565	2.575	2.620	2.632	2.642	2.617	2.616	2.593	2.502	2.525	2.533	2.570	(41)
	Ebn at Noon		319	312	306	291	278	268	275	289	298	312	318	322	(42)
		Edh at Noon	34	32	29	25	22	21	22	26	32	34	35	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2357	2056	1635	1183	879	722	783	1026	1372	1752	2102	2350	(44)
	RadStd		164	117	111	75	60	46	35	49	56	110	138	141	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A	(47)

Nomenclature: See separate page