

NORSEMAN, Australia

WMO: 946390

Lat: 32.200S

Lon: 121.783E

Elev: 912

StdP: 14.22

Time Zone: 8.00 (E08)

Period: 90-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.9	37.4	31.5	26.7	48.6	33.3	28.8	49.2	27.5	58.1	23.9	61.6	0.1	0	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	100.1	70.6	96.3	69.5	92.8	68.6	75.7	90.2	72.9	89.7	70.8	87.5	8.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	120.1	83.7	67.9	106.2	79.5	65.8	98.3	77.0	39.8	89.2	37.2	90.0	35.2	86.9	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.2	19.0	17.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			29.9	82.2	1.5	4.0	28.8	85.1	27.9	87.5	27.1	89.7	26.0	92.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.7	75.9	74.1	70.4	65.7	58.8	53.4	51.9	53.1	58.0	62.8	68.2	72.2		
	DBStd	10.14	6.29	6.48	6.68	5.64	5.25	3.99	4.29	4.69	5.94	7.15	7.12	6.46		
	HDD50	65	0	0	0	0	1	13	28	18	5	0	0	0		
	HDD65	1822	2	4	18	60	203	348	406	371	221	130	46	13		
	CDD50	5051	804	675	633	471	275	115	87	113	247	398	545	688		
	CDD65	1333	340	258	187	81	12	0	0	2	13	63	141	236		
	CDH74	15715	4211	2997	2035	702	97	0	0	30	213	857	1720	2853		
	CDH80	7397	2256	1517	914	213	14	0	0	3	52	326	731	1371		
(14) Wind	WSAvg	6.1	6.9	6.7	6.7	5.2	4.7	5.1	5.5	5.5	6.3	6.4	7.1	7.1		
(15) Precipitation	PrecAvg	12.0	0.9	1.1	1.1	1.0	1.3	1.3	1.2	0.9	0.9	0.7	0.9	0.9		
	PrecMax	24.0	4.6	6.3	7.4	3.6	4.4	4.1	3.1	2.6	2.6	2.8	3.4	5.9		
	PrecMin	7.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.2	0.0	0.0	0.0	0.0		
	PrecStd	3.4	1.1	1.4	1.6	0.8	1.1	0.8	0.7	0.6	0.7	0.6	0.7	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.9	105.7	100.7	90.5	82.7	70.9	71.2	77.6	86.3	93.8	97.2	100.0		
		MCWB	71.2	73.8	71.0	65.0	62.8	57.3	56.8	57.7	61.9	65.1	67.6	68.9		
	2%	DB	100.0	99.9	94.8	86.7	76.9	67.7	67.2	71.4	80.0	88.3	92.6	95.3		
		MCWB	70.8	71.6	69.3	64.7	60.7	56.7	55.0	55.8	59.6	63.8	67.1	68.2		
	5%	DB	95.8	94.8	89.0	82.0	73.1	65.2	64.0	67.4	75.4	83.5	88.1	91.5		
		MCWB	69.5	70.3	67.9	64.0	60.1	55.7	53.7	54.8	58.1	62.4	65.6	67.5		
	10%	DB	91.6	90.0	84.2	77.8	69.7	62.9	61.5	63.7	71.6	78.5	83.9	88.0		
		MCWB	68.5	69.5	65.8	63.0	58.9	54.5	52.7	53.4	56.9	60.6	63.9	66.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.1	80.1	75.4	69.6	66.9	61.1	59.8	60.8	64.0	68.3	73.4	76.7		
		MCDB	91.1	93.2	88.5	81.3	75.9	65.7	66.1	70.6	80.0	87.1	89.7	91.6		
	2%	WB	74.5	76.5	71.6	67.8	63.7	59.3	56.7	57.9	61.2	65.6	69.9	71.1		
		MCDB	91.4	88.8	87.6	78.4	71.8	64.0	63.1	66.7	75.7	83.4	87.2	88.3		
	5%	WB	72.0	73.5	69.5	66.1	61.9	57.5	55.0	56.0	59.2	63.2	67.3	69.0		
		MCDB	90.1	89.8	85.3	76.8	69.7	62.7	61.7	64.8	71.9	80.1	83.1	87.5		
	10%	WB	69.9	71.1	67.6	64.4	60.3	55.6	53.7	54.3	57.8	61.3	65.0	67.2		
		MCDB	88.5	86.0	80.9	74.6	67.2	61.3	60.0	62.4	69.4	77.0	80.3	85.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.8	25.3	23.3	21.8	19.3	19.8	19.1	21.3	23.3	25.5	25.3	26.5		
		MCDBR	33.2	34.0	30.9	28.1	24.2	23.5	22.9	29.0	30.1	31.3	30.9	32.1		
		MCWBR	11.1	12.1	11.5	12.3	12.4	13.8	13.1	15.6	13.6	12.6	12.7	11.2		
	5% WB	MCDBR	29.9	29.4	26.8	23.1	19.6	18.9	19.3	24.3	27.0	28.5	28.4	29.1		
		MCWBR	13.0	13.7	11.9	11.8	11.7	12.3	12.5	14.4	13.0	12.8	13.1	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.337	0.338	0.319	0.308	0.292	0.281	0.279	0.288	0.307	0.319	0.325	0.325		
	taud		2.593	2.604	2.639	2.654	2.669	2.680	2.684	2.641	2.566	2.556	2.566	2.597		
	Ebn at Noon		318	312	307	294	284	280	286	297	306	314	319	323		
	Edh at Noon		33	32	29	25	22	21	22	25	30	33	34	33		
(44) All-Sky Solar Radiation	RadAvg		2419	2127	1779	1359	1027	875	944	1243	1663	2032	2306	2519		
	RadStd		147	173	119	78	62	43	52	63	66	127	145	155		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-112	+157	+72

Nomenclature: See separate page