

KATANNING, Australia

WMO: 946410

Lat: 33.6856S

Lon: 117.6064E

Elev: 1053

StdP: 14.15

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.0	38.8	27.9	22.7	74.1	31.0	26.3	66.1	27.0	55.9	24.1	55.0	3.6	270	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	96.7	64.4	92.7	63.8	88.8	62.9	68.5	85.0	66.8	83.8	65.2	81.8	8.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	92.7	72.2	61.7	85.5	70.4	60.1	80.6	68.8	33.4	85.7	31.9	83.6	30.7	81.9	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.2	21.0	18.7	DB	33.2	104.5	2.0	2.5	31.8	106.3	30.7	107.7	29.6	109.1	28.1	111.0
			WB	32.1	74.5	1.8	5.3	30.8	78.3	29.8	81.5	28.8	84.4	27.5	88.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	70.8	70.7	67.4	62.5	56.5	52.3	50.3	51.1	52.7	57.6	64.0	67.4	(6)
(7)		DBStd	9.07	5.84	5.73	6.03	5.57	4.48	3.60	3.38	3.79	4.59	5.61	6.20	6.18	(7)
(8)		HDD50	116	0	0	0	0	3	17	39	31	22	4	0	0	(8)
(9)		HDD65	2462	13	12	42	113	266	382	456	432	370	241	92	43	(9)
(10)		CDD50	3841	644	579	540	375	205	85	47	65	103	238	420	540	(10)
(11)		CDD65	712	192	171	118	38	3	0	0	0	0	11	62	117	(11)
(12)		CDH74	8724	2341	1915	1243	342	30	0	0	1	17	228	966	1641	(12)
(13)		CDH80	3878	1162	887	513	85	3	0	0	0	1	65	396	766	(13)
(14)	Wind	WSAvg	8.3	9.9	9.7	8.8	7.1	6.8	7.5	7.6	7.4	8.2	8.4	9.2	9.2	(14)
(15)	Precipitation	PrecAvg	18.9	0.6	0.7	0.8	1.3	2.4	3.0	2.9	2.6	1.9	1.3	1.0	0.6	(15)
(16)		PrecMax	26.6	3.4	2.9	5.3	4.2	6.5	6.1	5.1	5.1	4.1	3.7	3.9	2.4	(16)
(17)		PrecMin	13.0	0.0	0.0	0.0	0.0	0.3	0.9	1.1	0.7	0.6	0.2	0.2	0.0	(17)
(18)		PrecStd	3.5	0.8	0.8	1.1	1.0	1.3	1.4	1.0	0.9	0.9	0.7	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.7	99.5	96.7	87.7	77.7	68.1	64.6	69.1	76.1	86.9	94.9	100.6	(19)
(20)		MCWB	67.1	66.5	63.8	62.4	57.8	53.8	53.3	55.9	57.5	60.9	62.8	63.4	(20)	
(21)		2%	DB	96.3	95.0	91.0	81.9	72.5	64.6	61.5	64.0	69.9	80.4	89.4	94.0	(21)
(22)		MCWB	64.5	66.0	63.8	61.7	56.6	53.6	52.9	54.5	56.2	59.1	60.9	63.3	(22)	
(23)		5%	DB	91.3	90.2	86.0	77.6	68.8	61.9	59.3	61.3	65.8	75.0	84.3	88.6	(23)
(24)		MCWB	64.0	64.2	63.0	60.1	56.0	53.1	52.5	53.6	55.3	57.3	59.9	62.0	(24)	
(25)		10%	DB	86.5	85.7	80.8	73.7	65.6	59.5	57.3	58.9	62.5	70.2	79.1	83.3	(25)
(26)		MCWB	62.9	63.3	61.7	58.9	55.4	52.6	51.6	52.4	53.8	56.1	58.7	60.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.0	72.7	68.2	65.7	63.1	58.7	56.8	58.4	60.6	64.4	65.9	68.5	(27)
(28)		MADB	86.2	88.5	82.8	77.6	70.4	62.9	60.3	65.0	70.4	79.1	84.0	85.9	(28)	
(29)		2%	WB	68.3	68.7	66.5	63.9	60.8	56.5	54.9	56.2	57.7	60.8	63.3	65.6	(29)
(30)		MADB	85.5	84.8	81.1	74.7	66.2	61.3	59.0	61.6	66.9	74.8	81.4	84.7	(30)	
(31)		5%	WB	66.2	66.7	65.0	62.4	58.9	54.9	53.5	54.6	55.9	58.9	61.5	63.7	(31)
(32)		MADB	85.3	84.0	79.2	72.9	64.5	59.4	57.8	59.6	63.8	71.2	78.6	83.3	(32)	
(33)		10%	WB	64.3	64.9	63.5	60.7	57.1	53.5	52.2	53.1	54.4	57.3	59.9	61.8	(33)
(34)		MADB	82.4	81.1	76.6	69.7	63.2	58.0	56.4	57.8	61.4	68.4	75.8	80.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	27.5	26.2	23.5	20.2	17.6	14.8	14.2	15.6	18.7	23.0	26.1	27.2	(35)	
(36)		5% DB	MADB	36.7	34.3	31.9	26.5	23.2	18.2	16.8	19.4	24.7	31.2	35.6	37.3	(36)
(37)		MCWBR	10.6	9.9	10.2	10.4	11.0	10.2	10.6	11.8	13.3	12.9	11.8	11.2	(37)	
(38)		5% WB	MADB	30.2	28.8	25.3	21.3	16.7	14.5	14.3	16.1	21.4	25.8	29.8	31.9	(38)
(39)		MCWBR	10.9	10.4	9.7	10.2	10.0	9.8	10.4	10.9	12.5	12.6	11.6	11.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.326	0.313	0.304	0.290	0.288	0.286	0.293	0.315	0.316	0.322	0.319	(40)	
(41)		taud	2.527	2.544	2.578	2.597	2.613	2.596	2.600	2.563	2.471	2.500	2.507	2.536	(41)	
(42)		Ebn at Noon	320	314	307	293	281	273	280	292	302	314	320	324	(42)	
(43)		Edh at Noon	35	33	30	26	23	22	23	27	33	35	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2501	2218	1782	1293	961	796	850	1097	1479	1896	2280	2542	(44)	
(45)		RadStd	155	116	103	85	62	40	43	45	56	111	141	143	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	+0.79	-2.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+189	N/A

Nomenclature: See separate page