

EUCLA, Australia

WMO: 946470

Lat: 31.680S Lon: 128.879E Elev: 94 StdP: 100.21 Time Zone: 8.75 (AUE) Period: 95-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 4.4	(c) 5.6	(d) -9.9	(e) 1.6	(f) 24.2	(g) -6.8	(h) 2.1	(i) 22.1	(j) 10.2	(k) 14.9	(l) 9.4	(m) 15.6	(n) 3.5	(o) 0	(p) 0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 7.2	(c) 36.8	(d) 17.3	(e) 33.2	(f) 16.8	(g) 29.9	(h) 16.5	(i) 21.5	(j) 27.3	(k) 20.6	(l) 25.5	(m) 19.9	(n) 24.1	(o) 6.8	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	14.9	22.8	19.2	14.1	22.0	18.5	13.5	21.5	63.2	27.3	59.8	25.8	57.3	24.2	34.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.4	7.8	DB	2.3	43.3	0.8	2.1	1.7	44.9	1.3	46.1	0.8	47.3	0.3	48.9	
			WB	1.1	24.7	1.1	3.0	0.3	26.9	-0.3	28.6	-0.9	30.3	-1.7	32.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	21.1	21.2	20.1	18.4	15.7	13.3	12.6	13.6	15.3	17.0	18.5	19.8
	DBStd	4.25	3.22	2.98	3.07	2.87	2.69	2.08	2.13	2.90	3.54	3.78	3.57	3.34
	HDD10.0	3	0	0	0	0	0	1	1	1	0	0	0	0
	HDD18.3	849	2	1	10	32	91	151	178	151	108	74	37	13
	CDD10.0	2633	346	314	312	253	178	101	82	113	158	216	256	305
	CDD18.3	438	89	83	64	34	11	1	1	4	16	32	42	59
	CDH23.3	3313	557	441	390	240	96	10	12	79	221	369	417	481
CDH26.7	1552	273	203	194	91	27	1	1	21	90	192	215	244	
Wind	WSAvg	4.6	5.2	5.0	4.6	4.1	3.9	4.1	4.2	4.4	4.7	5.0	5.1	5.1
Precipitation	PrecAvg	301	13	21	25	27	33	32	28	31	27	16	22	22
	PrecMax	424	84	182	97	85	104	103	83	111	72	56	68	149
	PrecMin	144	0	0	0	2	1	2	7	3	0	0	1	1
	PrecStd	76	20	32	27	20	21	23	17	22	20	14	18	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	39.3	38.3	33.7	29.9	24.8	24.9	29.3	33.8	37.0	38.8	40.8
		MCWB	18.8	19.4	18.1	16.1	15.3	13.2	11.7	12.6	14.2	15.6	17.5	18.2
	2%	DB	33.1	32.6	32.4	29.1	25.9	21.7	21.9	25.5	29.2	32.3	32.8	33.0
		MCWB	18.7	18.6	17.3	15.6	14.3	12.5	11.7	11.8	13.8	14.6	16.5	17.6
	5%	DB	28.8	27.9	27.4	25.8	22.9	19.7	19.6	22.2	25.4	27.4	27.9	27.8
		MCWB	18.7	18.5	17.5	15.4	14.2	12.0	11.2	11.5	13.0	14.1	16.1	17.5
	10%	DB	25.3	25.0	24.0	23.0	20.6	18.0	17.6	19.4	21.8	22.9	24.0	24.7
		MCWB	19.1	19.2	17.8	16.0	14.0	12.0	10.9	11.1	12.5	13.6	16.0	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.1	23.0	21.6	19.8	18.3	16.4	15.2	15.2	17.2	18.2	20.4	22.2
		MCDB	30.2	30.4	27.4	24.3	21.2	20.0	19.0	19.8	23.5	27.0	28.4	28.4
	2%	WB	21.3	21.4	20.3	18.8	17.1	14.9	13.8	14.2	15.5	16.8	18.7	20.2
		MCDB	27.6	26.0	24.6	22.1	20.7	18.2	17.2	19.0	22.0	23.5	25.9	26.2
	5%	WB	20.4	20.5	19.6	18.2	16.2	13.9	12.9	13.3	14.6	16.0	17.7	19.2
		MCDB	25.6	24.2	23.0	21.3	20.1	17.1	16.6	18.1	20.3	21.9	23.3	24.3
	10%	WB	19.6	19.8	18.8	17.5	15.2	13.1	12.1	12.5	13.9	15.2	16.9	18.4
		MCDB	23.9	23.1	22.1	20.7	18.9	16.3	15.9	17.1	19.3	20.7	21.8	22.6
Mean Daily Temperature Range	5% DB	MDBR	7.7	7.2	7.9	9.3	9.8	9.8	10.4	11.3	11.6	10.3	9.0	8.4
		MCDBR	15.5	14.3	15.3	14.8	13.9	12.9	14.1	16.3	18.3	19.1	18.0	16.2
		MCWBR	5.8	5.6	5.9	6.2	6.5	6.5	7.0	6.9	6.5	6.7	6.3	5.9
	5% WB	MCDBR	10.9	8.9	9.0	9.6	9.7	9.7	10.3	11.7	12.6	13.1	12.0	11.2
		MCWBR	4.9	4.4	4.9	5.2	5.8	6.2	6.3	6.5	5.9	5.7	5.3	5.3
Clear-Sky Solar Irradiance	taub	0.364	0.362	0.341	0.328	0.307	0.297	0.297	0.306	0.345	0.342	0.353	0.352	
	taud	2.507	2.533	2.574	2.604	2.632	2.630	2.619	2.581	2.457	2.483	2.489	2.517	
	Ebn at Noon	976	957	945	907	879	864	881	917	924	966	979	990	
	Edh at Noon	114	107	97	84	73	69	73	84	107	111	115	113	
All-Sky Solar Radiation	RadAvg	7.44	6.64	5.56	4.32	3.30	2.84	3.14	4.11	5.38	6.58	7.26	7.73	
	RadStd	0.59	0.62	0.36	0.25	0.20	0.12	0.18	0.20	0.34	0.27	0.46	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A