

NULLARBOR, Australia

WMO: 946510

Lat: 31.449S

Lon: 130.898E

Elev: 213

StdP: 14.58

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.9	38.9	19.4	14.7	75.9	23.6	18.0	71.3	29.1	59.6	26.4	59.2	9.3	40	0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	102.3	66.1	96.8	64.5	91.3	63.6	71.5	85.4	69.6	82.3	68.1	78.9	17.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.5	105.4	72.9	66.6	98.5	71.5	65.1	93.4	70.6	35.4	85.0	33.8	82.1	32.5	78.9	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.5	25.1	22.9	DB	32.6	111.4	2.4	3.8	30.9	114.2	29.5	116.4	28.1	118.6	26.4	121.3	(4)
(5)			WB	31.2	75.1	2.8	2.5	29.1	77.0	27.5	78.4	25.9	79.8	23.8	81.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	71.2	70.9	68.3	64.9	59.0	54.4	53.6	55.2	59.0	63.0	66.4	69.2
	DBStd	8.62	6.84	6.38	6.27	5.46	4.83	3.76	3.70	5.00	6.36	7.15	7.37	7.00
	HDD50	15	0	0	0	0	0	4	6	4	1	0	0	0
	HDD65	1707	6	5	26	67	199	318	353	309	205	129	66	24
	CDD50	4718	656	586	566	446	280	137	118	165	272	404	492	596
	CDD65	936	197	172	127	63	14	1	0	5	27	67	107	156
	CDH74	9778	1757	1439	1166	674	167	13	18	129	490	996	1311	1618
	CDH80	5042	986	775	615	274	44	1	2	24	204	516	718	883
(14) Wind	WSAvg	12.8	15.2	14.8	13.2	11.5	10.5	10.5	11.0	11.8	12.8	13.9	14.4	14.5
(15) Precipitation	PrecAvg	10.4	0.4	0.6	1.1	0.9	1.1	1.0	1.1	0.9	1.0	0.9	0.7	0.8
	PrecMax	19.7	1.9	2.4	8.7	3.8	3.1	3.3	3.9	2.8	3.5	4.6	2.5	4.3
	PrecMin	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.1	0.5	0.7	2.0	1.0	0.7	0.8	0.9	0.6	0.9	1.1	0.6	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.1	105.9	103.4	94.6	85.7	75.7	76.4	83.5	92.7	99.9	103.8	106.1
		MCWB	67.3	68.5	65.9	62.4	59.6	56.7	55.3	56.5	59.9	62.9	64.9	66.0
	2%	DB	99.9	98.5	94.7	87.4	78.5	70.5	70.9	77.7	86.5	92.7	96.0	97.9
		MCWB	67.6	67.2	64.7	61.4	58.5	54.7	53.6	54.9	58.8	60.4	63.3	64.2
	5%	DB	90.7	89.5	86.6	81.8	73.4	66.9	67.2	72.0	79.2	85.3	88.1	89.8
		MCWB	66.6	66.8	64.5	60.3	57.2	54.0	53.2	54.3	56.9	58.4	62.2	64.4
	10%	DB	82.9	81.8	78.9	76.1	68.9	63.9	63.6	67.1	73.0	77.7	80.7	82.4
		MCWB	65.7	66.0	63.1	60.4	57.4	53.6	52.8	53.0	55.5	58.1	61.4	64.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	74.5	71.4	67.6	64.4	60.9	59.8	60.0	63.2	66.7	69.1	73.3
		MCDB	87.4	89.1	83.0	75.4	70.0	66.8	66.2	69.3	80.4	81.3	86.1	84.4
	2%	WB	70.9	71.3	69.0	65.8	62.5	58.4	57.4	58.1	60.8	63.4	66.5	69.6
		MCDB	86.5	84.6	78.4	73.3	69.6	64.1	64.2	68.0	76.3	79.7	84.5	84.9
	5%	WB	69.0	69.3	67.4	64.4	60.8	56.6	55.6	56.3	59.0	61.4	64.6	67.3
		MCDB	82.4	79.9	75.6	72.2	68.5	62.5	62.9	66.1	72.0	76.0	80.5	80.7
	10%	WB	67.4	67.8	65.9	63.0	59.2	55.2	54.1	54.8	57.5	59.9	63.0	65.5
		MCDB	78.2	77.2	74.4	70.9	66.4	61.2	61.4	64.4	68.8	72.2	75.3	77.3
(35) Mean Daily Temperature Range	5% DB	MDBR	18.9	18.7	19.8	21.7	20.7	20.8	21.6	23.4	24.7	24.0	22.0	21.5
		MCDBR	36.8	35.7	34.8	32.6	28.8	26.9	28.1	32.2	36.8	39.2	38.7	37.1
		MCWBR	11.1	11.2	12.1	13.0	13.2	14.6	14.6	14.5	13.9	12.7	11.9	
	5% WB	MCDBR	25.3	23.4	21.7	21.5	21.0	19.9	21.6	24.9	28.3	29.1	28.7	27.4
		MCWBR	9.2	9.2	9.7	11.0	12.1	13.0	13.7	13.6	13.1	12.0	10.9	10.9
(40) Clear-Sky Solar Irradiance	taub		0.360	0.362	0.339	0.329	0.311	0.299	0.298	0.307	0.338	0.347	0.353	0.351
	taud		2.510	2.522	2.570	2.589	2.606	2.620	2.616	2.571	2.480	2.458	2.479	2.511
	Ebn at Noon		311	304	301	287	278	274	280	291	296	305	311	314
	Edh at Noon		36	35	31	27	24	22	23	27	33	36	37	36
(44) All-Sky Solar Radiation	RadAvg		2449	2227	1865	1407	1075	919	1005	1320	1749	2122	2371	2515
	RadStd		171	153	101	87	56	39	52	62	98	90	123	103

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	+0.56	N/A	-4.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page