

CEDUNA, Australia

WMO: 946530

Lat: 32.1297S

Lon: 133.6975E

Elev: 52

StdP: 14.67

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.3	37.9	10.6	9.5	81.5	17.7	13.5	78.9	27.7	58.9	25.3	58.9	6.0	70	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	103.2	65.1	98.2	63.8	93.0	63.1	71.7	85.9	69.5	83.5	67.9	80.5	16.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	104.2	74.7	65.9	95.6	73.1	64.1	89.6	71.9	35.5	85.3	33.6	83.8	32.3	80.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.9	24.5	22.4	DB	31.0	111.7	2.0	2.8	29.6	113.7	28.5	115.3	27.4	116.9	25.9	118.9	(4)
(5)			WB	30.4	77.3	1.8	4.8	29.1	80.8	28.1	83.6	27.1	86.3	25.8	89.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	71.8	71.4	67.9	63.6	58.6	54.2	53.3	54.6	58.6	62.8	66.4	69.6	(6)	
	DBStd	9.24	7.90	7.56	7.11	6.23	5.33	4.34	4.19	5.13	6.30	7.61	7.76	7.84	(7)	
	HDD50	36	0	0	0	0	1	10	14	10	1	0	0	0	(8)	
	HDD65	1828	8	9	39	97	212	325	362	327	214	138	70	27	(9)	
	CDD50	4669	675	599	556	409	269	136	117	151	260	398	491	608	(10)	
	CDD65	988	218	189	131	56	15	1	1	4	23	70	110	170	(11)	
	CDH74	11727	2378	2001	1431	647	150	10	10	77	399	1070	1502	2052	(12)	
	CDH80	6128	1361	1104	750	250	34	0	1	11	142	526	814	1135	(13)	
(14) Wind	WSAvg	12.0	14.1	13.5	12.3	10.7	9.8	9.7	10.4	11.0	12.3	13.2	13.5	13.8	(14)	
(15) Precipitation	PrecAvg	11.3	0.5	0.5	0.7	0.7	1.2	1.3	1.5	1.3	1.1	0.9	0.7	0.8	(15)	
	PrecMax	21.0	3.4	2.4	3.8	3.9	3.1	3.5	4.3	3.4	3.4	4.2	2.2	4.9	(16)	
	PrecMin	6.6	0.0	0.0	0.0	0.0	0.2	0.1	0.3	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.4	0.6	0.6	0.9	0.8	0.8	0.7	0.8	0.9	0.8	0.9	0.6	1.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.2	106.9	102.4	93.8	84.6	74.6	74.7	81.0	90.4	98.6	103.8	106.1	(19)	
		MCWB	66.9	67.4	64.0	61.5	58.5	55.9	54.1	55.2	58.4	61.1	63.0	64.2	(20)	
	2%	DB	102.4	100.7	95.3	87.1	78.1	69.3	69.3	75.4	84.1	91.9	96.3	99.7	(21)	
		MCWB	66.1	65.6	64.3	59.8	56.6	54.0	52.6	53.5	56.4	58.7	61.6	63.4	(22)	
	5%	DB	94.7	93.0	88.9	81.2	73.3	65.9	65.5	70.6	78.2	86.0	90.1	92.4	(23)	
		MCWB	65.4	66.0	63.0	58.8	55.7	53.6	52.4	52.8	55.2	57.1	61.2	62.8	(24)	
	10%	DB	86.7	85.8	81.6	76.2	69.0	63.2	62.5	65.6	72.4	79.3	82.8	85.6	(25)	
		MCWB	65.6	65.5	62.5	58.8	56.0	53.5	52.2	52.0	54.3	56.4	60.3	62.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.2	74.9	72.0	67.0	63.5	61.1	59.1	59.3	62.3	65.6	68.6	73.2	(27)	
		MCDB	86.8	86.1	82.9	75.0	69.5	68.9	65.0	68.0	75.2	82.5	82.5	82.9	(28)	
	2%	WB	71.4	71.4	68.9	64.8	61.6	58.3	56.6	57.3	60.1	63.0	65.8	69.1	(29)	
		MCDB	88.4	84.0	80.2	73.0	68.1	63.6	62.4	65.1	72.4	77.2	80.0	83.1	(30)	
	5%	WB	69.2	69.2	67.1	63.5	60.0	56.5	55.2	55.7	58.5	61.1	64.3	67.0	(31)	
		MCDB	84.4	82.3	76.9	71.5	67.1	61.9	61.5	63.7	69.4	74.6	79.4	80.8	(32)	
	10%	WB	67.4	67.5	65.4	61.9	58.5	55.0	53.8	54.4	57.0	59.4	62.7	65.2	(33)	
		MCDB	81.0	79.7	74.9	70.4	65.9	60.5	59.9	62.5	67.5	71.5	75.8	78.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	20.7	21.1	21.7	22.8	20.6	19.4	19.6	22.1	23.7	23.8	22.4	22.1	(35)	
		MCDBR	37.1	36.1	34.4	31.8	27.2	23.4	25.1	30.5	35.5	37.6	38.1	36.7	(36)	
		MCWBR	12.4	12.3	12.8	13.2	12.1	12.4	12.9	13.9	14.2	13.9	13.2	13.5	(37)	
	5% WB	MCDBR	25.3	24.7	22.3	21.3	19.3	17.7	19.0	22.4	27.0	27.6	26.5	26.6	(38)	
		MCWBR	10.6	10.5	10.9	11.7	11.6	11.6	12.3	13.3	13.3	12.8	12.0	12.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.352	0.351	0.332	0.324	0.311	0.296	0.298	0.308	0.334	0.348	0.352	0.343	(40)	
	taud		2.518	2.540	2.574	2.585	2.590	2.618	2.604	2.559	2.486	2.446	2.472	2.522	(41)	
	Ebn at Noon		313	307	302	288	276	273	278	289	297	304	311	317	(42)	
	Edh at Noon		36	34	30	27	24	22	23	27	33	36	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2501	2271	1884	1406	1041	887	961	1267	1699	2067	2353	2513	(44)	
	RadStd		142	117	118	84	55	40	43	62	96	119	111	113	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+169	+108	(46)
(47)	Regional (3 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+169	+108	(47)

Nomenclature: See separate page