

ELLISTON, Australia

WMO: 946560

Lat: 33.650S

Lon: 134.888E

Elev: 30

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.6	42.7	32.6	27.1	61.1	35.4	30.4	56.2	29.2	55.4	25.2	56.5	1.3	90	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	93.2	68.3	88.4	66.9	84.3	65.1	71.9	85.3	69.6	80.7	67.9	78.2	10.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	103.7	75.6	65.9	95.5	73.4	64.5	90.9	72.0	35.7	85.9	33.7	80.9	32.3	78.2	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.9	19.0	35.4	102.2	3.0	3.6	33.3	104.8	31.6	106.8	29.9	108.9	27.8	111.5		
(5)			34.8	76.6	2.8	5.6	32.7	80.6	31.1	83.8	29.5	86.9	27.5	91.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	69.6	69.0	66.1	62.7	58.7	55.4	54.2	55.4	58.2	61.0	64.5	66.8	(6)
(7)		DBStd	7.43	6.67	6.02	5.81	5.23	4.09	3.67	3.33	3.66	4.82	5.87	6.41	6.34	(7)
(8)		HDD50	10	0	0	0	0	0	3	5	2	0	0	0	0	(8)
(9)		HDD65	1798	10	10	46	105	204	289	336	299	214	160	82	43	(9)
(10)		CDD50	4300	607	531	500	381	269	165	134	169	247	340	435	522	(10)
(11)		CDD65	610	151	121	81	36	8	0	0	1	10	35	67	100	(11)
(12)		CDH74	4795	1257	832	591	199	34	2	0	6	102	337	594	841	(12)
(13)		CDH80	1909	591	347	208	52	7	0	0	0	20	97	233	354	(13)
(14)	Wind	WSAvg	8.9	11.0	10.4	8.7	7.0	6.5	7.3	7.6	8.2	9.1	9.9	10.5	10.8	(14)
(15)	Precipitation	PrecAvg	16.9	0.4	0.6	0.6	1.1	2.1	2.6	2.8	2.4	1.7	1.2	0.7	0.7	(15)
(16)		PrecMax	25.4	1.8	3.9	2.4	5.2	5.7	5.9	5.3	4.6	5.0	3.8	2.4	2.6	(16)
(17)		PrecMin	9.0	0.0	0.0	0.0	0.0	0.5	1.1	0.8	0.5	0.2	0.1	0.0	0.0	(17)
(18)		PrecStd	3.7	0.4	0.7	0.7	1.0	1.2	1.1	1.2	1.1	1.1	0.9	0.5	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.4	96.3	93.6	85.6	77.9	69.9	68.6	73.5	82.7	88.7	94.3	95.8	(19)
(20)			MCWB	70.8	71.7	67.5	63.0	59.2	57.1	55.6	57.6	61.7	62.4	66.3	68.8	(20)
(21)		2%	DB	92.8	89.9	85.7	79.3	71.7	65.3	64.5	68.5	76.5	81.9	86.7	88.7	(21)
(22)			MCWB	68.3	69.7	65.7	62.6	58.5	56.7	55.0	56.1	60.5	60.2	64.9	66.4	(22)
(23)		5%	DB	86.0	84.8	81.2	74.8	68.0	63.0	61.9	64.5	71.7	76.8	81.0	83.8	(23)
(24)			MCWB	67.2	67.6	64.2	61.7	59.9	56.1	54.9	55.0	58.9	59.3	63.0	64.6	(24)
(25)		10%	DB	80.0	79.0	76.3	70.8	65.5	61.4	60.2	61.8	67.0	71.5	75.5	78.1	(25)
(26)			MCWB	66.3	66.2	63.8	61.1	58.6	55.5	54.2	54.4	57.3	58.2	62.2	63.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.1	76.5	71.9	68.9	64.8	61.1	58.9	60.4	66.4	65.4	69.9	71.9	(27)
(28)			MCD B	87.7	88.0	83.9	76.8	69.0	66.2	62.9	68.5	76.9	79.8	84.1	85.5	(28)
(29)		2%	WB	71.6	71.9	67.9	65.5	62.7	59.0	57.4	58.2	62.6	63.0	67.0	69.1	(29)
(30)			MCD B	85.9	85.5	79.4	73.4	67.0	62.6	61.3	63.8	71.3	74.5	80.2	80.3	(30)
(31)		5%	WB	69.1	69.4	66.3	63.9	61.0	57.8	56.3	56.9	60.4	61.3	65.2	67.2	(31)
(32)			MCD B	80.0	79.7	75.2	70.4	65.8	61.3	60.3	62.2	67.8	71.0	76.3	78.3	(32)
(33)		10%	WB	67.3	67.5	65.0	62.7	59.5	56.7	55.2	55.7	58.8	59.9	63.6	65.5	(33)
(34)			MCD B	77.0	75.8	73.5	68.7	64.4	60.4	59.4	60.7	65.3	68.2	73.3	75.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.7	13.2	14.4	15.5	13.9	12.8	12.9	14.2	15.3	16.7	15.5	15.6	(35)
(36)			MCDBR	24.0	22.1	21.9	20.2	17.5	14.6	15.9	20.3	24.9	26.3	24.2	25.0	(36)
(37)			MCWBR	9.9	9.1	9.5	10.9	10.8	9.3	10.2	12.3	13.4	12.4	10.4	10.4	(37)
(38)		5% WB	MCDBR	18.6	16.5	17.3	17.1	14.6	12.2	13.0	16.3	20.1	21.2	19.3	18.4	(38)
(39)			MCWBR	10.0	8.4	9.1	11.4	10.9	9.0	10.0	11.6	13.0	12.0	10.6	10.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.347	0.329	0.321	0.310	0.303	0.301	0.308	0.335	0.343	0.345	0.338	(40)	
(41)		taud	2.556	2.565	2.601	2.614	2.624	2.622	2.627	2.592	2.505	2.484	2.510	2.558	(41)	
(42)		Ebn at Noon	315	308	302	288	274	268	275	288	295	305	313	318	(42)	
(43)		Edh at Noon	34	33	30	26	23	21	22	26	32	35	36	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2486	2211	1800	1322	943	794	859	1157	1569	1983	2283	2459	(44)	
(45)		RadStd	111	113	89	82	42	38	42	70	105	127	125	124	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page