

KYANCUTTA, Australia

WMO: 946570

Lat: 33.133S

Lon: 135.555E

Elev: 58

StdP: 100.63

Time Zone: 9.50 (AUA)

Period: 94-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 0.8	(c) 2.1	(d) -2.4	(e) 3.1	(f) 14.2	(g) -0.9	(h) 3.5	(i) 12.3	(j) 12.3	(k) 14.5	(l) 11.7	(m) 12.8	(n) 0.1	(o) 70	(p) 0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.2	40.2	20.8	37.7	20.1	35.4	19.4	23.1	33.4	21.8	32.5	20.8	31.9	3.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.3	26.5	18.8	13.7	24.5	17.4	12.5	23.5	68.6	33.1	63.9	31.7	60.1	32.1	33.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.4	8.9	7.3		-1.8	44.0	1.5	1.1	-2.9	44.8	-3.8	45.4	-4.7	46.0	-5.8	46.8	
			DB	-1.9	26.4	1.5	3.8	-3.0	29.1	-3.9	31.4	-4.8	33.5	-5.9	36.3	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	23.9	24.1	20.2	16.9	14.1	11.8	11.2	11.5	14.2	16.1	19.2	21.7
	DBStd	5.68	4.27	4.41	3.83	3.11	2.88	2.20	2.31	2.45	3.41	3.91	4.04	4.15
	HDD10.0	33	0	0	0	0	1	7	13	11	1	0	0	0
	HDD18.3	1134	3	3	19	64	137	196	222	212	134	96	35	12
	CDD10.0	2598	429	394	316	207	128	61	50	58	126	189	277	363
	CDD18.3	656	174	164	77	21	7	1	0	1	9	26	62	116
	CDH23.3	9201	2330	2178	1039	351	79	3	0	13	167	449	974	1617
CDH26.7	4829	1346	1265	504	116	17	0	0	1	52	196	479	855	
Wind	WSAvg	2.5	3.0	2.7	2.3	1.8	1.8	2.2	2.1	2.2	2.8	3.0	2.9	3.0
Precipitation	PrecAvg	300	15	14	11	19	32	37	39	39	34	24	19	17
	PrecMax	542	141	66	47	85	91	102	77	80	99	83	81	62
	PrecMin	155	0	0	0	0	4	6	8	6	3	1	0	0
	PrecStd	77	25	16	13	20	19	22	17	21	24	21	15	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	42.0	38.9	32.2	29.4	22.6	21.6	25.4	31.4	35.5	39.3	41.5
		MCWB	21.9	22.1	20.1	18.8	16.1	16.0	12.9	14.1	16.6	17.7	20.0	20.7
	2%	DB	40.0	40.0	35.2	29.5	25.6	19.7	19.5	22.0	27.6	32.0	35.3	38.0
		MCWB	20.5	21.7	18.7	16.9	15.0	13.1	12.2	13.0	15.9	16.4	19.2	19.7
	5%	DB	37.3	36.8	32.3	27.2	22.8	18.1	17.7	19.6	24.6	28.6	32.0	35.3
		MCWB	20.1	20.8	18.1	16.1	14.4	12.5	11.8	12.3	14.6	15.4	17.6	18.7
	10%	DB	34.2	34.2	29.2	24.8	20.3	16.6	16.1	17.4	21.8	25.4	29.3	31.7
		MCWB	19.6	19.9	17.4	15.3	13.7	12.1	11.4	11.5	13.7	14.7	16.5	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.3	25.5	21.7	20.4	18.0	16.3	14.7	15.5	18.3	18.8	21.2	22.8
		MCDB	33.5	33.9	34.6	26.0	22.7	20.4	18.7	22.5	27.4	29.4	34.7	35.3
	2%	WB	22.6	23.7	19.9	18.3	16.6	14.5	13.3	13.9	16.6	17.3	19.9	21.0
		MCDB	32.8	32.8	28.0	25.0	22.0	17.7	16.8	19.3	24.5	28.7	32.0	32.1
	5%	WB	21.4	22.4	19.1	17.1	15.4	13.5	12.6	13.1	15.4	16.3	18.6	19.9
		MCDB	33.1	32.5	28.1	24.3	20.4	16.4	16.1	17.6	22.5	26.5	28.8	30.7
	10%	WB	20.2	21.2	18.2	16.2	14.5	12.7	11.9	12.2	14.4	15.3	17.4	18.9
		MCDB	32.1	31.5	27.5	23.4	19.3	15.8	15.3	16.6	20.8	23.8	27.2	30.2
Mean Daily Temperature Range	5% DB	MDBR	16.7	16.2	15.6	15.5	12.7	10.3	11.1	12.5	14.1	14.9	15.7	16.2
		MCDBR	21.6	20.0	20.3	19.5	17.0	12.8	13.3	16.8	19.8	20.5	20.8	21.4
		MCWBR	6.9	6.6	6.9	8.8	8.5	7.1	7.5	8.8	8.8	8.2	7.3	7.1
	5% WB	MCDBR	17.6	15.8	16.3	15.9	12.8	9.8	11.0	13.5	16.3	17.9	17.8	17.4
		MCWBR	6.2	6.2	6.4	7.5	6.9	6.1	6.9	7.8	7.9	7.8	7.0	6.8
Clear-Sky Solar Irradiance	taub		0.343	0.342	0.325	0.316	0.310	0.296	0.295	0.303	0.332	0.343	0.345	0.335
	taud		2.505	2.527	2.558	2.567	2.557	2.585	2.581	2.544	2.455	2.427	2.456	2.513
	Ebn at Noon		994	975	958	913	864	854	873	913	934	963	986	1007
	Edh at Noon		114	107	97	86	77	70	74	86	106	117	118	114
All-Sky Solar Radiation	RadAvg		7.87	7.02	5.75	4.25	3.06	2.59	2.80	3.70	5.01	6.33	7.24	7.78
	RadStd		0.37	0.40	0.31	0.27	0.13	0.12	0.12	0.22	0.34	0.44	0.36	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page