

COLES POINT, Australia

WMO: 946580

Lat: 34.375S

Lon: 135.374E

Elev: 29

StdP: 100.98

Time Zone: 9.50 (AUA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	5.7	-1.0	3.5	23.1	1.1	4.1	18.5	14.1	12.3	13.2	12.7	4.2	40	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.1	34.5	18.6	32.2	18.0	30.0	17.5	20.9	28.0	19.9	27.1	19.0	26.0	5.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	22.2	17.7	12.7	21.6	16.7	12.0	20.7	60.5	28.0	57.0	27.1	54.1	26.0	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.5	9.5	DB	2.9	38.9	0.8	1.6	2.3	40.0	1.8	41.0	1.3	41.9	0.7	43.1	(4)
(5)			WB	2.4	22.5	0.9	1.3	1.7	23.4	1.2	24.2	0.7	24.9	0.1	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	20.7	20.9	19.1	16.8	14.3	12.3	11.4	11.9	13.4	15.2	17.7	19.4	(6)	
	DBStd	4.47	3.84	3.77	3.40	2.67	2.09	1.88	1.70	1.78	2.48	3.23	3.82	3.78	(7)	
	HDD10.0	13	0	0	0	0	0	3	6	3	1	0	0	0	(8)	
	HDD18.3	1183	12	9	28	62	129	182	214	201	149	111	58	29	(9)	
	CDD10.0	2228	333	307	283	204	132	72	49	61	103	161	232	291	(10)	
	CDD18.3	355	86	83	52	16	2	0	0	0	2	13	39	62	(11)	
	CDH23.3	3392	868	762	417	88	15	1	0	1	24	150	428	638	(12)	
(13)	CDH26.7	1396	407	327	153	20	2	0	0	0	4	42	167	273	(13)	
(14)	Wind	WSAvg	5.2	5.4	5.3	4.9	4.5	4.9	5.2	5.5	5.3	5.3	5.4	5.3	5.4	(14)
(15) Precipitation	PrecAvg	528	12	15	19	37	63	81	94	82	55	37	21	20	(15)	
	PrecMax	884	58	89	102	156	156	183	181	157	156	105	73	80	(16)	
	PrecMin	314	0	0	0	3	15	22	29	18	11	6	1	0	(17)	
	PrecStd	114	11	17	21	35	30	36	40	33	32	24	17	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.7	36.7	33.9	29.1	25.3	19.7	18.5	21.4	26.3	30.7	34.2	36.1	(19)	
		MCWB	19.2	19.3	17.7	16.0	14.2	14.1	12.8	13.8	14.9	15.8	17.6	17.8	(20)	
	2%	DB	34.1	33.9	30.7	25.7	21.3	17.5	16.5	18.7	22.8	27.4	30.9	32.7	(21)	
		MCWB	19.0	19.4	17.6	15.2	14.2	13.5	12.7	12.9	14.3	14.9	17.0	17.5	(22)	
	5%	DB	31.3	30.7	27.9	23.3	19.2	16.5	15.5	16.7	20.0	24.4	28.4	29.6	(23)	
		MCWB	18.2	18.7	17.1	15.2	14.0	13.3	12.5	12.5	13.7	14.5	16.4	16.8	(24)	
	10%	DB	28.2	27.9	25.2	21.4	17.9	15.6	14.7	15.4	18.0	21.5	25.3	26.8	(25)	
		MCWB	17.5	18.1	16.7	14.9	13.9	12.9	12.2	12.2	13.4	13.8	15.6	16.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	23.0	21.3	18.3	17.1	16.0	14.9	15.4	16.7	17.7	19.7	21.1	(27)	
		MCDB	29.9	30.6	27.1	22.2	19.3	17.7	16.0	18.5	21.6	24.6	29.2	25.4	(28)	
	2%	WB	20.7	20.9	19.7	17.5	16.2	14.7	14.0	14.1	15.5	16.4	18.3	19.4	(29)	
		MCDB	28.6	28.8	25.2	20.7	18.5	16.1	15.2	16.4	19.8	22.6	27.2	26.2	(30)	
	5%	WB	19.6	19.8	18.6	16.8	15.4	14.0	13.2	13.4	14.7	15.6	17.3	18.3	(31)	
		MCDB	27.3	27.2	24.0	20.2	17.7	15.6	14.8	15.7	18.2	20.9	24.7	25.8	(32)	
	10%	WB	18.5	18.9	17.7	16.1	14.7	13.3	12.6	12.7	13.9	14.7	16.4	17.4	(33)	
		MCDB	26.4	25.6	23.2	19.7	17.1	15.1	14.4	15.0	17.2	19.7	23.2	24.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	10.1	9.4	8.7	7.4	6.7	6.6	7.4	8.4	9.9	10.4	10.4	(35)	
		MCDBR	15.7	14.1	13.2	11.6	9.8	7.6	7.7	10.3	12.9	15.3	15.4	15.5	(36)	
		MCWBR	5.3	4.9	4.7	5.0	5.5	5.1	5.4	6.3	6.5	6.2	5.5	5.4	(37)	
	5% WB	MCDBR	12.4	11.4	10.2	8.6	7.3	6.1	6.3	8.2	10.0	11.8	12.7	12.2	(38)	
		MCWBR	5.4	4.8	4.9	5.3	5.2	4.9	5.3	5.9	6.0	6.1	5.6	5.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.342	0.327	0.320	0.311	0.305	0.299	0.308	0.336	0.340	0.344	0.335	(40)	
	taud		2.552	2.567	2.599	2.610	2.616	2.619	2.632	2.588	2.492	2.484	2.497	2.552	(41)	
	Ebn at Noon		994	973	953	905	859	838	865	904	927	964	986	1005	(42)	
	Edh at Noon		108	103	93	81	72	67	69	82	101	110	114	109	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.64	6.72	5.45	3.95	2.77	2.31	2.53	3.44	4.72	6.03	7.00	7.56	(44)	
	RadStd		0.33	0.33	0.24	0.24	0.13	0.11	0.12	0.21	0.32	0.40	0.40	0.33	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (10 neighbors)	+0.29	N/A	N/A	+0.92	N/A	N/A	N/A	-102	+121	N/A	(47)

Nomenclature: See separate page