

CLEVE, Australia

WMO: 946620

Lat: 33.7081S

Lon: 136.5025E

Elev: 577

StdP: 14.39

Time Zone: 9.50 (AUA)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.3	41.9	20.5	15.7	76.2	24.5	19.0	76.5	32.4	55.7	30.3	56.5	7.2	20	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	100.8	64.7	96.0	63.5	91.3	62.7	70.0	83.2	68.2	82.9	66.6	81.2	16.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	101.7	72.5	64.4	92.6	71.2	62.3	85.9	69.8	34.4	82.0	32.8	82.8	31.5	81.8	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.4	25.4	22.8	36.9	108.9	1.3	2.8	36.0	110.9	35.3	112.6	34.6	114.1	33.7	116.2		
			35.8	72.8	1.0	2.3	35.1	74.4	34.5	75.8	33.9	77.0	33.1	78.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.8	71.5	71.0	67.6	63.7	58.1	53.4	52.3	53.2	57.1	60.7	65.2	68.1	(6)
(7)		DBStd	9.35	7.89	7.35	7.14	6.36	5.32	3.91	3.99	4.90	6.31	7.55	7.98	7.73	(7)
(8)		HDD50	52	0	0	0	0	1	10	20	17	3	1	0	0	(8)
(9)		HDD65	2084	12	13	45	99	228	348	393	369	254	183	93	47	(9)
(10)		CDD50	4346	668	589	545	410	251	113	91	115	216	332	456	560	(10)
(11)		CDD65	905	215	181	125	60	14	1	0	2	17	49	99	142	(11)
(12)		CDH74	10448	2548	1882	1300	551	62	2	0	13	191	714	1337	1848	(12)
(13)		CDH80	5200	1437	988	617	187	7	0	0	1	45	284	657	977	(13)
(14)	Wind	WSAvg	12.1	13.0	12.5	11.7	11.0	11.1	11.5	12.6	12.1	12.5	12.3	12.2	12.7	(14)
(15)	Precipitation	PrecAvg	15.8	0.7	0.9	0.9	1.1	1.7	1.8	2.0	1.9	1.7	1.3	1.0	1.0	(15)
(16)		PrecMax	23.5	3.0	4.9	3.6	3.9	4.6	4.8	4.0	3.8	4.7	3.8	3.1	3.5	(16)
(17)		PrecMin	8.9	0.0	0.0	0.0	0.0	0.2	0.4	0.6	0.2	0.5	0.1	0.0	0.1	(17)
(18)		PrecStd	3.7	0.7	1.1	0.8	0.9	1.0	0.9	0.9	0.8	1.0	0.9	0.7	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	107.5	104.2	100.2	92.7	80.3	69.8	68.4	75.7	85.7	94.2	100.6	104.1	(19)	
(20)		MCWB	65.6	66.8	63.5	62.0	58.1	55.0	52.8	54.5	57.1	59.9	63.5	64.6	(20)	
(21)		DB	101.0	97.8	93.0	85.2	74.8	65.1	64.5	69.6	79.5	87.8	93.8	97.5	(21)	
(22)		MCWB	65.1	64.9	62.7	59.7	56.1	52.7	51.6	52.9	56.3	58.2	61.4	62.9	(22)	
(23)		DB	94.5	91.3	87.3	79.9	70.4	62.3	61.5	65.4	74.7	82.0	88.1	90.8	(23)	
(24)		MCWB	64.9	64.8	62.2	58.2	54.8	52.2	51.3	51.7	55.1	57.1	60.3	61.9	(24)	
(25)		DB	88.1	85.7	81.0	75.7	66.9	59.9	59.0	62.0	70.2	76.6	81.8	84.3	(25)	
(26)		MCWB	63.5	64.2	61.4	57.4	54.6	51.9	50.7	50.8	53.7	55.8	59.1	60.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	72.0	73.4	70.8	65.8	61.4	58.2	56.5	57.2	61.5	63.6	67.1	69.2	(27)	
(28)		MCDWB	86.7	83.4	80.7	74.6	69.8	63.5	61.2	67.2	74.3	79.7	83.6	83.8	(28)	
(29)		WB	69.4	70.6	67.9	63.5	59.2	55.8	54.5	55.3	58.7	60.9	64.5	66.9	(29)	
(30)		MCDWB	86.6	82.5	78.6	73.0	67.0	60.7	59.8	63.6	73.3	77.7	83.4	83.5	(30)	
(31)		WB	67.7	68.4	65.8	61.7	57.5	54.5	53.2	53.8	56.8	59.2	62.9	65.0	(31)	
(32)		MCDWB	85.8	81.1	77.2	72.0	65.3	59.2	58.4	61.8	69.5	74.9	80.7	81.4	(32)	
(33)		WB	65.8	66.7	63.8	60.2	56.3	53.2	52.0	52.4	55.2	57.5	61.0	63.1	(33)	
(34)		MCDWB	81.8	79.8	75.7	70.7	63.8	57.7	57.2	59.5	65.8	71.7	76.0	78.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	20.8	19.0	18.1	17.6	13.8	12.1	12.4	15.1	18.9	21.7	21.7	21.6	(35)	
(36)		5% DB	33.8	31.4	28.6	24.9	19.0	14.9	15.0	20.1	27.1	32.4	32.9	34.4	(36)	
(37)		MCWBR	9.2	8.6	8.6	8.5	7.7	7.8	7.9	9.2	10.2	10.9	9.7	9.9	(37)	
(38)		5% WB	26.9	22.6	21.2	19.6	14.7	12.0	12.7	16.4	22.9	26.5	27.1	25.9	(38)	
(39)		MCWBR	9.2	8.4	8.5	8.3	7.7	7.7	8.0	9.2	10.3	10.8	9.8	9.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.339	0.320	0.314	0.304	0.293	0.291	0.299	0.325	0.336	0.339	0.332	(40)	
(41)		taud	2.518	2.546	2.583	2.581	2.586	2.600	2.601	2.566	2.487	2.458	2.486	2.528	(41)	
(42)		Ebn at Noon	316	310	305	290	276	271	278	291	298	307	315	320	(42)	
(43)		Edh at Noon	36	33	30	27	23	22	23	27	32	36	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2470	2174	1779	1316	935	788	859	1148	1551	1965	2266	2418	(44)	
(45)		RadStd	127	130	90	79	38	42	34	70	109	134	118	119	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (18 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+187	N/A	(47)

Nomenclature: See separate page