

WHYALLA, Australia

WMO: 946640

Lat: 33.017S

Lon: 137.517E

Elev: 15

StdP: 101.14

Time Zone: 9.50 (AUA)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 4.2	(c) 5.3	(d) -4.0	(e) 2.7	(f) 21.7	(g) -1.9	(h) 3.2	(i) 21.5	(j) 10.3	(k) 16.7	(l) 9.5	(m) 16.0	(n) 1.5	(o) 320	(p) 0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.6	37.7	20.0	35.2	19.6	32.9	19.1	23.0	31.0	22.1	30.3	21.2	28.8	5.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	25.8	19.6	14.4	25.1	18.6	13.5	24.5	68.3	31.0	64.7	30.0	61.4	28.8	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 9.1	(c) 8.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 10.0	(b) 9.1	(c) 8.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	23.6	24.7	21.4	18.3	14.8	12.7	12.2	12.9	15.0	17.5	20.0	21.6
	DBStd	5.37	4.23	4.23	3.49	3.04	2.47	2.38	2.26	2.66	3.43	3.69	4.14	3.41
	HDD10.0	11	0	0	0	0	0	3	4	3	1	0	0	0
	HDD18.3	899	2	2	6	37	116	170	192	169	113	62	27	6
	CDD10.0	2878	422	412	354	249	148	84	72	93	152	234	300	358
	CDD18.3	724	166	180	102	36	5	1	1	2	14	37	76	106
	CDH23.3	6844	1626	1783	769	311	24	3	2	26	132	450	795	925
	CDH26.7	3153	850	882	318	100	2	0	0	3	34	185	368	411
Wind	WSAvg	4.1	4.9	4.3	4.1	3.7	3.3	3.3	3.7	3.6	3.9	4.4	4.6	4.9
Precipitation	PrecAvg	289	22	23	19	22	28	28	24	24	29	30	25	19
	PrecMax	536	115	143	112	104	94	92	56	57	108	104	87	91
	PrecMin	135	0	0	0	1	1	1	3	2	2	1	0	1
	PrecStd	97	26	32	23	21	18	24	14	15	22	26	20	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	40.7	36.4	33.0	26.6	23.3	22.2	26.3	30.2	34.9	38.0	36.9
		MCWB	22.0	21.1	20.5	18.2	15.2	14.1	12.9	14.7	16.2	17.0	18.2	17.2
	2%	DB	37.5	37.9	32.7	29.4	23.5	20.2	19.8	22.7	26.9	31.2	33.8	34.0
		MCWB	20.5	20.5	19.5	16.6	14.3	13.9	11.9	13.1	15.2	15.5	17.4	18.3
	5%	DB	34.4	34.7	29.9	26.7	21.4	18.6	18.1	20.2	24.2	28.3	30.6	31.2
		MCWB	20.3	20.2	18.8	15.8	14.0	12.7	11.7	12.1	14.2	14.9	17.0	18.3
	10%	DB	31.3	31.9	27.3	24.1	19.6	17.2	16.5	18.2	21.5	25.2	28.0	28.6
		MCWB	19.8	20.2	18.3	15.5	13.7	12.1	11.1	11.6	13.5	14.7	16.8	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.9	24.7	23.0	20.2	17.9	17.1	14.8	16.2	19.2	19.2	20.9	22.4
		MCDB	31.9	29.3	33.2	25.3	20.6	18.6	19.2	22.6	26.6	26.6	31.1	29.3
	2%	WB	22.5	23.6	21.4	19.1	16.6	14.9	13.4	14.5	16.8	17.6	19.7	20.7
		MCDB	30.8	29.1	28.0	24.3	20.2	19.0	17.1	20.1	22.5	24.0	28.8	27.9
	5%	WB	21.6	22.5	20.4	17.7	15.5	13.7	12.4	13.1	15.5	16.5	18.7	19.8
		MCDB	30.0	30.6	25.8	23.9	19.7	17.6	16.3	18.0	21.0	23.1	26.3	26.6
	10%	WB	20.6	21.7	19.5	16.7	14.7	12.7	11.5	12.1	14.3	15.6	17.8	18.9
		MCDB	28.7	29.8	25.0	22.3	18.5	16.0	15.5	16.6	19.4	22.5	24.7	25.3
Mean Daily Temperature Range	5% DB	MDBR	10.6	10.6	9.6	10.4	9.3	8.4	8.9	10.1	10.3	10.7	10.5	9.7
		MCDBR	16.8	15.5	14.3	15.1	12.0	10.3	11.4	13.9	15.4	17.7	16.7	15.4
		MCWBR	4.7	4.2	4.7	6.0	5.4	5.4	5.9	6.3	6.0	6.0	4.5	4.4
	5% WB	MCDBR	12.6	11.5	10.9	11.8	9.1	8.3	9.4	11.5	11.8	13.3	12.7	10.9
		MCWBR	4.7	4.1	4.9	6.1	5.0	5.4	5.8	6.2	5.7	5.9	4.3	4.8
Clear-Sky Solar Irradiance	taub	0.348	0.347	0.328	0.320	0.308	0.297	0.297	0.308	0.335	0.343	0.349	0.340	
	taud	2.537	2.562	2.602	2.605	2.615	2.624	2.618	2.573	2.491	2.476	2.498	2.543	
	Ebn at Noon	990	971	956	910	870	856	874	909	932	963	982	1001	
	Edh at Noon	110	104	93	83	73	68	71	84	102	112	114	110	
All-Sky Solar Radiation	RadAvg	8.03	7.18	5.96	4.48	3.23	2.69	2.93	3.89	5.28	6.55	7.44	7.97	
	RadStd	0.39	0.37	0.31	0.21	0.13	0.15	0.13	0.21	0.34	0.33	0.33	0.35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page