

LEIGH CREEK, Australia

WMO: 946740

Lat: 30.5964S

Lon: 138.4219E

Elev: 36

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.0	39.0	11.9	10.1	81.4	16.6	12.8	76.3	25.2	58.5	23.6	57.8	4.1	140	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.8	104.2	66.4	101.0	65.1	98.0	64.3	72.9	86.0	70.8	87.5	69.1	87.8	12.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	109.6	78.4	66.0	95.8	76.7	62.5	84.7	75.7	36.6	86.0	34.7	88.0	33.2	87.3	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 25.3	23.0	20.8	DB	32.2	108.1	2.2	1.6	30.6	109.2	29.3	110.2	28.1	111.1	26.5	112.2	(4)
(5)			WB	30.0	75.3	2.4	1.8	28.3	76.5	26.9	77.6	25.5	78.5	23.7	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	82.5	82.0	75.3	66.8	59.0	53.2	51.5	54.6	61.9	66.6	73.1	78.2	(6)
(7)		DBStd	12.44	7.28	7.18	6.60	6.01	5.07	4.49	3.92	5.18	7.07	7.30	7.92	7.23	(7)
(8)		HDD50	54	0	0	0	0	1	15	27	9	1	1	0	0	(8)
(9)		HDD65	1578	0	0	4	48	199	355	418	327	145	67	13	2	(9)
(10)		CDD50	6247	1008	895	786	503	278	111	74	152	357	515	694	874	(10)
(11)		CDD65	2298	543	475	325	101	12	1	0	5	51	116	258	411	(11)
(12)		CDH74	29596	7641	6431	3670	935	87	5	1	56	606	1472	3176	5516	(12)
(13)		CDH80	15675	4550	3719	1740	272	5	0	0	9	197	588	1562	3033	(13)
(14)	Wind	WSAvg	9.6	11.4	10.5	9.7	8.7	7.7	7.9	8.1	8.8	10.3	10.6	11.1	11.1	(14)
(15)	Precipitation	PrecAvg	8.2	0.8	1.2	0.4	0.6	0.7	0.7	0.5	0.6	0.8	0.6	0.7	0.7	(15)
(16)		PrecMax	17.7	3.8	6.6	2.0	3.5	2.4	2.9	1.5	2.4	3.9	2.5	2.9	2.9	(16)
(17)		PrecMin	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.3	1.1	1.5	0.6	0.8	0.7	0.8	0.5	0.7	0.9	0.7	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.6	107.2	100.2	91.4	80.5	73.5	70.5	79.9	91.4	96.0	103.1	105.2	(19)
(20)			MCWB	66.7	70.0	64.4	61.3	58.0	55.6	51.9	57.7	60.1	61.3	63.3	65.1	(20)
(21)		2%	DB	104.6	103.2	96.6	86.6	76.4	68.9	66.7	74.0	85.6	91.0	98.2	101.2	(21)
(22)			MCWB	66.9	67.3	63.7	59.3	56.6	54.3	50.9	53.5	58.3	60.4	62.6	63.5	(22)
(23)		5%	DB	101.2	99.7	93.4	82.9	73.2	65.3	63.5	69.7	80.9	86.6	93.5	97.4	(23)
(24)			MCWB	65.6	66.4	62.8	58.6	55.3	52.1	49.8	51.9	56.4	58.6	61.2	62.7	(24)
(25)		10%	DB	97.5	96.5	89.2	79.3	70.0	62.5	60.9	65.8	76.3	82.1	89.1	93.8	(25)
(26)			MCWB	64.4	65.8	62.1	57.6	54.1	50.8	48.9	49.9	54.6	56.8	60.5	62.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.2	76.1	71.6	66.2	60.8	60.1	55.4	59.0	62.6	64.3	70.0	72.3	(27)
(28)			MCD B	84.9	82.8	87.5	74.3	71.4	67.3	60.0	74.2	78.3	85.7	84.5	86.4	(28)
(29)		2%	WB	71.6	74.0	68.3	63.3	58.6	56.8	53.0	55.6	60.2	62.4	66.9	69.7	(29)
(30)			MCD B	87.5	85.1	85.5	75.4	71.1	63.5	61.2	68.8	78.7	83.6	83.9	83.3	(30)
(31)		5%	WB	69.8	72.1	65.8	61.3	57.1	54.3	51.4	53.5	58.4	60.5	65.0	67.5	(31)
(32)			MCD B	90.5	87.1	85.1	77.9	69.1	62.0	60.5	66.0	76.2	79.7	83.1	84.9	(32)
(33)		10%	WB	68.0	70.0	63.8	59.5	55.5	52.2	50.2	51.7	56.4	58.7	63.3	65.3	(33)
(34)			MCD B	90.9	87.3	85.4	77.4	68.0	60.0	59.0	63.1	73.2	77.6	82.5	86.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.8	21.6	22.7	21.8	20.3	18.5	18.9	20.7	22.7	23.5	23.0	24.0	(35)
(36)			MCDBR	26.0	24.5	25.6	25.4	23.8	21.9	22.5	26.4	27.9	28.9	27.8	27.5	(36)
(37)			MCWBR	9.1	8.6	10.0	11.2	11.3	11.4	11.8	12.7	11.6	11.5	10.0	10.2	(37)
(38)		5% WB	MCD BR	21.3	16.6	20.1	19.7	19.3	16.2	18.7	21.2	22.6	23.8	21.7	20.1	(38)
(39)			MCWBR	8.2	6.4	8.6	9.4	9.8	9.6	10.8	10.9	10.8	10.5	9.6	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.363	0.354	0.335	0.325	0.307	0.294	0.297	0.316	0.354	0.357	0.364	0.354	(40)	
(41)		taud	2.435	2.489	2.515	2.523	2.543	2.565	2.541	2.471	2.363	2.374	2.394	2.438	(41)	
(42)		Ebn at Noon	310	307	302	289	279	277	280	287	291	302	307	313	(42)	
(43)		Edh at Noon	39	36	33	29	25	23	25	30	37	40	40	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2556	2328	2026	1568	1185	1008	1102	1420	1854	2214	2422	2586	(44)	
(45)		RadStd	135	147	132	68	62	64	46	63	108	113	120	102	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (3 neighbors)		+0.72	N/A	N/A	+1.93	N/A	N/A	N/A	N/A	+284	+193	(47)

Nomenclature: See separate page