

ADELAIDE KENT TOWN, Australia

WMO: 946750

Lat: 34.9211S

Lon: 138.6217E

Elev: 51

StdP: 100.71

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	5.7	-4.8	2.5	25.4	-2.5	3.1	22.4	8.5	13.8	7.8	13.9	0.7	50	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	38.1	19.1	35.8	18.6	33.5	18.2	21.8	30.4	20.8	30.0	19.8	29.6	4.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.4	24.7	18.0	13.0	23.7	16.4	11.8	23.2	63.8	30.7	60.2	29.5	56.8	29.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.1	6.4	DB	2.4	42.1	0.8	1.9	1.8	43.4	1.3	44.5	0.9	45.6	0.3	47.0	(4)
(5)			WB	1.9	23.7	0.9	2.1	1.3	25.2	0.8	26.4	0.3	27.6	-0.3	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	23.5	23.3	20.7	17.6	14.5	12.0	11.5	12.2	14.3	16.7	19.4	21.3	(6)	
	DBStd	5.50	4.62	4.55	4.07	3.19	2.53	1.98	1.96	2.37	3.00	3.82	4.49	4.54	(7)	
	HDD10.0	16	0	0	0	0	0	4	7	4	1	0	0	0	(8)	
	HDD18.3	1050	3	4	15	51	123	189	212	191	128	81	37	15	(9)	
	CDD10.0	2653	417	372	333	228	139	65	53	73	130	208	283	351	(10)	
	CDD18.3	644	162	143	90	29	4	0	0	1	8	30	71	107	(11)	
	CDH23.3	7341	1930	1631	939	249	18	0	0	5	64	348	835	1321	(12)	
	CDH26.7	3543	1037	836	419	72	2	0	0	1	10	123	373	671	(13)	
(14) Wind	WSAvg	2.9	3.1	3.0	2.8	2.4	2.3	2.4	2.7	2.9	3.2	3.2	3.3	3.2	(14)	
(15) Precipitation	PrecAvg	551	20	14	26	38	61	85	77	70	63	49	31	25	(15)	
	PrecMax	716	42	63	106	106	128	175	160	129	151	105	107	73	(16)	
	PrecMin	357	0	0	0	1	8	31	22	21	16	6	1	6	(17)	
	PrecStd	95	13	15	26	30	32	36	33	33	31	27	22	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	39.7	37.5	32.4	25.6	20.9	19.8	23.7	28.0	33.4	37.3	40.0	(19)	
		MCWB	19.9	20.6	18.6	16.9	14.3	13.4	11.6	12.8	14.5	16.0	18.1	19.1	(20)	
	2%	DB	38.2	36.9	33.9	28.5	22.9	18.1	17.7	20.8	25.1	30.0	33.8	36.5	(21)	
		MCWB	19.4	19.7	18.2	15.7	14.2	12.3	10.9	11.8	13.6	14.6	17.2	17.9	(22)	
	5%	DB	35.4	34.5	31.2	26.0	20.7	16.8	16.2	18.6	22.7	27.2	30.8	33.4	(23)	
		MCWB	19.1	19.0	17.7	15.1	13.4	11.8	10.8	11.1	12.7	14.4	16.5	17.2	(24)	
	10%	DB	32.3	31.8	28.5	23.9	19.0	15.7	15.1	16.7	20.5	24.5	28.2	30.4	(25)	
		MCWB	18.2	18.5	17.1	14.7	13.1	11.4	10.6	10.6	12.3	13.7	16.0	16.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.7	21.7	19.0	16.6	15.2	13.7	14.2	16.6	18.2	20.7	22.0	(27)	
		MCDB	30.7	34.0	28.9	24.2	20.4	17.6	16.1	19.5	22.8	26.3	30.0	29.6	(28)	
	2%	WB	21.7	21.9	20.3	17.7	15.5	13.7	12.7	13.1	15.0	16.7	19.1	20.2	(29)	
		MCDB	30.8	30.7	28.1	23.4	19.3	16.1	14.9	17.6	21.8	24.3	28.7	29.4	(30)	
	5%	WB	20.6	20.7	19.1	16.7	14.7	13.0	12.1	12.3	14.0	15.7	18.1	19.0	(31)	
		MCDB	31.1	29.7	27.6	23.0	18.6	15.4	14.3	16.1	20.1	23.6	26.9	29.2	(32)	
	10%	WB	19.6	19.6	17.9	15.8	14.0	12.3	11.4	11.6	13.1	14.7	16.9	17.8	(33)	
		MCDB	30.6	29.3	26.9	21.9	17.8	14.7	13.8	15.2	18.4	22.1	26.3	27.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	11.1	10.3	9.5	7.9	7.1	6.9	7.8	8.7	10.2	10.7	11.2	(35)	
		MCDBR	15.7	14.3	14.1	13.4	10.5	8.8	8.3	11.3	13.0	15.2	14.9	15.9	(36)	
	5% WB	MCWBR	5.3	5.1	4.9	5.0	4.7	4.6	4.3	5.2	5.3	5.5	5.4	5.5	(37)	
		MCWBR	12.5	11.5	11.3	10.1	8.0	6.5	6.3	8.5	10.6	11.9	12.7	12.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.342	0.324	0.318	0.307	0.298	0.298	0.310	0.333	0.346	0.348	0.338	(40)	
		taud	2.525	2.547	2.586	2.590	2.601	2.609	2.601	2.550	2.480	2.449	2.475	2.524	(41)	
	Ebn at Noon		993	973	954	904	859	841	861	898	928	958	982	1001	(42)	
		Edh at Noon	111	104	93	82	72	67	71	84	102	114	116	112	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.80	6.85	5.57	4.04	2.77	2.28	2.47	3.38	4.64	6.03	7.12	7.66	(44)	
(45)	RadStd		0.39	0.33	0.25	0.22	0.12	0.14	0.11	0.21	0.36	0.38	0.33	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.52	N/A	N/A	+1.37	N/A	N/A	N/A	-73	+172	+110	(46)
(47)	Regional (24 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70	(47)

Nomenclature: See separate page