

MT CRAWFORD, Australia

WMO: 946780

Lat: 34.7253S

Lon: 138.9280E

Elev: 526

StdP: 95.17

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.2	3.9	-5.6	2.5	23.3	-3.5	3.0	21.0	14.5	8.9	13.4	8.2	5.8	100	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	35.3	17.2	32.9	16.6	30.7	16.1	19.7	27.1	18.7	27.0	17.8	26.4	5.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.8	20.9	16.5	12.5	20.2	15.1	11.4	19.2	58.7	26.8	55.2	27.0	52.1	26.5	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.2	10.1	1.8	38.9	1.3	1.6	0.9	40.1	0.2	41.0	-0.5	41.8	-1.5	43.0		
(5)			1.2	21.6	1.4	1.5	0.2	22.7	-0.6	23.6	-1.3	24.4	-2.3	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	20.1	19.8	17.5	14.9	11.6	8.9	8.3	8.9	10.8	13.1	16.3	18.2		
	DBStd	5.70	5.10	4.83	4.46	3.89	2.85	1.96	1.98	2.64	3.29	4.19	4.76	4.88		
	HDD10.0	216	1	0	0	3	13	44	60	55	26	12	1	0		
	HDD18.3	1923	36	36	72	118	211	284	310	293	228	172	98	65		
	CDD10.0	1675	315	274	234	150	62	11	8	20	50	109	189	253		
	CDD18.3	339	92	77	47	16	1	0	0	0	2	11	36	59		
	CDH23.3	4070	1242	913	485	96	1	0	0	0	4	103	426	799		
	CDH26.7	1769	626	413	172	22	0	0	0	0	0	24	155	357		
(14) Wind	WSAvg	5.9	6.1	6.0	5.7	5.4	5.5	5.6	6.1	6.1	6.1	6.1	6.0	6.0		
(15) Precipitation	PrecAvg	536	22	24	23	37	54	71	74	64	63	41	31	34		
	PrecMax	847	59	106	120	115	108	135	148	145	162	130	87	116		
	PrecMin	312	1	0	2	4	8	18	21	12	18	0	6	5		
	PrecStd	117	15	26	23	27	26	34	29	33	33	28	20	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.5	36.7	33.9	29.4	22.1	17.1	15.8	19.4	23.8	29.7	33.6	37.0		
		MCWB	17.8	18.5	17.5	15.2	12.7	11.4	10.2	11.6	12.9	14.2	16.5	17.1		
	2%	DB	35.8	33.9	30.7	25.9	19.5	14.4	13.9	16.8	21.2	26.1	30.7	33.6		
		MCWB	17.5	17.4	16.2	13.8	11.9	10.4	9.3	10.3	12.1	13.5	15.8	16.0		
	5%	DB	32.9	31.6	28.5	23.5	17.7	12.9	12.6	14.8	19.1	23.6	28.1	30.5		
		MCWB	16.7	16.8	15.7	13.1	11.5	9.7	8.9	9.6	11.5	12.9	14.8	15.3		
	10%	DB	30.0	29.1	26.0	21.5	15.9	11.7	11.3	13.1	16.8	21.2	25.4	27.8		
		MCWB	16.1	16.5	15.0	12.7	10.9	9.3	8.5	8.9	10.5	12.2	14.4	14.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	21.7	19.6	17.1	14.5	13.1	12.0	12.7	14.8	17.1	18.9	19.6		
		MCDB	25.1	30.9	26.3	21.3	17.6	14.7	13.2	16.4	20.2	24.2	25.8	25.7		
	2%	WB	19.7	19.8	18.3	15.7	13.4	11.5	10.8	11.4	13.3	15.2	17.6	18.1		
		MCDB	27.9	26.9	25.5	20.8	16.3	13.0	12.2	14.9	18.7	21.8	25.7	26.8		
	5%	WB	18.6	18.6	17.2	14.7	12.6	10.7	9.9	10.4	12.2	14.0	16.6	16.9		
		MCDB	28.5	26.3	24.8	20.6	15.5	11.9	11.3	13.4	17.3	20.9	24.4	26.5		
	10%	WB	17.5	17.5	16.2	13.8	11.8	9.9	9.2	9.6	11.2	13.0	15.5	15.9		
		MCDB	27.4	25.9	23.8	19.5	14.7	11.1	10.5	12.1	15.7	19.1	22.8	24.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	12.1	10.5	8.2	5.4	4.3	4.3	5.3	7.1	9.4	11.4	12.1		
		MCDBR	15.7	14.7	13.0	10.8	7.1	5.5	5.8	7.4	10.5	13.2	14.5	15.4		
	5% WB	MCWBR	4.9	5.1	4.6	4.2	3.5	3.6	3.6	4.4	5.1	5.6	5.5	5.5		
		MCWBR	13.5	12.6	11.6	9.2	5.8	4.4	4.8	6.5	9.2	11.5	12.7	13.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.317	0.303	0.295	0.286	0.277	0.277	0.287	0.309	0.319	0.322	0.314		
		taud	2.544	2.571	2.601	2.606	2.617	2.628	2.619	2.570	2.498	2.476	2.502	2.548		
	Ebn at Noon	Ebn at Noon	1018	999	978	930	887	870	888	926	955	985	1008	1026		
		Edh at Noon	109	102	92	81	70	65	69	82	100	111	113	109		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.85	6.93	5.65	4.09	2.82	2.33	2.52	3.43	4.69	6.07	7.15	7.71		
	RadStd	RadStd	0.39	0.34	0.26	0.22	0.12	0.14	0.10	0.23	0.37	0.39	0.34	0.29		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.43	N/A	N/A	N/A	N/A	N/A	-92	+157	+70	

Nomenclature: See separate page