

NURIOOTPA, Australia

WMO: 946810

Lat: 34.4761S

Lon: 139.0056E

Elev: 906

StdP: 14.22

Time Zone: 9.50 (AUA)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.9	35.1	17.4	13.6	79.6	22.4	17.4	77.8	28.2	52.0	25.8	51.3	3.1	50	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.9	99.5	63.7	95.2	62.5	91.0	61.9	69.6	81.1	67.4	82.1	65.6	81.8	11.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	102.0	73.0	63.5	90.8	71.1	60.5	81.5	69.5	34.3	79.3	32.3	81.9	30.9	81.8	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	20.9	18.5	29.1	106.0	2.0	2.5	27.6	107.8	26.4	109.3	25.3	110.7	23.8	112.5		
(5)			30.2	76.6	1.5	6.1	29.2	80.9	28.3	84.5	27.5	87.9	26.4	92.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.0	71.6	70.8	65.9	59.8	53.5	48.8	48.0	49.0	53.3	58.0	63.5	67.1		
	DBStd	10.53	8.26	8.10	7.46	6.02	4.86	4.04	3.88	4.37	5.41	6.96	8.19	8.24		
	HDD50	271	0	0	0	1	18	69	85	72	19	6	1	0		
	HDD65	2969	26	27	77	178	359	487	527	497	353	241	127	70		
	CDD50	3572	668	584	494	296	126	32	23	40	119	253	406	531		
	CDD65	794	229	191	106	23	1	0	0	0	3	23	82	136		
	CDH74	10487	2960	2331	1281	326	16	0	0	2	56	432	1157	1926		
	CDH80	5097	1588	1179	568	96	0	0	0	0	6	151	520	989		
(14) Wind	WSAvg	8.9	9.7	9.2	8.6	7.7	7.5	7.7	8.9	9.1	9.7	9.6	9.4	9.6		
(15) Precipitation	PrecAvg	19.4	0.8	0.7	0.9	1.5	2.1	2.2	2.6	2.5	2.4	1.8	1.2	0.8		
	PrecMax	28.0	3.1	3.9	5.2	5.0	6.8	5.2	4.6	4.6	5.8	4.6	2.9	3.4		
	PrecMin	8.7	0.0	0.0	0.0	0.1	0.6	0.4	0.6	0.6	0.7	0.0	0.0	0.0		
	PrecStd	4.4	0.6	0.9	0.9	1.2	1.4	1.3	1.1	1.2	1.2	1.3	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.3	101.6	97.4	89.2	76.2	66.1	64.5	71.0	79.9	90.6	97.5	102.8		
		MCWB	64.5	65.8	63.4	60.2	55.2	54.6	51.2	53.4	56.7	59.3	61.6	63.8		
	2%	DB	100.2	97.1	91.2	81.9	71.1	61.3	60.4	65.4	74.2	84.0	91.4	96.6		
		MCWB	63.7	64.7	62.4	57.5	54.7	51.6	49.8	51.5	55.0	57.1	60.7	61.1		
	5%	DB	94.5	92.8	86.5	77.3	66.3	58.6	57.8	61.6	69.3	78.5	86.3	90.5		
		MCWB	63.1	63.5	61.4	56.9	53.7	51.0	49.4	50.4	54.1	56.5	59.3	60.1		
	10%	DB	89.0	87.6	81.1	72.7	62.9	56.5	55.5	58.1	65.0	73.1	80.6	84.8		
		MCWB	62.1	62.5	60.2	56.1	52.9	50.2	49.0	49.5	52.7	55.2	58.2	59.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	73.3	69.4	65.0	59.8	57.1	54.6	55.8	60.6	63.9	67.4	73.4		
		MCDB	80.0	89.0	80.6	72.1	66.3	61.1	58.2	64.2	70.7	79.5	80.3	78.0		
	2%	WB	69.0	69.6	66.5	61.9	57.4	54.1	52.6	53.6	57.9	60.6	64.4	66.9		
		MCDB	81.7	82.8	80.0	70.6	64.0	57.7	56.4	61.1	69.2	73.2	78.8	81.0		
	5%	WB	66.8	67.3	64.3	59.8	55.7	52.6	51.2	52.0	55.6	58.4	62.5	64.1		
		MCDB	84.7	81.2	78.7	69.9	62.2	56.3	55.2	58.4	65.7	71.5	78.9	80.2		
	10%	WB	64.9	65.0	62.2	58.0	54.5	51.3	49.9	50.6	53.7	56.4	60.3	61.9		
		MCDB	84.3	81.6	77.4	68.8	60.8	55.1	53.9	56.4	62.6	69.0	76.2	78.4		
(35) Mean Daily Temperature Range	MDBR		25.9	24.5	22.8	21.4	17.2	14.7	14.3	16.5	18.8	22.5	24.3	25.2		
	5% DB	MCDBR	33.0	30.9	29.9	29.6	23.7	18.7	18.4	23.6	27.3	32.4	32.3	33.8		
		MCWBR	10.0	10.2	9.9	11.1	11.0	10.9	10.5	12.3	12.3	12.2	10.9	10.8		
	5% WB	MCDBR	24.6	23.0	23.1	20.7	16.8	13.6	13.9	18.3	23.1	25.4	26.5	25.3		
		MCWBR	11.6	10.5	10.4	10.5	9.4	9.1	9.1	10.9	12.7	11.8	10.7	12.3		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.329	0.313	0.305	0.295	0.284	0.285	0.295	0.320	0.329	0.334	0.326		
	taud		2.509	2.536	2.568	2.576	2.584	2.604	2.593	2.541	2.463	2.452	2.468	2.516		
	Ebn at Noon		319	313	307	292	278	273	279	291	299	309	316	322		
	Edh at Noon		36	34	30	27	23	21	23	27	33	36	37	36		
(44) All-Sky Solar Radiation	RadAvg		2502	2217	1814	1316	912	751	812	1101	1504	1942	2279	2456		
	RadStd		124	106	87	69	40	45	33	75	119	125	109	92		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	-166	+284	+126

Nomenclature: See separate page