

LOXTON, Australia

WMO: 946820

Lat: 34.4389S

Lon: 140.5978E

Elev: 100

StdP: 14.64

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.3	34.0	18.7	14.1	80.2	23.1	17.5	75.5	21.1	59.9	19.0	59.3	0.7	130	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.7	102.9	66.0	98.7	65.5	94.7	64.3	71.9	84.8	69.9	85.7	68.0	86.6	9.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	106.0	75.5	65.3	93.9	74.3	62.3	84.3	73.4	35.7	83.6	33.9	85.1	32.3	86.7	92.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.7	17.4	15.6	26.9	110.0	1.5	2.5	25.8	111.8	25.0	113.3	24.1	114.7	23.0	116.6		
(5)			28.9	76.2	2.2	3.0	27.3	78.3	26.0	80.1	24.8	81.8	23.1	83.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	75.0	73.9	68.5	61.5	55.4	50.8	50.0	51.8	56.7	61.5	67.2	70.9		
	DBStd	10.54	7.13	7.08	6.74	5.70	4.77	4.24	4.26	4.57	5.57	6.44	7.23	6.96		
	HDD50	134	0	0	0	0	8	41	53	29	3	0	0	0		
	HDD65	2268	4	6	36	134	301	427	465	409	261	151	56	18		
	CDD50	4462	774	670	572	347	174	63	53	85	203	357	516	648		
	CDD65	1120	313	256	143	30	2	0	0	0	11	43	122	200		
	CDH74	16064	4276	3256	1914	526	45	0	2	27	230	908	1925	2955		
	CDH80	8291	2439	1768	913	179	2	0	0	3	66	387	961	1573		
(14) Wind	WSAvg	7.4	8.5	8.2	7.4	6.3	6.0	5.6	6.4	7.2	8.0	8.4	8.4	8.5		
(15) Precipitation	PrecAvg	10.1	0.7	0.7	0.4	0.7	0.9	0.9	1.1	1.0	1.1	1.1	0.9	0.7		
	PrecMax	21.4	3.0	3.9	2.2	2.6	3.3	2.9	2.8	2.6	3.9	4.8	3.1	2.3		
	PrecMin	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0		
	PrecStd	3.2	0.7	0.8	0.5	0.7	0.7	0.7	0.7	0.6	0.8	1.1	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.4	106.2	100.1	91.8	79.0	69.3	69.9	77.4	86.8	95.8	103.0	106.0		
		MCWB	67.6	69.3	65.7	62.3	57.5	54.7	52.9	54.0	57.2	60.4	64.3	65.1		
	2%	DB	103.3	100.4	94.7	85.2	74.0	65.3	65.1	71.5	80.9	89.4	95.8	99.9		
		MCWB	66.9	66.7	65.1	60.3	56.7	53.2	51.4	52.1	55.8	59.5	63.1	64.5		
	5%	DB	98.2	95.9	90.3	80.1	69.6	62.6	62.2	66.6	75.0	84.0	90.5	94.6		
		MCWB	65.5	65.9	64.2	59.1	55.8	52.7	51.0	51.1	55.0	57.8	61.8	63.0		
	10%	DB	92.8	91.1	84.5	75.2	66.3	60.4	59.6	63.1	70.2	78.2	85.1	89.1		
		MCWB	65.0	65.0	62.5	58.2	54.9	51.9	50.3	50.4	53.7	56.4	60.3	62.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.6	75.4	70.5	65.8	61.7	58.6	56.6	57.1	61.2	65.0	69.7	71.5		
		MCDB	82.3	88.9	85.3	74.3	70.2	62.0	61.9	68.2	73.5	80.6	85.7	84.4		
	2%	WB	71.7	72.6	68.3	63.5	59.2	55.9	54.1	54.7	58.8	62.2	67.1	68.4		
		MCDB	85.4	85.1	84.0	75.2	67.9	61.4	60.3	65.3	72.1	77.5	83.1	84.1		
	5%	WB	69.6	70.3	66.3	61.6	57.5	54.3	52.6	53.1	56.7	60.2	65.1	66.2		
		MCDB	88.9	84.1	82.5	74.9	66.1	60.3	59.3	62.7	70.6	75.7	82.3	86.3		
	10%	WB	67.4	67.9	64.6	59.8	55.9	52.8	51.3	51.6	54.9	58.2	62.8	64.3		
		MCDB	88.6	86.8	81.2	72.9	64.3	58.9	58.1	61.3	67.2	74.0	80.1	84.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	29.7	28.2	26.8	26.2	22.2	19.8	19.9	22.4	24.7	27.4	28.4	29.3		
		MCDBR	38.6	36.1	34.9	35.1	28.4	23.3	23.6	29.8	33.6	38.1	37.4	38.9		
		MCWBR	11.0	10.5	10.8	13.5	13.6	13.0	12.3	13.8	13.8	12.9	11.3	11.6		
	5% WB	MCDBR	29.2	25.8	27.7	26.1	22.3	18.8	18.7	23.4	27.4	28.0	28.6	28.6		
		MCWBR	11.6	9.8	10.3	11.3	11.7	11.4	11.1	12.3	12.7	11.4	10.5	11.5		
(40) Clear-Sky Solar Irradiance	taub	0.342	0.338	0.321	0.313	0.299	0.291	0.291	0.302	0.333	0.334	0.343	0.334	0.334		
	taud	2.479	2.514	2.545	2.543	2.564	2.576	2.573	2.527	2.435	2.449	2.455	2.494	2.494		
	Ebn at Noon	315	310	304	289	276	270	276	288	295	308	313	319	319		
	Edh at Noon	37	34	31	27	24	22	23	27	34	36	37	36	36		
(44) All-Sky Solar Radiation	RadAvg	2502	2234	1842	1344	942	771	831	1132	1535	1971	2273	2478	2478		
	RadStd	117	122	94	68	43	46	36	72	109	127	104	91	91		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-158	+283	+133

Nomenclature: See separate page