

LOXTON, Australia

WMO: 946820

Lat: 34.4389S

Lon: 140.5978E

Elev: 30

StdP: 100.96

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -0.4	(c) 1.1	(d) -7.4	(e) 2.0	(f) 26.8	(g) -4.9	(h) 2.5	(i) 24.2	(j) 9.4	(k) 15.5	(l) 8.5	(m) 15.2	(n) 0.3	(o) 130	(p) 0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 16.5	(c) 39.4	(d) 18.9	(e) 37.0	(f) 18.6	(g) 34.9	(h) 18.0	(i) 22.2	(j) 29.3	(k) 21.0	(l) 29.8	(m) 20.0	(n) 30.3	(o) 4.2	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	15.1	24.1	18.5	13.4	23.5	16.8	12.0	23.0	65.2	28.7	61.1	29.5	57.3	30.4	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.8	(b) 7.8	(c) 7.0	(e) -2.8	(f) 43.3	(g) 0.8	(h) 1.4	(i) -3.4	(j) 44.3	(k) -3.9	(l) 45.2	(m) -4.4	(n) 45.9	(o) -5.0	(p) 47.0		
(a) 8.8	(b) 7.8	(c) 7.0	(e) -1.7	(f) 24.5	(g) 1.2	(h) 1.7	(i) -2.6	(j) 25.7	(k) -3.3	(l) 26.7	(m) -4.0	(n) 27.6	(o) -4.9	(p) 28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	23.9	23.3	20.3	16.4	13.0	10.4	10.0	11.0	13.7	16.4	19.6	21.6		
	DBStd	5.86	3.96	3.93	3.74	3.17	2.65	2.35	2.37	2.54	3.09	3.58	4.02	3.87		
	HDD10.0	74	0	0	0	0	4	23	29	16	2	0	0	0		
	HDD18.3	1260	2	3	20	74	167	237	258	227	145	84	31	10		
	CDD10.0	2479	430	372	318	193	97	35	29	47	113	198	287	360		
	CDD18.3	622	174	142	79	17	1	0	0	0	6	24	68	111		
	CDH23.3	8924	2376	1809	1063	292	25	0	1	15	128	504	1069	1642		
	CDH26.7	4606	1355	982	507	99	1	0	0	2	37	215	534	874		
(14) Wind	WSAvg	3.3	3.8	3.7	3.3	2.8	2.7	2.5	2.9	3.2	3.6	3.7	3.8	3.8		
(15) Precipitation	PrecAvg	256	17	18	11	17	23	24	28	26	27	29	22	19		
	PrecMax	544	77	100	57	66	83	73	70	65	100	123	78	59		
	PrecMin	80	0	0	0	0	0	1	1	3	1	0	0	0		
	PrecStd	81	18	21	13	17	17	17	18	15	20	27	17	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	41.2	37.8	33.2	26.1	20.7	21.1	25.2	30.5	35.4	39.4	41.1		
		MCWB	19.8	20.7	18.7	16.8	14.2	12.6	11.6	12.2	14.0	15.8	17.9	18.4		
	2%	DB	39.6	38.0	34.8	29.5	23.4	18.5	18.4	22.0	27.2	31.9	35.5	37.7		
		MCWB	19.4	19.3	18.4	15.7	13.7	11.8	10.8	11.2	13.2	15.3	17.3	18.1		
	5%	DB	36.8	35.5	32.4	26.7	20.9	17.0	16.8	19.2	23.9	28.9	32.5	34.8		
		MCWB	18.6	18.9	17.9	15.1	13.2	11.5	10.6	10.6	12.8	14.4	16.5	17.2		
	10%	DB	33.8	32.8	29.2	24.0	19.1	15.8	15.3	17.3	21.2	25.7	29.5	31.7		
		MCWB	18.3	18.3	16.9	14.5	12.7	11.1	10.2	10.2	12.1	13.6	15.7	16.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	24.1	21.4	18.8	16.5	14.8	13.7	13.9	16.2	18.3	20.9	22.0		
		MCDB	27.9	31.6	29.6	23.5	21.2	16.7	16.6	20.1	23.1	27.0	29.8	29.1		
	2%	WB	22.0	22.6	20.2	17.5	15.1	13.3	12.3	12.6	14.9	16.8	19.5	20.2		
		MCDB	29.7	29.5	28.9	24.0	20.0	16.3	15.7	18.5	22.3	25.3	28.4	28.9		
	5%	WB	20.9	21.3	19.1	16.4	14.1	12.4	11.5	11.7	13.7	15.7	18.4	19.0		
		MCDB	31.6	29.0	28.1	23.9	19.0	15.7	15.2	17.0	21.5	24.3	27.9	30.2		
	10%	WB	19.7	20.0	18.1	15.5	13.3	11.6	10.7	10.9	12.7	14.6	17.1	17.9		
		MCDB	31.4	30.5	27.3	22.7	17.9	14.9	14.5	16.3	19.6	23.3	26.7	28.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.5	15.7	14.9	14.6	12.4	11.0	11.0	12.5	13.7	15.2	15.8	16.3		
		MCDBR	21.5	20.0	19.4	19.5	15.8	12.9	13.1	16.6	18.7	21.2	20.8	21.6		
		MCWBR	6.1	5.8	6.0	7.5	7.6	7.2	6.8	7.7	7.7	7.2	6.3	6.5		
	5% WB	MCDBR	16.2	14.3	15.4	14.5	12.4	10.4	10.4	13.0	15.2	15.6	15.9	15.9		
		MCWBR	6.4	5.4	5.7	6.3	6.5	6.3	6.1	6.8	7.0	6.3	5.8	6.4		
(40) Clear-Sky Solar Irradiance	taub	0.342	0.338	0.321	0.313	0.299	0.291	0.291	0.302	0.333	0.334	0.343	0.334	0.334		
	taud	2.479	2.514	2.545	2.543	2.564	2.576	2.573	2.527	2.435	2.449	2.455	2.494	2.494		
	Ebn at Noon	994	978	959	910	869	851	870	908	929	971	987	1006	1006		
	Edh at Noon	116	108	97	86	75	69	73	86	107	114	118	118	115		
(44) All-Sky Solar Radiation	RadAvg	7.89	7.04	5.81	4.24	2.97	2.43	2.62	3.57	4.84	6.21	7.17	7.81	7.81		
	RadStd	0.37	0.38	0.29	0.21	0.14	0.15	0.11	0.23	0.34	0.40	0.33	0.29	0.29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-88	+157	+74

Nomenclature: See separate page