

KUITPO FOREST RESERVE, Australia

WMO: 946830

Lat: 35.1711S

Lon: 138.6783E

Elev: 1199

StdP: 14.07

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.9	41.2	27.1	22.0	70.5	30.0	25.2	64.5	25.0	51.8	23.1	51.6	9.1	30	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.4	95.3	63.9	90.7	62.8	86.4	62.0	67.7	83.1	66.0	81.2	64.4	79.7	10.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	93.9	69.4	61.6	85.6	68.0	59.6	79.5	66.3	32.7	83.3	31.4	80.3	30.1	79.7	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.2	21.1	18.7	DB	37.0	101.9	1.4	3.3	36.0	104.3	35.2	106.2	34.5	108.1	33.5	110.5	
			WB	35.2	71.3	1.3	2.3	34.3	73.0	33.5	74.3	32.8	75.6	31.8	77.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	67.1	66.3	64.0	60.1	54.5	50.0	48.9	49.8	52.7	56.6	60.8	64.0	(6)
(7)		DBStd	9.11	8.36	7.90	7.44	6.26	4.72	3.32	3.33	4.46	5.46	7.03	8.08	8.32	(7)
(8)		HDD50	200	0	0	0	1	7	39	61	57	25	9	1	0	(8)
(9)		HDD65	3132	68	71	112	178	329	451	498	470	370	281	181	123	(9)
(10)		CDD50	3067	531	457	434	302	146	38	28	52	107	212	326	434	(10)
(11)		CDD65	525	134	108	81	30	3	0	0	0	2	19	56	92	(11)
(12)		CDH74	6152	1754	1213	842	223	7	0	0	1	14	222	666	1210	(12)
(13)		CDH80	2707	906	557	322	56	0	0	0	0	1	55	247	563	(13)
(14)	Wind	WSAvg	10.6	11.6	11.5	10.8	9.9	9.7	10.6	10.3	10.4	10.9	10.8	11.1	(14)	
(15)	Precipitation	PrecAvg	33.0	1.1	1.1	1.4	2.4	3.6	4.3	4.7	4.4	3.6	2.9	1.8	1.5	(15)
(16)		PrecMax	44.6	4.0	6.8	4.3	8.1	9.8	9.6	11.2	7.9	6.4	7.0	4.3	6.0	(16)
(17)		PrecMin	17.9	0.2	0.0	0.0	0.2	0.3	0.7	0.7	1.6	1.3	0.5	0.1	0.2	(17)
(18)		PrecStd	5.8	0.9	1.3	1.1	1.6	1.9	2.0	2.2	1.7	1.3	1.7	1.1	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	101.5	98.3	94.9	86.5	73.8	63.7	63.2	69.2	76.0	85.9	92.3	98.4	(19)	
(20)		MCWB	65.1	65.9	62.6	61.3	56.1	54.1	51.5	54.0	56.5	58.5	62.0	64.1	(20)	
(21)		DB	95.9	91.8	87.9	80.2	68.6	59.7	58.8	64.5	71.9	79.9	86.8	92.8	(21)	
(22)		MCWB	64.2	64.1	62.2	58.9	54.9	51.2	49.5	51.4	54.6	57.9	61.2	62.3	(22)	
(23)		DB	90.4	87.1	83.3	75.3	65.2	56.9	56.2	60.8	67.5	75.1	81.8	86.4	(23)	
(24)		MCWB	63.5	63.1	61.7	57.4	53.9	50.8	48.9	50.3	53.2	56.6	59.5	60.9	(24)	
(25)		DB	83.9	82.0	78.4	71.2	61.9	54.9	54.1	57.3	63.5	70.4	76.6	80.6	(25)	
(26)		MCWB	61.7	62.3	60.2	56.1	53.5	50.2	48.8	49.1	51.6	55.0	58.6	59.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	69.7	70.3	68.1	63.3	59.3	56.0	54.9	55.8	58.7	63.1	66.4	68.4	(27)	
(28)		MCDWB	81.7	86.2	82.3	74.2	64.7	58.7	57.2	64.0	70.6	78.0	79.8	80.8	(28)	
(29)		WB	67.6	67.2	65.7	61.3	57.8	53.9	52.8	53.6	56.4	60.0	63.9	65.6	(29)	
(30)		MCDWB	84.9	82.1	77.2	71.9	62.7	56.5	54.8	60.3	67.3	73.5	79.2	80.7	(30)	
(31)		WB	65.7	65.3	63.8	59.7	56.3	52.7	51.3	52.0	54.6	57.9	62.1	63.4	(31)	
(32)		MCDWB	82.9	80.7	76.8	69.8	61.1	55.1	53.4	57.6	64.0	70.5	76.3	79.8	(32)	
(33)		WB	63.7	63.4	62.0	58.1	54.9	51.4	50.2	50.5	53.0	56.0	60.0	61.5	(33)	
(34)		MCDWB	80.6	77.9	75.7	67.5	59.5	53.7	52.5	55.1	60.8	67.4	73.5	76.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	20.4	18.9	17.4	14.4	10.2	8.4	8.4	10.4	13.3	16.5	18.2	19.3	(35)	
(36)		5% DB	30.0	27.3	24.5	21.0	14.9	11.3	11.2	15.8	20.9	25.6	26.3	29.1	(36)	
(37)		MCWBR	9.7	9.7	8.9	8.5	7.6	7.0	6.8	8.3	9.6	10.8	10.4	10.3	(37)	
(38)		5% WB	25.4	23.3	21.6	17.0	11.7	8.6	8.6	13.4	17.7	22.6	23.2	23.5	(38)	
(39)		MCWBR	10.5	9.9	9.4	8.5	7.2	6.4	6.3	8.0	9.3	10.8	10.7	10.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.326	0.310	0.303	0.295	0.288	0.287	0.298	0.317	0.328	0.332	0.323	(40)	
(41)		taud	2.562	2.580	2.625	2.627	2.630	2.632	2.628	2.581	2.520	2.491	2.510	2.562	(41)	
(42)		Ebn at Noon	320	314	308	292	277	271	277	289	300	309	317	323	(42)	
(43)		Edh at Noon	34	32	29	25	22	21	22	26	31	35	36	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2452	2141	1738	1257	857	708	768	1058	1454	1890	2237	2410	(44)	
(45)		RadStd	123	106	78	71	36	45	34	64	111	116	99	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (26 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126	(47)

Nomenclature: See separate page