

KUITPO FOREST RESERVE, Australia

WMO: 946830

Lat: 35.1711S

Lon: 138.6783E

Elev: 366

StdP: 97.01

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	5.1	-2.7	3.1	21.4	-1.1	3.6	18.1	11.2	11.0	10.3	10.9	4.1	30	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	35.2	17.7	32.6	17.1	30.2	16.7	19.8	28.4	18.9	27.3	18.0	26.5	4.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.4	20.8	16.4	12.2	20.0	15.3	11.4	19.1	58.3	28.5	55.1	26.8	52.2	26.5	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.5	8.4	2.8	38.9	0.8	1.8	2.2	40.2	1.8	41.2	1.4	42.3	0.8	43.6
			1.8	21.9	0.7	1.3	1.3	22.8	0.8	23.5	0.4	24.2	-0.1	25.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	19.5	19.1	17.8	15.6	12.5	10.0	9.4	9.9	11.5	13.6	16.0	17.8	(6)
	DBStd	5.06	4.65	4.39	4.13	3.48	2.62	1.85	1.85	2.48	3.03	3.91	4.49	4.62	(7)
	HDD10.0	111	0	0	0	1	4	22	34	32	14	5	1	0	(8)
	HDD18.3	1740	38	39	62	99	183	251	277	261	206	156	101	68	(9)
	CDD10.0	1704	295	254	241	168	81	21	16	29	59	118	181	241	(10)
	CDD18.3	292	74	60	45	17	2	0	0	0	1	11	31	51	(11)
	CDH23.3	3418	974	674	468	124	4	0	0	1	8	123	370	672	(12)
	CDH26.7	1504	503	309	179	31	0	0	0	0	1	31	137	313	(13)
(14) Wind	WSAvg	4.7	5.2	5.1	4.8	4.4	4.3	4.3	4.7	4.6	4.7	4.9	4.8	5.0	(14)
(15) Precipitation	PrecAvg	837	29	27	35	60	92	110	119	113	91	74	45	39	(15)
	PrecMax	1134	102	172	110	206	249	244	285	200	163	179	109	152	(16)
	PrecMin	454	5	0	0	5	8	19	18	40	32	12	3	4	(17)
	PrecStd	148	23	33	28	41	49	51	55	42	33	42	27	30	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	36.8	35.0	30.3	23.2	17.6	17.3	20.7	24.4	30.0	33.5	36.9	(19)
		MCWB	18.4	18.8	17.0	16.3	13.4	12.3	10.8	12.2	13.6	14.7	16.7	17.8	(20)
	2%	DB	35.5	33.2	31.1	26.8	20.3	15.4	14.9	18.1	22.2	26.6	30.4	33.8	(21)
		MCWB	17.9	17.8	16.8	15.0	12.7	10.7	9.7	10.8	12.5	14.4	16.2	16.8	(22)
	5%	DB	32.5	30.6	28.5	24.0	18.4	13.8	13.5	16.0	19.7	24.0	27.7	30.2	(23)
		MCWB	17.5	17.3	16.5	14.1	12.2	10.5	9.4	10.2	11.8	13.7	15.3	16.0	(24)
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	28.8	27.8	25.8	21.8	16.6	12.7	12.3	14.1	17.5	21.3	24.8	27.0	(25)
		MCWB	16.5	16.8	15.7	13.4	11.9	10.1	9.3	9.5	10.9	12.8	14.8	15.5	(26)
	0.4%	WB	21.0	21.3	20.1	17.4	15.2	13.4	12.7	13.2	14.8	17.3	19.1	20.2	(27)
		MCDB	27.6	30.1	28.0	23.5	18.2	14.8	14.0	17.8	21.5	25.6	26.5	27.1	(28)
	2%	WB	19.8	19.6	18.7	16.3	14.3	12.2	11.6	12.0	13.5	15.5	17.7	18.7	(29)
		MCDB	29.4	27.9	25.1	22.2	17.0	13.6	12.7	15.7	19.6	23.1	26.2	27.1	(30)
(31) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	5%	WB	18.7	18.5	17.7	15.4	13.5	11.5	10.7	11.1	12.6	14.4	16.7	17.5	(31)
		MCDB	28.3	27.1	24.9	21.0	16.2	12.9	11.9	14.2	17.8	21.4	24.6	26.6	(32)
	10%	WB	17.6	17.5	16.7	14.5	12.7	10.8	10.1	10.3	11.6	13.3	15.5	16.4	(33)
		MCDB	27.0	25.5	24.3	19.7	15.3	12.1	11.4	12.8	16.0	19.6	23.1	25.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	10.5	9.6	8.0	5.6	4.7	4.6	5.8	7.4	9.2	10.1	10.7	(35)
		MCDBR	16.7	15.2	13.6	11.6	8.3	6.3	6.2	8.8	11.6	14.2	14.6	16.2	(36)
	5% WB	MCWBR	5.4	5.4	5.0	4.7	4.2	3.9	3.8	4.6	5.4	6.0	5.8	5.7	(37)
		MCWBR	14.1	12.9	12.0	9.5	6.5	4.8	4.8	7.4	9.9	12.6	12.9	13.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.327	0.326	0.310	0.303	0.295	0.288	0.287	0.298	0.317	0.328	0.332	0.323	(40)
		taud	2.562	2.580	2.625	2.627	2.630	2.632	2.628	2.581	2.520	2.491	2.510	2.562	(41)
	Ebn at Noon	Ebn at Noon	1009	989	970	920	874	853	874	912	945	975	998	1017	(42)
		Edh at Noon	107	101	90	79	69	65	68	81	98	109	112	108	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.73	6.75	5.48	3.96	2.70	2.23	2.42	3.33	4.58	5.96	7.05	7.60	(44)
	RadStd	RadStd	0.39	0.33	0.24	0.22	0.12	0.14	0.11	0.20	0.35	0.37	0.31	0.30	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70

Nomenclature: See separate page