

YUNTA, Australia

WMO: 946840

Lat: 32.5707S

Lon: 139.5644E

Elev: 986

StdP: 14.18

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	29.1	32.4	14.2	11.7	62.5	17.7	13.9	63.2	27.0	56.8	24.2	57.0	1.7	0	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.8	103.4	65.1	99.5	64.1	95.9	63.4	70.5	85.9	68.7	86.1	66.9	85.9	12.1	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	101.9	75.0	63.8	91.9	73.6	60.8	82.4	73.7	35.0	84.9	33.4	85.5	31.9	85.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	22.7	20.2	DB	23.9	108.1	2.4	2.8	22.2	110.1	20.7	111.7	19.4	113.3	17.6	115.3	(4)
(5)			WB	22.6	73.0	2.5	2.3	20.7	74.7	19.2	76.0	17.8	77.3	16.0	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	77.0	75.4	69.6	62.1	54.7	49.0	48.9	51.0	57.2	62.7	68.3	72.8		
	DBStd	11.91	7.80	7.74	7.29	6.69	5.64	4.79	4.77	5.40	6.94	7.36	7.72	7.85		
	HDD50	225	0	0	0	1	15	74	79	49	7	0	0	0		
	HDD65	2369	3	6	34	135	324	481	498	435	255	137	48	13		
	CDD50	4718	838	710	606	364	160	43	45	80	222	393	550	707		
	CDD65	1387	376	296	175	48	4	0	0	1	20	64	148	255		
	CDH74	20015	5474	4081	2332	634	36	0	0	16	334	1059	2243	3806		
	CDH80	10399	3202	2257	1081	186	1	0	0	86	422	1099	2065			
(14) Wind	WSAvg	9.2	10.1	9.5	8.6	7.8	7.7	7.6	9.0	9.6	10.5	10.4	10.0	10.1		
(15) Precipitation	PrecAvg	10.2	1.1	0.9	0.6	0.7	1.0	0.7	0.7	0.8	0.8	1.0	0.7	1.0		
	PrecMax	19.8	4.6	4.7	5.7	4.6	4.8	2.4	2.0	2.3	3.8	3.9	3.9	3.7		
	PrecMin	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.5	1.2	1.1	1.1	1.0	1.1	0.6	0.5	0.6	0.8	1.0	0.8	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.0	107.3	99.0	90.1	78.3	67.9	69.2	76.4	87.2	95.3	101.4	105.6		
		MCWB	66.3	68.3	63.6	61.1	56.6	52.8	51.8	54.1	57.2	60.4	62.8	65.3		
	2%	DB	104.1	101.5	94.8	84.9	73.8	64.4	65.3	71.1	82.2	89.6	95.7	100.5		
		MCWB	65.4	65.5	63.0	58.7	55.2	51.2	50.6	51.6	55.7	58.6	62.2	63.5		
	5%	DB	100.0	96.9	90.5	81.2	70.1	61.5	62.1	67.0	77.9	84.9	91.2	95.9		
		MCWB	64.7	64.9	62.1	57.7	53.9	50.5	49.6	50.0	54.7	56.9	60.2	62.4		
	10%	DB	95.4	93.0	86.2	77.2	66.8	59.1	59.4	63.4	73.1	79.8	86.5	91.4		
		MCWB	63.8	64.1	61.2	57.0	53.0	50.3	48.6	49.0	52.9	55.5	59.3	61.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	73.5	69.2	65.1	59.3	57.5	56.1	56.5	60.9	63.7	68.6	71.3		
		MCDB	84.4	88.6	84.2	74.0	70.1	60.8	62.1	69.6	76.6	83.4	81.8	83.3		
	2%	WB	70.0	71.1	67.0	62.5	57.5	54.0	52.6	53.6	58.2	61.0	65.6	67.8		
		MCDB	88.5	85.0	81.2	73.5	67.9	60.5	61.0	65.7	75.3	81.2	82.2	83.4		
	5%	WB	68.2	69.1	65.1	60.3	55.8	52.2	50.8	51.8	56.0	59.2	63.7	65.7		
		MCDB	88.3	86.1	81.3	74.7	66.4	59.2	59.3	63.7	73.7	78.5	83.0	84.9		
	10%	WB	66.4	66.8	63.2	58.5	54.3	50.8	49.4	50.1	54.0	57.3	61.7	63.8		
		MCDB	89.9	86.4	82.3	73.8	64.5	57.6	57.8	61.3	70.3	76.1	81.5	87.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	28.8	27.1	25.9	25.5	21.8	20.0	20.4	22.7	25.6	26.7	27.0	28.4		
		MCDBR	34.2	31.9	31.5	29.8	25.7	23.8	23.4	27.3	31.6	33.4	33.2	34.0		
		MCWBR	12.2	10.9	11.7	13.4	12.9	14.0	12.9	13.9	14.1	14.1	12.7	12.4		
	5% WB	MCDBR	25.6	23.8	23.7	22.6	20.7	18.0	20.3	23.1	27.0	27.2	26.4	25.1		
		MCWBR	10.8	8.8	9.9	10.8	11.1	11.5	12.1	12.8	12.9	12.1	10.7	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.330	0.330	0.312	0.305	0.289	0.280	0.281	0.292	0.321	0.326	0.335	0.326		
	taud		2.516	2.544	2.579	2.571	2.594	2.605	2.591	2.545	2.451	2.454	2.463	2.507		
	Ebn at Noon		320	314	309	294	283	279	284	294	300	311	316	322		
	Edh at Noon		36	34	30	27	23	22	23	27	34	36	37	36		
(44) All-Sky Solar Radiation	RadAvg		2545	2312	1941	1458	1051	872	958	1261	1722	2130	2371	2573		
	RadStd		130	128	130	72	52	54	50	83	120	103	110	92		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+196	N/A	

Nomenclature: See separate page