

YUNTA, Australia

WMO: 946840

Lat: 32.5707S

Lon: 139.5644E

Elev: 301

StdP: 97.77

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	-1.6	0.2	-9.9	1.7	16.9	-8.0	2.0	17.3	12.1	13.8	10.8	13.9	0.8	0	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.0	39.6	18.4	37.5	17.8	35.5	17.5	21.4	29.9	20.4	30.0	19.4	30.0	5.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.6	23.9	17.7	13.1	23.1	16.0	11.8	23.2	63.6	29.4	59.9	29.7	56.4	29.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.2	9.0	DB	-4.5	42.3	1.4	1.5	-5.5	43.4	-6.3	44.3	-7.0	45.2	-8.0	46.3	(4)
(5)			WB	-5.2	22.8	1.4	1.3	-6.3	23.7	-7.1	24.5	-7.9	25.2	-8.9	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	25.0	24.1	20.9	16.7	12.6	9.4	9.4	10.6	14.0	17.0	20.2	22.7	(6)	
	DBStd	6.61	4.34	4.30	4.05	3.72	3.14	2.66	2.65	3.00	3.86	4.09	4.29	4.36	(7)	
	HDD10.0	125	0	0	0	1	8	41	44	27	4	0	0	0	(8)	
	HDD18.3	1316	2	3	19	75	180	267	277	242	142	76	27	7	(9)	
	CDD10.0	2621	466	394	337	202	89	24	25	44	123	218	306	393	(10)	
	CDD18.3	771	209	164	97	27	2	0	0	1	11	36	82	142	(11)	
	CDH23.3	11119	3041	2267	1296	352	20	0	0	9	186	588	1246	2114	(12)	
(13)	CDH26.7	5777	1779	1254	601	103	1	0	0	0	48	234	611	1147	(13)	
(14)	Wind	WSAvg	4.1	4.5	4.3	3.9	3.5	3.4	4.0	4.3	4.7	4.7	4.5	4.5	(14)	
(15) Precipitation	PrecAvg	258	27	22	16	19	25	19	17	20	20	25	19	25	(15)	
	PrecMax	502	117	119	146	116	123	62	50	58	97	99	99	95	(16)	
	PrecMin	87	0	0	0	0	1	0	0	0	0	0	0	0	(17)	
	PrecStd	88	31	29	27	26	27	15	13	15	20	26	21	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	41.8	37.2	32.3	25.7	20.0	20.7	24.7	30.7	35.2	38.6	40.9	(19)	
		MCWB	19.1	20.2	17.5	16.1	13.6	11.6	11.0	12.3	14.0	15.8	17.1	18.5	(20)	
	2%	DB	40.0	38.6	34.9	29.4	23.2	18.0	18.5	21.7	27.9	32.0	35.4	38.1	(21)	
		MCWB	18.6	18.6	17.2	14.8	12.9	10.7	10.4	10.9	13.2	14.8	16.8	17.5	(22)	
	5%	DB	37.8	36.1	32.5	27.3	21.2	16.4	16.7	19.5	25.5	29.4	32.9	35.5	(23)	
		MCWB	18.2	18.3	16.7	14.3	12.2	10.3	9.8	10.0	12.6	13.9	15.6	16.9	(24)	
	10%	DB	35.2	33.9	30.1	25.1	19.3	15.1	15.2	17.4	22.8	26.6	30.3	33.0	(25)	
		MCWB	17.7	17.8	16.2	13.9	11.7	10.1	9.2	9.4	11.6	13.1	15.2	16.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	23.1	20.7	18.4	15.2	14.1	13.4	13.6	16.0	17.6	20.3	21.9	(27)	
		MCDB	29.1	31.5	29.0	23.3	21.2	16.0	16.7	20.9	24.8	28.6	27.7	28.5	(28)	
	2%	WB	21.1	21.7	19.4	16.9	14.2	12.2	11.4	12.0	14.5	16.1	18.7	19.9	(29)	
		MCDB	31.4	29.4	27.3	23.1	19.9	15.8	16.1	18.7	24.0	27.4	27.9	28.5	(30)	
	5%	WB	20.1	20.6	18.4	15.7	13.2	11.2	10.4	11.0	13.4	15.1	17.6	18.7	(31)	
		MCDB	31.3	30.0	27.4	23.7	19.1	15.1	15.2	17.6	23.2	25.8	28.3	29.4	(32)	
	10%	WB	19.1	19.3	17.3	14.7	12.4	10.4	9.7	10.0	12.2	14.1	16.5	17.6	(33)	
		MCDB	32.2	30.2	28.0	23.2	18.0	14.2	14.3	16.3	21.3	24.5	27.5	31.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	15.0	14.4	14.2	12.1	11.1	11.3	12.6	14.2	14.8	15.0	15.8	(35)	
		MCDBR	19.0	17.7	17.5	16.6	14.3	13.2	13.0	15.2	17.5	18.5	18.4	18.9	(36)	
	5% WB	MCWBR	6.8	6.1	6.5	7.5	7.2	7.8	7.2	7.7	7.8	7.8	7.1	6.9	(37)	
		MCWBR	14.2	13.2	13.2	12.5	11.5	10.0	11.3	12.8	15.0	15.1	14.7	13.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.330	0.330	0.312	0.305	0.289	0.280	0.281	0.292	0.321	0.326	0.335	0.326	(40)	
		taud	2.516	2.544	2.579	2.571	2.594	2.605	2.591	2.545	2.451	2.454	2.463	2.507	(41)	
	Ebn at Noon	Ebn at Noon	1008	989	974	927	893	879	894	928	947	981	996	1016	(42)	
		Edh at Noon	112	106	95	86	74	69	73	86	106	114	118	114	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	8.02	7.29	6.12	4.59	3.31	2.75	3.02	3.97	5.43	6.72	7.47	8.11	(44)	
	RadStd	RadStd	0.41	0.40	0.41	0.23	0.16	0.17	0.16	0.26	0.38	0.33	0.35	0.29	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+109	N/A

Nomenclature: See separate page