

KADINA, Australia

WMO: 946850

Lat: 33.9703S

Lon: 137.6628E

Elev: 136

StdP: 14.62

Time Zone: 9.50 (AUA)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.0	35.2	25.8	19.9	77.0	29.1	23.2	66.4	30.5	57.6	28.3	57.1	7.8	120	0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	102.8	66.5	97.8	65.5	93.5	64.3	70.9	85.7	69.3	86.1	67.8	84.6	14.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	102.4	74.7	65.2	93.6	73.0	62.8	86.1	72.0	34.9	84.9	33.5	86.4	32.2	85.0	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.4	24.6	22.4	DB	29.5	109.7	1.2	2.9	28.7	111.8	27.9	113.5	27.3	115.1	26.4	117.2
			WB	29.4	73.4	1.8	1.7	28.1	74.6	27.0	75.6	26.0	76.5	24.6	77.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	74.1	72.6	69.0	62.8	56.7	51.4	50.3	50.9	54.8	60.3	65.6	69.5
	DBStd	10.30	7.50	7.13	6.87	5.49	4.24	3.96	3.95	4.49	5.31	6.87	7.52	7.84
	HDD50	128	0	0	0	0	1	31	45	41	9	1	0	0
	HDD65	2320	5	9	30	106	260	408	454	436	309	184	83	36
	CDD50	4303	748	631	588	385	209	73	55	70	153	319	469	603
	CDD65	1021	287	220	154	41	2	0	0	0	3	37	103	174
	CDH74	13827	3764	2702	1837	513	17	0	0	5	108	724	1583	2574
	CDH80	7065	2109	1417	878	166	1	0	0	0	20	280	783	1411
(14) Wind	WSAvg	12.0	13.4	12.9	12.2	11.2	10.8	10.3	11.4	11.6	11.7	12.4	12.7	13.4
(15) Precipitation	PrecAvg	14.8	0.6	0.8	0.7	1.1	1.6	1.9	1.9	1.7	1.7	1.3	0.9	0.7
	PrecMax	22.8	2.8	3.9	2.3	4.6	4.5	5.4	4.2	3.5	4.2	3.9	2.0	2.1
	PrecMin	9.3	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.2	0.3	0.0	0.0	0.0
	PrecStd	3.1	0.6	1.0	0.6	1.1	0.9	1.1	0.9	0.8	0.9	1.0	0.5	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.0	105.1	101.7	90.6	76.0	65.7	66.1	73.4	83.0	93.4	100.7	106.4
		MCWB	69.0	68.7	64.8	63.1	59.0	54.1	54.7	54.9	58.1	61.0	64.1	66.6
	2%	DB	104.2	98.6	94.0	84.6	71.9	63.0	62.1	68.0	76.9	87.7	94.1	99.9
		MCWB	67.4	67.2	65.0	60.7	58.2	55.2	53.7	53.8	56.8	58.8	62.7	65.3
	5%	DB	97.4	94.3	89.4	80.0	68.5	61.2	60.1	64.3	72.3	82.3	89.5	94.2
		MCWB	66.4	65.7	65.4	59.5	57.5	54.8	53.2	53.4	55.6	58.5	61.5	63.4
	10%	DB	91.4	88.9	84.4	75.3	65.7	59.4	58.4	60.8	67.7	77.1	83.6	88.1
		MCWB	64.8	65.1	63.9	59.3	57.2	53.7	52.8	53.1	54.6	57.4	60.3	62.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.7	73.4	71.8	67.5	63.7	59.6	57.8	58.6	62.1	65.0	68.1	70.8
		MCDB	83.6	85.8	83.5	74.6	69.2	61.6	61.6	64.7	73.9	77.7	84.8	84.9
	2%	WB	70.8	70.7	69.5	64.8	61.1	57.4	55.8	56.5	59.1	62.6	65.8	68.4
		MCDB	88.5	84.7	81.8	74.3	66.8	60.7	59.6	63.5	69.5	76.8	83.4	85.8
	5%	WB	69.2	68.7	67.5	62.8	59.7	55.8	54.6	55.0	57.4	60.8	64.3	66.5
		MCDB	89.1	85.6	81.0	73.8	65.3	59.4	58.5	61.0	67.5	74.8	80.9	84.1
	10%	WB	67.4	67.0	65.9	61.3	58.1	54.5	53.3	53.8	55.9	59.2	62.4	64.6
		MCDB	86.4	83.7	80.3	71.8	63.9	58.4	57.3	59.6	65.2	72.4	78.1	82.1
(35) Mean Daily Temperature Range	5% DB	MDBR	26.8	25.3	23.5	22.4	17.8	16.5	16.4	20.4	23.8	26.5	27.1	26.6
		MCDBR	37.4	34.0	31.4	30.0	22.9	18.0	18.2	26.5	33.0	36.7	37.2	37.9
		MCWBR	11.6	10.1	10.6	12.4	12.0	11.8	11.6	14.6	15.0	14.4	12.4	11.8
	5% WB	MCDBR	27.1	25.8	24.6	21.3	17.1	14.2	15.1	20.5	25.9	27.4	28.1	27.5
		MCWBR	11.1	9.9	9.6	11.0	10.5	10.1	10.8	13.1	13.8	12.5	11.0	11.3
(40) Clear-Sky Solar Irradiance	taub		0.346	0.344	0.326	0.318	0.308	0.297	0.299	0.306	0.333	0.342	0.346	0.338
	taud		2.516	2.545	2.583	2.591	2.604	2.619	2.605	2.566	2.479	2.457	2.478	2.527
	Ebn at Noon		314	308	303	288	274	269	275	288	295	305	312	318
	Edh at Noon		36	33	30	26	23	21	23	27	33	36	37	36
(44) All-Sky Solar Radiation	RadAvg		2504	2222	1815	1345	951	787	856	1162	1577	2000	2318	2467
	RadStd		122	111	80	67	37	41	37	65	109	107	105	99

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (26 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-166	+283	+124	

Nomenclature: See separate page