

FOWLERS GAP, Australia

WMO: 946860

Lat: 31.0863S

Lon: 141.7010E

Elev: 595

StdP: 14.38

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	37.1	11.4	10.1	73.7	15.3	12.2	74.7	25.5	60.2	23.3	61.0	2.1	280	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.1	106.6	66.1	103.2	65.7	100.3	64.8	72.4	87.1	70.6	87.9	69.1	87.9	12.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	108.9	77.1	66.2	98.7	75.2	63.4	89.4	75.7	36.5	84.6	34.9	87.6	33.5	87.4	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	21.6	19.6	30.5	110.4	1.9	3.2	29.1	112.7	28.0	114.6	26.9	116.4	25.5	118.8		
(5)			27.8	74.9	2.2	2.4	26.2	76.6	24.9	78.0	23.7	79.3	22.0	81.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.7	84.9	81.7	76.1	67.8	58.4	52.3	51.9	54.8	61.6	69.2	74.7	80.4	(6)
(7)		DBStd	13.21	7.60	7.38	7.08	6.48	5.61	4.70	5.07	5.60	6.80	7.69	7.86	7.75	(7)
(8)		HDD50	76	0	0	0	0	3	28	34	11	0	0	0	0	(8)
(9)		HDD65	1575	0	0	4	43	218	382	407	324	148	40	8	1	(9)
(10)		CDD50	6550	1083	888	809	533	264	96	93	159	348	596	740	941	(10)
(11)		CDD65	2576	618	468	348	126	14	1	1	7	46	171	299	477	(11)
(12)		CDH74	34744	9139	6328	4110	1340	130	4	7	67	655	2301	3923	6740	(12)
(13)		CDH80	19361	5774	3701	2070	471	8	0	0	8	215	1053	2090	3971	(13)
(14)	Wind	WSAvg	9.6	11.4	10.9	9.7	8.5	7.6	7.8	7.9	8.7	9.7	10.4	10.9	11.2	(14)
(15)	Precipitation	PrecAvg	9.4	1.2	1.3	0.5	0.4	0.8	0.7	0.8	0.5	0.8	0.6	1.0	1.1	(15)
(16)		PrecMax	20.2	6.8	5.4	3.0	2.4	2.8	2.1	2.8	1.9	4.0	2.5	3.9	4.7	(16)
(17)		PrecMin	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	4.4	1.7	1.5	0.7	0.6	0.7	0.5	0.8	0.6	0.9	0.7	0.9	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.7	108.7	102.1	93.9	81.1	72.7	74.3	80.2	90.8	98.8	106.6	108.8	(19)
(20)			MCWB	67.1	67.6	65.8	63.1	58.7	56.8	55.1	54.9	57.4	61.6	64.1	65.9	(20)
(21)		2%	DB	107.6	104.3	97.9	88.7	77.8	68.0	70.0	75.2	86.0	94.3	100.6	103.7	(21)
(22)			MCWB	67.0	66.2	64.1	61.8	57.5	53.8	53.4	53.3	56.2	60.5	62.4	65.1	(22)
(23)		5%	DB	103.9	100.5	94.3	85.4	74.5	64.7	66.4	71.4	81.5	90.5	95.9	100.3	(23)
(24)			MCWB	66.7	65.8	63.4	60.3	56.1	52.5	52.0	51.8	54.9	59.1	61.4	63.9	(24)
(25)		10%	DB	100.7	96.6	90.6	82.0	70.6	62.0	62.9	67.5	77.0	86.2	91.4	96.9	(25)
(26)			MCWB	65.8	65.0	63.1	58.9	54.8	51.5	50.3	50.8	54.2	58.1	60.6	63.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.0	75.1	71.5	67.4	63.6	60.2	62.9	58.6	62.1	65.4	69.5	74.3	(27)
(28)			MCD B	83.9	87.0	84.5	79.0	70.2	66.4	67.2	66.8	74.0	81.8	82.5	83.4	(28)
(29)		2%	WB	72.7	72.2	69.8	65.1	60.2	56.9	56.0	55.6	59.2	63.5	67.3	69.8	(29)
(30)			MCD B	89.0	85.6	82.8	77.4	71.6	63.3	64.3	70.1	78.8	83.1	81.8	87.9	(30)
(31)		5%	WB	70.7	70.3	68.0	62.9	58.4	54.9	53.0	53.4	57.1	61.7	65.6	67.8	(31)
(32)			MCD B	90.6	87.2	82.7	78.6	70.3	61.8	63.3	68.7	75.3	83.5	81.9	89.0	(32)
(33)		10%	WB	69.1	68.2	66.0	60.9	56.4	53.1	51.1	51.7	55.1	59.8	63.7	65.9	(33)
(34)			MCD B	91.0	88.1	84.5	78.5	67.9	60.0	61.7	66.1	72.6	82.0	84.6	91.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.1	22.3	22.0	22.3	21.3	18.5	20.5	22.6	24.3	24.9	23.7	23.8	(35)
(36)			MCD BR	27.2	25.9	26.2	26.8	25.4	22.2	24.5	27.2	30.6	29.9	29.6	27.0	(36)
(37)			MCWBR	9.2	8.7	10.0	11.7	12.0	12.0	13.1	12.9	13.2	11.7	10.3	9.5	(37)
(38)		5% WB	MCD BR	20.4	19.6	18.9	19.8	20.2	16.6	20.5	22.9	24.2	23.4	21.9	21.8	(38)
(39)			MCWBR	8.3	7.0	7.7	9.0	10.3	9.5	11.9	12.2	11.3	10.4	8.6	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.334	0.316	0.303	0.291	0.282	0.284	0.294	0.338	0.331	0.342	0.332	(40)	
(41)		taud	2.489	2.525	2.553	2.559	2.562	2.574	2.557	2.510	2.378	2.417	2.430	2.471	(41)	
(42)		Ebn at Noon	318	313	308	296	285	280	285	295	296	310	314	320	(42)	
(43)		Edh at Noon	37	34	31	28	25	23	24	29	36	38	39	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2580	2333	2010	1552	1163	971	1078	1392	1834	2215	2413	2586	(44)	
(45)		RadStd	131	133	126	75	65	52	49	66	99	117	137	104	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page