

FOWLERS GAP, Australia

WMO: 946860

Lat: 31.0863S

Lon: 141.7010E

Elev: 182

StdP: 99.16

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.4	2.8	-11.4	1.4	23.2	-9.3	1.7	23.7	11.4	15.7	10.4	16.1	0.9	280	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	41.4	18.9	39.6	18.7	38.0	18.2	22.4	30.6	21.5	31.1	20.6	31.1	5.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.6	25.0	19.0	14.1	24.0	17.5	12.8	24.3	67.0	29.2	63.2	30.9	60.1	30.8	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.8	9.7	8.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-0.8	43.5	1.1	1.8	-1.6	44.8	-2.2	45.9	-2.8	46.9	-3.6	48.2
			-2.3	23.8	1.2	1.3	-3.2	24.8	-3.9	25.5	-4.6	26.3	-5.5	27.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	29.4	27.6	24.5	19.9	14.7	11.3	11.1	12.7	16.4	20.7	23.7	26.9
	DBStd	7.34	4.22	4.10	3.93	3.60	3.12	2.61	2.82	3.11	3.78	4.27	4.37	4.31
	HDD10.0	42	0	0	0	0	2	16	19	6	0	0	0	0
	HDD18.3	875	0	0	2	24	121	212	226	180	82	22	4	1
	CDD10.0	3639	602	493	449	296	147	53	52	88	193	331	411	523
	CDD18.3	1431	343	260	193	70	8	1	1	4	26	95	166	265
	CDH23.3	19302	5077	3516	2283	744	72	2	4	37	364	1278	2179	3744
	CDH26.7	10756	3208	2056	1150	262	4	0	0	4	119	585	1161	2206
Wind	WSAvg	4.3	5.1	4.9	4.4	3.8	3.4	3.5	3.6	3.9	4.3	4.7	4.9	5.0
Precipitation	PrecAvg	239	31	33	12	9	20	17	20	13	20	15	25	27
	PrecMax	514	172	138	77	62	72	54	71	47	101	64	99	119
	PrecMin	79	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	111	44	39	19	14	19	13	20	14	22	17	22	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	42.6	38.9	34.4	27.3	22.6	23.5	26.8	32.7	37.1	41.5	42.7
		MCWB	19.5	19.8	18.8	17.3	14.8	13.8	12.8	12.7	14.1	16.4	17.8	18.9
	2%	DB	42.0	40.1	36.6	31.5	25.4	20.0	21.1	24.0	30.0	34.6	38.1	39.9
		MCWB	19.4	19.0	17.8	16.5	14.2	12.1	11.9	11.8	13.4	15.8	16.9	18.4
	5%	DB	40.0	38.0	34.6	29.7	23.6	18.2	19.1	21.9	27.5	32.5	35.5	37.9
		MCWB	19.3	18.8	17.4	15.7	13.4	11.4	11.1	11.0	12.7	15.0	16.3	17.7
	10%	DB	38.1	35.9	32.5	27.8	21.4	16.7	17.2	19.7	25.0	30.1	33.0	36.1
		MCWB	18.8	18.3	17.3	14.9	12.7	10.8	10.2	10.4	12.3	14.5	15.9	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	24.0	22.0	19.6	17.5	15.6	17.2	14.8	16.7	18.6	20.8	23.5
		MCDB	28.8	30.6	29.2	26.1	21.2	19.1	19.5	19.4	23.4	27.7	28.1	28.5
	2%	WB	22.6	22.3	21.0	18.4	15.7	13.8	13.3	13.1	15.1	17.5	19.6	21.0
		MCDB	31.7	29.8	28.2	25.2	22.0	17.4	18.0	21.2	26.0	28.4	27.7	31.1
	5%	WB	21.5	21.3	20.0	17.2	14.7	12.7	11.7	11.9	14.0	16.5	18.7	19.9
		MCDB	32.5	30.7	28.2	25.9	21.3	16.6	17.4	20.4	24.1	28.6	27.7	31.7
	10%	WB	20.6	20.1	18.9	16.1	13.5	11.7	10.6	11.0	12.8	15.4	17.6	18.9
		MCDB	32.8	31.2	29.1	25.8	20.0	15.6	16.5	19.0	22.6	27.8	29.2	32.8
Mean Daily Temperature Range	5% DB	MDBR	12.8	12.4	12.2	12.4	11.8	10.3	11.4	12.5	13.5	13.9	13.1	13.2
		MCDBR	15.1	14.4	14.5	14.9	14.1	12.3	13.6	15.1	17.0	16.6	16.4	15.0
		MCWBR	5.1	4.8	5.5	6.5	6.6	6.7	7.3	7.2	7.3	6.5	5.7	5.3
	5% WB	MCDBR	11.3	10.9	10.5	11.0	11.2	9.2	11.4	12.7	13.5	13.0	12.1	12.1
MCWBR		4.6	3.9	4.3	5.0	5.7	5.3	6.6	6.8	6.3	5.8	4.8	5.1	
Clear-Sky Solar Irradiance	taub	0.335	0.334	0.316	0.303	0.291	0.282	0.284	0.294	0.338	0.331	0.342	0.332	
	taud	2.489	2.525	2.553	2.559	2.562	2.574	2.557	2.510	2.378	2.417	2.430	2.471	
	Ebn at Noon	1004	987	972	934	898	883	897	929	932	978	990	1010	
	Edh at Noon	116	108	99	88	78	73	77	91	115	119	122	119	
All-Sky Solar Radiation	RadAvg	8.13	7.36	6.34	4.89	3.67	3.06	3.40	4.39	5.78	6.98	7.61	8.15	
	RadStd	0.41	0.42	0.40	0.24	0.20	0.16	0.15	0.21	0.31	0.37	0.43	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page