

LAMEROO AUSTIN PLAINS, Australia

WMO: 946900

Lat: 35.3778S

Lon: 140.5378E

Elev: 364

StdP: 14.50

Time Zone: 9.50 (AUA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.3	36.1	22.7	17.4	77.8	26.0	20.3	77.2	30.1	55.9	27.1	55.4	7.7	70	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.2	102.5	65.6	98.0	64.4	93.8	63.1	69.7	84.8	68.0	84.6	66.2	85.1	13.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	97.5	73.0	63.5	88.7	71.7	60.8	80.5	70.5	34.0	83.3	32.5	84.0	31.1	84.9	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	24.1	21.4	30.5	109.6	1.0	3.1	29.8	111.9	29.2	113.7	28.7	115.5	28.0	117.7
			30.0	72.8	1.0	2.9	29.3	74.9	28.7	76.5	28.2	78.2	27.4	80.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	72.9	71.1	67.4	61.1	54.9	49.8	49.0	50.1	53.6	59.5	64.7	68.8	(6)
(7)		DBStd	10.49	7.88	7.59	7.68	6.12	4.65	3.47	3.54	4.00	5.34	7.18	8.13	8.07	(7)
(8)		HDD50	181	0	0	0	0	8	45	62	48	15	3	0	0	(8)
(9)		HDD65	2677	12	21	60	151	314	457	496	462	345	208	105	46	(9)
(10)		CDD50	3895	709	590	540	333	160	38	31	50	124	296	442	582	(10)
(11)		CDD65	916	256	191	136	33	1	0	0	0	3	36	97	163	(11)
(12)		CDH74	13802	3746	2623	1805	493	19	0	0	7	114	767	1633	2595	(12)
(13)		CDH80	7170	2127	1393	870	172	1	0	0	1	28	320	838	1420	(13)
(14)	Wind	WSAvg	11.1	12.2	11.8	11.1	10.1	10.2	9.5	10.8	11.2	11.6	11.9	12.2	(14)	
(15)	Precipitation	PrecAvg	14.8	0.7	0.9	0.7	1.1	1.4	1.6	1.7	1.8	1.6	1.5	1.1	1.0	(15)
(16)		PrecMax	24.3	3.2	6.1	3.8	4.4	3.5	4.2	3.3	3.5	4.3	5.5	2.7	3.5	(16)
(17)		PrecMin	8.0	0.0	0.0	0.0	0.0	0.1	0.2	0.4	0.5	0.4	0.0	0.0	0.1	(17)
(18)		PrecStd	3.5	0.7	1.2	0.7	1.0	0.9	0.9	0.8	0.8	0.8	1.1	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.0	104.3	100.5	92.2	76.6	66.3	65.9	73.9	83.5	94.9	101.6	106.7	(19)
(20)		0.4%	MCWB	67.5	67.9	64.2	62.6	57.3	53.4	53.7	55.0	57.2	60.5	64.0	65.8	(20)
(21)		2%	DB	103.7	98.6	94.3	84.5	72.0	62.5	61.5	67.6	76.8	88.4	94.8	100.1	(21)
(22)		2%	MCWB	65.7	65.5	63.9	60.1	56.8	53.1	52.6	53.9	56.1	59.0	61.7	64.1	(22)
(23)		5%	DB	97.7	94.2	89.7	79.7	67.5	60.1	58.9	62.8	71.1	82.7	89.8	94.1	(23)
(24)		5%	MCWB	64.7	64.0	63.3	58.3	55.4	52.5	51.8	52.1	54.4	57.0	61.0	62.1	(24)
(25)		10%	DB	91.9	89.0	84.2	74.5	64.4	57.9	56.7	59.5	66.4	76.8	84.0	88.2	(25)
(26)		10%	MCWB	63.5	63.0	61.7	56.9	54.5	51.6	50.9	51.2	53.3	56.2	59.9	61.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	72.7	69.3	64.9	61.1	58.0	56.4	57.4	60.0	64.6	68.2	70.6	(27)
(28)		0.4%	MCDWB	83.7	92.3	80.9	76.0	69.7	60.8	60.8	67.1	73.0	80.8	83.0	87.6	(28)
(29)		2%	WB	69.9	69.4	67.1	62.8	58.7	55.3	54.5	55.0	57.8	61.6	65.8	67.3	(29)
(30)		2%	MCDWB	84.7	83.8	82.1	75.7	66.7	60.3	58.9	64.4	70.8	77.5	82.6	83.5	(30)
(31)		5%	WB	68.0	67.3	65.3	60.8	57.3	53.7	53.0	53.4	56.1	59.5	63.9	65.1	(31)
(32)		5%	MCDWB	88.3	83.0	82.3	73.4	63.8	58.5	57.7	60.5	68.2	76.2	83.0	85.0	(32)
(33)		10%	WB	65.9	65.2	63.7	59.0	55.9	52.4	51.6	52.0	54.3	57.7	61.6	63.1	(33)
(34)		10%	MCDWB	87.7	83.8	81.1	71.2	62.3	56.8	55.9	58.7	64.5	73.6	78.4	82.8	(34)
(35)	Mean Daily Temperature Range		MDBR	30.2	28.7	26.3	24.0	18.8	17.3	16.4	19.4	23.8	28.5	28.8	29.4	(35)
(36)		5% DB	MCDBR	37.7	35.3	32.5	31.3	23.9	20.0	19.0	25.9	33.1	37.6	37.9	38.8	(36)
(37)			MCWBR	11.9	11.3	11.2	12.6	11.5	11.8	11.8	14.2	15.1	14.5	12.3	12.5	(37)
(38)			MCDBR	28.0	27.3	25.8	25.4	19.0	17.0	16.4	21.3	27.6	30.4	30.2	28.7	(38)
(39)		5% WB	MCWBR	11.2	10.2	10.5	11.2	10.4	11.0	11.1	13.0	13.9	13.3	11.4	11.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.333	0.316	0.308	0.297	0.290	0.292	0.301	0.328	0.336	0.340	0.329	(40)	
(41)		taud	2.477	2.517	2.553	2.560	2.574	2.586	2.575	2.534	2.452	2.440	2.458	2.507	(41)	
(42)		Ebn at Noon	316	311	305	289	275	269	274	287	296	307	314	320	(42)	
(43)		Edh at Noon	37	34	30	27	23	21	23	27	33	36	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2476	2197	1781	1288	878	727	782	1070	1449	1902	2228	2420	(44)	
(45)		RadStd	121	111	84	68	44	43	33	61	116	129	115	93	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	-162	+277	+124

Nomenclature: See separate page