

GRIFFITH, Australia

WMO: 947050

Lat: 34.317S

Lon: 146.067E

Elev: 410

StdP: 14.48

Time Zone: 10.00 (AUS)

Period: 90-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.3	33.7	25.1	19.4	65.2	28.0	22.3	59.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.4	99.2	66.6	95.4	66.5	92.0	65.8	73.9	83.4	71.6	83.2	69.8	82.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	118.7	77.2	68.6	106.7	75.4	66.1	97.7	74.3	37.8	82.9	35.6	81.9	34.0	82.8	96.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			28.0	80.2	1.5	7.6	26.9	85.7	26.1	90.2	25.3	94.4	24.2	100.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	74.4	75.2	68.8	61.0	55.3	50.4	48.5	49.8	54.6	60.3	66.1	71.7
	DBStd	11.22	6.69	7.17	6.50	6.05	5.38	4.82	4.17	5.07	5.96	6.46	7.53	7.83
	HDD50	229	0	0	0	1	12	53	80	66	16	1	0	0
	HDD65	2518	4	6	35	151	304	439	513	472	319	181	74	20
	CDD50	4333	756	705	582	331	175	64	33	59	153	320	482	673
	CDD65	1147	295	291	151	31	2	0	0	1	6	35	106	229
	CDH74	14070	3477	3341	1631	384	22	0	0	12	70	548	1453	3132
	CDH80	6514	1704	1681	624	77	1	0	0	2	6	184	636	1599
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	16.0	1.5	1.0	1.2	1.3	1.6	1.4	1.4	1.5	1.5	1.5	1.2	1.2
	PrecMax	26.0	10.1	5.4	8.5	6.7	5.4	2.8	3.5	3.5	4.6	5.6	5.0	4.1
	PrecMin	7.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.2	0.2	0.0	0.0
	PrecStd	4.7	1.9	1.3	1.5	1.3	1.2	0.9	1.0	0.8	1.0	1.3	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.8	102.4	96.7	85.4	76.7	70.3	66.4	74.3	80.5	92.4	99.0	102.9
		MCWB	69.8	69.7	65.9	62.8	59.2	57.2	53.4	56.8	58.9	64.6	64.0	66.2
	2%	DB	97.9	97.6	90.4	82.3	73.2	66.3	62.8	67.2	76.0	85.1	92.9	98.2
		MCWB	68.8	68.1	65.9	61.4	58.2	55.7	53.2	54.6	58.7	60.7	62.8	65.4
	5%	DB	93.4	93.8	86.4	78.9	69.4	62.7	59.6	63.8	71.7	79.8	87.0	93.8
		MCWB	68.3	67.4	65.1	60.7	58.0	54.7	51.9	52.8	57.3	60.5	61.6	64.2
	10%	DB	89.2	90.2	82.9	74.8	65.9	59.6	57.4	60.9	67.5	75.5	82.5	89.4
		MCWB	66.4	67.3	64.1	59.3	56.5	53.0	51.3	51.6	55.7	58.7	60.5	64.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	85.7	77.3	75.1	67.5	64.6	60.2	57.4	60.5	64.0	76.3	69.2	73.9
		MCDB	87.6	84.8	78.3	77.2	68.2	65.1	60.7	67.0	71.9	77.0	80.8	83.0
	2%	WB	73.5	73.6	70.4	65.1	62.1	58.0	55.4	56.8	61.7	65.7	67.1	70.0
		MCDB	83.5	84.6	80.7	72.2	67.3	62.5	59.4	63.6	70.8	75.3	82.1	82.9
	5%	WB	71.4	71.6	67.9	63.0	59.8	56.0	53.2	54.6	59.5	62.9	65.0	67.9
		MCDB	82.3	85.9	80.6	73.1	66.1	61.4	58.4	61.9	67.4	75.0	80.2	84.7
	10%	WB	69.5	69.7	65.7	60.8	57.9	53.6	51.5	52.5	57.0	60.6	62.9	66.0
		MCDB	82.8	83.9	79.0	71.5	64.7	58.8	56.3	59.2	65.4	71.1	78.8	83.3
Mean Daily Temperature Range	5% DB	MDBR	25.2	24.4	24.3	24.2	21.2	17.8	18.6	20.9	22.4	24.5	25.6	26.4
		MCDBR	30.0	28.7	28.1	29.4	25.7	22.0	21.7	25.6	27.4	30.8	32.3	31.7
		MCWBR	10.5	9.3	10.8	12.8	12.9	12.4	13.3	13.9	12.8	12.0	10.6	9.0
	5% WB	MCDBR	22.1	22.0	22.8	21.4	18.2	17.7	17.8	20.8	21.4	23.7	23.8	25.3
		MCWBR	9.9	10.3	11.5	11.0	11.1	11.2	12.2	12.7	11.8	12.8	10.4	9.9
Clear-Sky Solar Irradiance	taub	0.339	0.340	0.319	0.308	0.297	0.289	0.285	0.293	0.322	0.326	0.343	0.336	
	taud	2.505	2.526	2.570	2.568	2.567	2.592	2.597	2.557	2.459	2.478	2.469	2.498	
	Ebn at Noon	316	309	305	291	277	271	279	292	298	310	313	319	
	Edh at Noon	36	34	30	27	23	22	23	27	33	35	37	36	
All-Sky Solar Radiation	RadAvg	2482	2194	1853	1380	1003	784	863	1165	1618	2036	2281	2506	
	RadStd	141	118	104	61	50	56	52	85	112	129	154	95	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.88	N/A	N/A	N/A	+2.30	+0.74	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page