

COBAR MO, Australia

WMO: 947110

Lat: 31.4839S

Lon: 145.8294E

Elev: 865

StdP: 14.24

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.1	39.1	11.6	10.2	76.1	16.0	12.8	76.3	18.5	59.2	16.6	57.5	4.9	200	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.8	104.1	66.0	100.7	65.3	97.7	64.7	72.6	84.4	70.9	84.4	69.5	85.2	10.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	113.2	75.8	67.5	104.5	75.0	65.2	96.2	74.4	36.9	84.5	35.3	82.8	34.1	84.8	91.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.5	14.8	DB	32.7	109.3	1.6	3.5	31.5	111.8	30.6	113.8	29.7	115.7	28.5	118.2	(4)
(5)			WB	30.8	76.4	1.6	4.3	29.7	79.5	28.7	82.0	27.8	84.4	26.6	87.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.9	83.1	80.5	74.9	67.3	58.4	52.7	51.6	54.3	60.6	68.0	73.8	78.8	(6)	
	DBStd	12.62	6.93	6.93	6.52	6.53	5.59	4.78	4.56	5.69	6.87	7.44	7.86	7.16	(7)	
	HDD50	77	0	0	0	0	3	24	33	16	1	0	0	0	(8)	
	HDD65	1636	0	0	7	50	216	368	417	338	169	55	14	2	(9)	
	CDD50	6254	1026	853	771	520	263	106	81	149	321	556	714	894	(10)	
	CDD65	2336	561	434	312	120	10	0	0	6	39	146	278	430	(11)	
	CDH74	28834	7749	5437	3262	1031	64	2	0	52	481	1693	3416	5647	(12)	
	CDH80	14997	4609	2995	1466	307	2	0	0	8	130	678	1706	3096	(13)	
(14) Wind	WSAvg	7.5	8.4	8.0	7.4	6.8	6.1	6.5	6.7	7.1	7.7	8.2	8.1	8.5	(14)	
(15) Precipitation	PrecAvg	16.0	1.7	1.7	1.4	1.0	1.3	1.2	1.1	1.1	1.0	1.4	1.4	1.4	(15)	
	PrecMax	30.1	9.2	7.4	8.6	7.9	5.7	4.4	4.0	3.0	4.2	4.1	6.3	6.0	(16)	
	PrecMin	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	6.7	2.1	1.9	1.6	1.5	1.2	1.0	1.0	0.9	1.1	1.0	1.5	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.3	107.3	99.5	91.6	79.4	72.5	71.4	80.6	89.0	95.3	103.8	106.1	(19)	
		MCWB	67.0	69.0	65.5	62.0	59.0	57.0	53.7	57.1	56.4	59.2	63.1	64.6	(20)	
	2%	DB	104.7	102.4	94.9	87.0	75.7	67.5	67.6	74.3	83.4	91.2	97.9	101.6	(21)	
		MCWB	66.9	66.8	64.6	61.9	57.4	54.4	52.2	53.2	55.5	59.0	62.5	63.8	(22)	
	5%	DB	101.1	98.4	91.3	83.4	72.5	64.3	64.1	69.8	79.4	87.5	93.8	97.8	(23)	
		MCWB	66.4	66.0	63.4	60.2	56.2	53.1	51.0	51.9	54.9	58.5	61.8	63.3	(24)	
	10%	DB	97.7	94.2	87.8	80.2	69.2	61.7	61.1	66.2	75.5	83.4	89.5	94.2	(25)	
		MCWB	65.8	65.4	63.2	59.3	55.0	51.9	49.5	50.3	53.6	57.7	61.5	62.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	75.3	72.3	67.2	64.0	59.8	60.9	60.2	61.7	66.3	69.9	72.6	(27)	
		MCDB	85.1	87.3	81.0	81.0	69.8	64.8	66.3	71.0	73.5	77.3	83.8	82.1	(28)	
	2%	WB	72.3	72.9	69.9	64.8	61.0	57.6	55.6	56.3	59.4	64.1	67.9	70.0	(29)	
		MCDB	84.9	85.7	82.9	75.4	68.6	62.4	61.6	68.2	71.5	77.6	82.0	82.2	(30)	
	5%	WB	70.6	71.1	68.0	63.0	58.8	55.7	53.1	53.7	57.4	61.9	66.3	68.3	(31)	
		MCDB	86.7	84.1	81.1	75.5	67.8	61.3	60.2	67.0	72.4	77.5	79.9	82.8	(32)	
	10%	WB	69.3	69.3	66.2	61.3	56.9	53.9	51.1	51.5	55.4	60.1	64.7	66.4	(33)	
		MCDB	87.9	84.3	80.3	76.3	66.1	59.9	59.0	64.3	72.2	77.8	80.1	84.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.8	21.4	21.2	21.1	19.0	16.7	18.2	20.7	22.7	23.3	23.0	23.5	(35)	
		MCDBR	26.1	25.4	24.7	23.6	21.8	19.7	21.4	24.4	27.4	27.4	27.2	26.8	(36)	
	5% WB	MCWBR	8.4	8.1	8.8	8.8	9.3	9.7	10.6	10.9	10.7	10.0	9.4	9.1	(37)	
		MCWBR	20.5	19.0	19.9	19.6	16.4	14.7	16.5	20.6	21.9	21.9	20.9	20.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.334	0.336	0.315	0.299	0.285	0.281	0.278	0.287	0.321	0.323	0.336	0.328	(40)	
		taud	2.588	2.603	2.647	2.654	2.648	2.652	2.643	2.598	2.485	2.518	2.528	2.571	(41)	
	Ebn at Noon		319	312	309	298	287	281	287	298	301	313	316	322	(42)	
		Edh at Noon	33	32	29	25	23	21	23	26	33	34	35	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2449	2183	1898	1493	1125	906	1025	1326	1756	2114	2307	2488	(44)	
	RadStd		124	151	135	81	59	55	59	79	96	143	194	113	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page