

YOUNG, Australia

WMO: 947120

Lat: 34.2492S

Lon: 148.2475E

Elev: 1249

StdP: 14.04

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.6	28.3	21.9	17.2	51.9	24.6	19.6	42.6	18.7	50.7	16.7	51.3	3.5	190	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.8	98.0	65.5	94.3	65.1	90.7	64.0	70.7	84.4	69.2	83.1	67.7	81.7	10.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	106.0	73.4	65.4	98.1	72.7	63.4	91.5	72.2	35.4	84.2	34.0	83.6	32.8	81.3	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.7	15.1	23.3	102.8	1.7	4.0	22.1	105.6	21.1	108.0	20.1	110.2	18.9	113.1		
(5)			22.6	73.0	1.7	2.1	21.4	74.5	20.4	75.7	19.4	76.9	18.2	78.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	73.8	72.3	66.3	58.2	50.4	46.2	44.0	45.5	50.1	56.2	63.4	68.9		
	DBStd	11.77	6.40	6.15	5.99	5.71	5.24	4.40	3.89	4.21	4.82	6.17	6.94	6.72		
	HDD50	608	0	0	0	7	59	130	190	151	57	13	1	0		
	HDD65	3432	8	11	57	212	452	564	651	603	447	278	112	37		
	CDD50	3480	738	624	505	253	72	16	5	12	60	206	402	587		
	CDD65	832	282	215	98	8	0	0	0	0	0	7	63	159		
	CDH74	11770	3707	2523	1256	234	2	0	0	0	20	358	1198	2472		
	CDH80	5429	1962	1205	443	44	0	0	0	0	1	94	503	1177		
(14) Wind	WSAvg	6.5	7.9	7.5	7.0	5.7	5.3	5.6	5.5	5.9	6.2	6.7	7.3	7.5		
(15) Precipitation	PrecAvg	26.3	2.2	1.7	1.9	2.2	2.4	1.7	2.6	2.6	2.5	2.5	1.9	2.1		
	PrecMax	41.1	10.4	5.7	7.3	11.5	7.4	5.8	5.6	4.9	6.5	6.6	5.1	6.1		
	PrecMin	9.7	0.0	0.0	0.0	0.0	0.2	0.2	0.1	0.3	0.6	0.0	0.0	0.0		
	PrecStd	7.6	2.2	1.6	1.9	2.6	1.7	1.3	1.4	1.1	1.6	1.7	1.4	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.2	101.0	93.9	85.4	73.4	66.3	62.4	68.6	76.7	87.7	97.0	100.8		
		MCWB	67.3	67.6	63.8	61.1	57.8	54.5	52.9	55.5	57.3	60.3	62.9	64.0		
	2%	DB	98.8	95.8	88.8	79.9	69.3	61.3	59.0	63.6	71.7	82.2	90.6	95.2		
		MCWB	66.3	66.2	63.8	59.9	56.1	52.8	51.1	52.4	56.6	59.4	61.7	63.3		
	5%	DB	94.8	91.5	84.8	76.1	66.2	58.7	56.7	60.2	68.0	78.0	85.8	90.8		
		MCWB	65.9	65.2	62.7	58.7	54.9	51.5	49.8	50.8	55.5	58.4	61.0	62.9		
	10%	DB	90.8	87.6	81.3	72.5	62.8	56.2	54.1	57.3	64.2	73.2	81.0	86.9		
		MCWB	65.0	64.7	61.9	57.7	53.8	50.8	48.0	49.4	53.9	57.5	60.2	62.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	73.4	70.3	65.3	61.4	57.4	56.7	57.1	62.6	65.9	68.9	70.5		
		MCDB	87.4	84.9	81.0	75.3	66.3	61.6	59.1	63.7	70.7	75.9	80.9	83.1		
	2%	WB	70.6	71.0	67.7	62.8	58.6	54.8	52.5	54.4	59.5	63.0	66.3	68.2		
		MCDB	86.9	83.0	78.3	72.7	66.0	58.7	57.3	61.1	67.3	74.2	79.5	81.4		
	5%	WB	69.0	69.3	65.9	61.1	56.6	52.9	50.5	52.1	57.2	61.1	64.4	66.4		
		MCDB	85.6	81.8	77.3	71.1	63.9	57.3	55.2	58.6	64.7	71.9	78.6	80.9		
	10%	WB	67.6	67.6	64.3	59.4	54.7	51.2	48.8	49.9	55.0	59.0	62.5	64.7		
		MCDB	83.7	80.6	76.0	69.9	61.3	55.7	53.2	56.4	62.3	70.3	75.0	80.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	28.8	26.4	26.6	27.4	24.6	19.8	20.3	23.0	26.2	29.2	28.6	30.2		
		MCDBR	35.6	33.0	32.5	33.3	29.4	24.6	25.5	28.8	33.9	38.4	37.8	36.4		
		MCWBR	10.5	10.3	12.2	15.7	17.2	16.6	17.9	18.2	19.8	18.1	13.6	11.9		
	5% WB	MCDBR	27.9	24.2	23.9	26.1	23.9	20.3	21.8	25.3	27.1	29.5	28.1	27.9		
		MCWBR	9.8	9.5	10.6	13.7	14.9	14.5	16.0	17.0	17.7	16.5	12.4	11.2		
(40) Clear-Sky Solar Irradiance	taub		0.345	0.340	0.320	0.302	0.290	0.283	0.278	0.284	0.313	0.325	0.338	0.335		
	taud		2.481	2.527	2.554	2.574	2.566	2.597	2.609	2.572	2.469	2.458	2.469	2.500		
	Ebn at Noon		315	310	305	293	280	274	282	295	302	311	315	319		
	Edh at Noon		37	34	31	27	23	22	22	26	33	36	37	36		
(44) All-Sky Solar Radiation	RadAvg		2429	2108	1780	1367	982	742	823	1112	1566	1982	2213	2445		
	RadStd		132	150	126	90	60	65	50	90	133	154	176	104		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-121	+238	+106

Nomenclature: See separate page