

YOUNG, Australia

WMO: 947120

Lat: 34.2492S

Lon: 148.2475E

Elev: 381

StdP: 96.84

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.0	-2.0	-5.6	2.5	11.1	-4.1	2.8	5.9	8.4	10.4	7.5	10.7	1.6	190	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.0	36.7	18.6	34.6	18.4	32.6	17.8	21.5	29.1	20.6	28.4	19.8	27.6	4.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	15.1	23.0	18.5	14.0	22.6	17.4	13.1	22.3	64.5	29.0	61.3	28.7	58.4	27.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.5	6.7	DB	-4.8	39.3	0.9	2.2	-5.5	40.9	-6.1	42.2	-6.6	43.4	-7.3	45.1	(4)
(5)			WB	-5.2	22.8	0.9	1.2	-5.9	23.6	-6.5	24.3	-7.0	24.9	-7.7	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	23.2	22.4	19.1	14.6	10.2	7.9	6.7	7.5	10.1	13.5	17.4	20.5	(6)	
	DBStd	6.54	3.56	3.42	3.33	3.17	2.91	2.44	2.16	2.34	2.68	3.43	3.86	3.73	(7)	
	HDD10.0	338	0	0	0	4	33	72	106	84	32	7	1	0	(8)	
	HDD18.3	1907	4	6	32	118	251	313	362	335	248	154	62	21	(9)	
	CDD10.0	1933	410	347	281	141	40	9	3	7	33	114	223	326	(10)	
	CDD18.3	462	157	119	54	4	0	0	0	0	0	4	35	88	(11)	
	CDH23.3	6539	2059	1402	698	130	1	0	0	0	11	199	666	1373	(12)	
	CDH26.7	3016	1090	669	246	24	0	0	0	0	1	52	279	654	(13)	
(14) Wind	WSAvg	2.9	3.6	3.4	3.1	2.5	2.4	2.5	2.4	2.6	2.8	3.0	3.2	3.4	(14)	
(15) Precipitation	PrecAvg	668	55	43	47	55	62	44	65	66	63	64	48	53	(15)	
	PrecMax	1044	263	145	185	291	188	147	143	124	165	168	129	154	(16)	
	PrecMin	246	0	0	0	0	4	4	3	8	14	1	0	0	(17)	
	PrecStd	194	55	40	47	66	44	34	36	27	41	43	36	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	38.4	34.4	29.7	23.0	19.1	16.9	20.3	24.8	31.0	36.1	38.2	(19)	
		MCWB	19.6	19.8	17.7	16.2	14.3	12.5	11.6	13.0	14.1	15.7	17.2	17.8	(20)	
	2%	DB	37.1	35.4	31.5	26.6	20.7	16.3	15.0	17.5	22.0	27.9	32.6	35.1	(21)	
		MCWB	19.1	19.0	17.6	15.5	13.4	11.5	10.6	11.3	13.7	15.2	16.5	17.4	(22)	
	5%	DB	34.9	33.0	29.3	24.5	19.0	14.8	13.7	15.7	20.0	25.5	29.9	32.7	(23)	
		MCWB	18.9	18.5	17.1	14.9	12.7	10.8	9.9	10.4	13.1	14.7	16.1	17.2	(24)	
	10%	DB	32.6	30.9	27.4	22.5	17.1	13.5	12.3	14.1	17.9	22.9	27.2	30.5	(25)	
		MCWB	18.3	18.1	16.6	14.3	12.1	10.4	8.9	9.7	12.2	14.2	15.7	16.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	23.0	21.3	18.5	16.4	14.1	13.7	13.9	17.0	18.8	20.5	21.4	(27)	
		MCDB	30.8	29.4	27.2	24.1	19.0	16.5	15.1	17.6	21.5	24.4	27.2	28.4	(28)	
	2%	WB	21.4	21.7	19.9	17.1	14.8	12.7	11.4	12.4	15.3	17.2	19.0	20.1	(29)	
		MCDB	30.5	28.3	25.7	22.6	18.9	14.8	14.0	16.1	19.6	23.4	26.4	27.4	(30)	
	5%	WB	20.6	20.7	18.8	16.2	13.6	11.6	10.3	11.2	14.0	16.1	18.0	19.1	(31)	
		MCDB	29.8	27.7	25.2	21.7	17.7	14.0	12.9	14.8	18.2	22.1	25.9	27.2	(32)	
	10%	WB	19.8	19.8	18.0	15.2	12.6	10.7	9.3	10.0	12.8	15.0	17.0	18.1	(33)	
		MCDB	28.7	27.0	24.5	21.1	16.3	13.2	11.8	13.5	16.8	21.3	23.9	26.7	(34)	
(35) Mean Daily Temperature Range	MDBR		16.0	14.7	14.8	15.2	13.7	11.0	11.3	12.8	14.5	16.2	15.9	16.8	(35)	
	5% DB	MCDBR	19.8	18.3	18.1	18.5	16.3	13.7	14.2	16.0	18.8	21.3	21.0	20.2	(36)	
		MCWBR	5.8	5.7	6.8	8.7	9.5	9.2	9.9	10.1	11.0	10.0	7.5	6.6	(37)	
	5% WB	MCDBR	15.5	13.5	13.3	14.5	13.3	11.3	12.1	14.1	15.1	16.4	15.6	15.5	(38)	
		MCWBR	5.5	5.3	5.9	7.6	8.3	8.1	8.9	9.5	9.8	9.2	6.9	6.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.345	0.340	0.320	0.302	0.290	0.283	0.278	0.284	0.313	0.325	0.338	0.335	(40)	
	taud		2.481	2.527	2.554	2.574	2.566	2.597	2.609	2.572	2.469	2.458	2.469	2.500	(41)	
	Ebn at Noon		992	976	960	923	882	863	890	931	951	979	992	1006	(42)	
	Edh at Noon		116	107	97	84	74	68	70	82	103	113	117	115	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.66	6.65	5.61	4.31	3.10	2.34	2.60	3.50	4.94	6.25	6.97	7.71	(44)	
	RadStd		0.42	0.47	0.40	0.28	0.19	0.20	0.16	0.28	0.42	0.49	0.56	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-67	+132	+59

Nomenclature: See separate page