

MUDGE, Australia

WMO: 947270

Lat: 32.5628S

Lon: 149.6150E

Elev: 1547

StdP: 13.89

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.3	29.4	22.3	17.7	51.4	24.9	20.1	46.6	22.5	51.5	20.4	52.7	2.7	30	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	95.9	66.7	92.3	65.6	88.9	65.0	71.3	84.3	69.9	82.2	68.6	80.8	11.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	110.1	73.8	66.7	104.0	73.2	65.1	98.3	72.4	36.1	84.1	34.9	81.8	33.7	80.8	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.7	18.3	16.2	DB	23.4	101.0	1.9	4.0	22.0	103.9	20.9	106.3	19.8	108.5	18.4	111.4
			WB	22.9	73.8	2.0	1.5	21.4	74.9	20.3	75.8	19.2	76.7	17.8	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.6	73.8	72.4	67.5	59.8	52.4	47.7	45.9	47.8	53.3	59.5	65.7	70.3	(6)
(7)		DBStd	11.02	5.64	5.39	4.99	5.14	4.78	4.28	3.92	4.22	4.81	5.72	6.54	5.59	(7)
(8)		HDD50	385	0	0	0	3	30	95	140	96	19	2	0	0	(8)
(9)		HDD65	2869	3	6	31	166	392	520	593	534	352	187	68	17	(9)
(10)		CDD50	3883	737	627	542	297	103	25	11	26	118	297	471	629	(10)
(11)		CDD65	893	276	213	108	10	0	0	0	1	16	88	181		(11)
(12)		CDH74	10213	2981	2051	1069	189	2	0	0	1	63	428	1251	2178	(12)
(13)		CDH80	4241	1425	882	338	25	0	0	0	5	108	520	938		(13)
(14)	Wind	WSAvg	6.9	7.7	7.6	7.0	6.0	5.7	6.0	6.2	6.8	7.2	7.3	7.7	7.7	(14)
(15)	Precipitation	PrecAvg	27.9	3.2	2.6	2.2	1.7	2.1	1.7	2.3	2.2	2.8	2.6	2.4		(15)
(16)		PrecMax	50.2	8.9	8.9	7.7	9.3	6.2	4.6	6.4	5.6	7.3	8.3	7.3	6.0	(16)
(17)		PrecMin	11.9	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.0	0.1	0.0	0.1	0.0	(17)
(18)		PrecStd	7.8	2.3	2.1	1.9	2.0	1.5	1.2	1.7	1.4	1.5	2.0	1.7	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.4	99.7	91.8	83.3	72.8	65.7	65.1	70.9	79.9	87.9	97.8	97.4	(19)
(20)			MCWB	68.3	69.3	65.2	62.4	57.7	54.4	52.4	54.2	57.5	60.6	64.3	65.1	(20)
(21)		2%	DB	96.2	93.9	87.5	78.9	69.7	62.1	61.3	66.8	75.2	83.0	91.3	92.8	(21)
(22)			MCWB	67.7	67.2	65.0	60.3	57.1	52.9	51.0	52.5	56.5	59.2	62.6	65.3	(22)
(23)		5%	DB	92.4	89.3	83.5	75.6	67.0	59.8	58.6	63.2	71.3	78.9	85.9	89.3	(23)
(24)			MCWB	66.9	66.6	63.9	59.1	55.4	52.0	49.8	51.0	55.2	59.0	62.2	63.8	(24)
(25)		10%	DB	88.2	85.3	79.9	72.5	64.1	57.8	56.3	60.1	67.5	74.7	81.0	85.4	(25)
(26)			MCWB	66.0	65.9	63.3	58.3	54.2	51.1	48.8	49.6	54.0	57.9	61.2	63.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	73.4	71.2	65.7	62.1	57.8	57.5	57.6	61.8	65.4	69.2	70.9	(27)
(28)			MADB	87.7	87.5	81.3	74.6	67.2	60.7	60.3	65.5	73.2	76.6	82.9	83.0	(28)
(29)		2%	WB	71.4	71.4	68.8	63.7	59.5	55.6	53.6	54.9	59.3	63.4	66.9	68.9	(29)
(30)			MADB	85.8	83.4	77.8	72.8	65.2	58.8	57.0	62.4	68.7	74.7	79.6	81.7	(30)
(31)		5%	WB	70.0	69.8	67.2	61.8	57.4	54.0	51.4	52.8	57.5	61.6	65.4	67.5	(31)
(32)			MADB	83.8	80.8	76.4	71.3	64.1	58.0	56.1	60.7	66.5	72.5	77.5	80.4	(32)
(33)		10%	WB	68.7	68.2	65.6	60.1	55.7	52.3	49.8	50.7	55.5	59.9	63.8	66.2	(33)
(34)			MADB	82.4	79.6	75.6	69.2	62.7	56.7	55.0	58.4	64.7	70.7	75.1	78.6	(34)
(35)	Mean Daily Temperature Range		MDBR	24.3	22.6	22.9	24.9	23.9	20.7	21.9	24.7	26.4	26.1	25.1	25.5	(35)
(36)		5% DB	MCDBR	32.2	30.6	30.3	30.3	28.5	24.5	26.7	31.5	34.7	34.3	34.3	32.6	(36)
(37)			MCWBR	9.6	9.6	11.4	13.4	16.0	15.6	17.0	18.2	17.5	14.9	12.2	10.6	(37)
(38)		5% WB	MCDBR	24.1	23.0	22.3	23.8	21.4	19.1	20.4	25.9	26.3	25.9	25.2	24.9	(38)
(39)			MCWBR	8.6	8.6	9.5	11.3	12.8	13.3	14.0	16.0	14.7	13.1	10.6	9.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.354	0.352	0.325	0.305	0.286	0.279	0.275	0.283	0.313	0.326	0.350	0.344	(40)	
(41)		taud	2.503	2.532	2.589	2.609	2.620	2.644	2.644	2.603	2.504	2.498	2.476	2.519	(41)	
(42)		Ebn at Noon	312	307	304	294	285	279	287	298	303	311	312	316	(42)	
(43)		Edh at Noon	36	34	30	26	23	21	22	26	32	35	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2320	2026	1700	1365	1045	807	929	1225	1650	1977	2148	2354	(44)	
(45)		RadStd	128	166	145	106	65	66	61	81	112	172	208	162	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.24	N/A	N/A	+2.88	+1.13	+1.21	N/A	N/A	+272	N/A	(46)
(47)	Regional (32 neighbors)	+0.81	N/A	N/A	+1.76	N/A	N/A	-18	-157	+331	+171	(47)

Nomenclature: See separate page