

COONABARABRAN NAMOI, Australia

WMO: 947280

Lat: 31.2711S

Lon: 149.2714E

Elev: 1673

StdP: 13.83

Time Zone: 10.00 (AUS)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 25.1	(c) 27.4	(d) 20.9	(e) 16.7	(f) 34.4	(g) 23.3	(h) 18.7	(i) 35.5	(j) 26.7	(k) 50.6	(l) 20.3	(m) 53.2	(n) 0.3	(o) 270	(p) 0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.9	94.8	66.9	91.5	66.1	88.5	66.0	72.1	82.8	70.5	81.9	69.2	81.1	7.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	114.5	75.8	67.3	106.7	74.7	65.7	100.9	73.5	36.9	82.6	35.5	82.2	34.3	80.9	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.6	(b) 16.0	(c) 12.3	(e) 22.0	(f) 99.4	(g) 2.6	(h) 3.0	(i) 20.1	(j) 101.6	(k) 18.6	(l) 103.4	(m) 17.2	(n) 105.1	(o) 15.3	(p) 107.3		
(a) 20.7	(b) 17.3	(c) 13.3	(e) 20.7	(f) 78.3	(g) 2.5	(h) 4.7	(i) 19.0	(j) 81.6	(k) 17.5	(l) 84.4	(m) 16.1	(n) 87.0	(o) 14.3	(p) 90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	72.3	71.9	66.9	58.8	52.5	47.2	44.9	47.3	52.8	58.6	64.6	69.9		
	DBStd	10.84	5.15	5.25	4.45	4.47	4.90	4.32	3.89	4.58	5.17	5.23	6.93	5.31		
	HDD50	440	0	0	0	2	27	107	164	111	27	2	0	0		
	HDD65	2999	3	7	29	190	387	533	622	550	367	208	90	13		
	CDD50	3686	690	614	524	264	105	24	7	26	110	268	438	616		
	CDD65	772	228	201	89	3	0	0	0	0	0	10	77	164		
	CDH74	9939	2741	2098	1163	186	5	0	0	4	61	349	1083	2249		
	CDH80	3866	1238	851	317	16	0	0	0	0	4	79	430	931		
(14) Wind	WSAvg	4.0	4.5	4.3	3.8	3.4	3.1	3.5	3.6	4.0	4.4	4.7	4.8	4.5		
(15) Precipitation	PrecAvg	32.5	4.8	3.0	2.5	2.0	2.4	1.9	2.2	2.2	2.2	2.8	3.0	2.9		
	PrecMax	53.5	14.4	10.0	8.0	10.0	8.5	6.9	9.7	6.7	5.7	8.9	12.5	9.0		
	PrecMin	16.3	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0	0.0		
	PrecStd	7.6	3.9	2.4	2.0	2.4	2.0	1.5	1.9	1.7	1.6	1.9	2.1	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.8	97.9	93.0	81.8	74.3	68.2	64.5	74.3	81.6	86.5	97.6	96.1		
		MCWB	67.1	71.4	65.0	61.8	59.9	57.3	51.5	57.2	60.8	61.6	64.1	65.6		
	2%	DB	94.8	92.4	87.1	78.6	70.3	64.5	61.9	68.8	76.3	82.3	91.0	92.2		
		MCWB	67.2	68.5	64.4	60.2	57.1	55.2	51.0	54.2	59.4	60.7	63.5	65.3		
	5%	DB	91.3	89.0	83.6	76.0	67.8	61.6	59.2	64.9	72.5	78.5	86.4	88.8		
		MCWB	66.5	68.3	64.8	59.7	56.2	53.2	49.4	52.4	56.7	59.4	63.3	65.6		
	10%	DB	87.5	85.8	80.6	73.2	64.9	59.0	56.7	61.6	68.7	74.4	80.9	85.8		
		MCWB	66.2	66.9	63.0	59.0	55.2	51.7	49.1	50.6	55.0	58.1	62.3	64.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	75.6	71.2	66.9	62.9	59.6	56.1	60.3	66.1	66.0	69.1	73.7		
		MCDB	88.5	91.7	80.5	73.7	69.1	64.5	59.3	69.2	75.4	79.0	82.0	82.4		
	2%	WB	71.4	73.0	69.2	63.9	60.6	57.2	53.8	56.7	61.2	63.5	67.2	69.6		
		MCDB	84.4	82.6	78.5	72.1	66.4	62.2	58.1	65.6	71.2	75.0	80.3	83.3		
	5%	WB	69.9	71.0	67.5	62.1	58.4	55.3	51.8	54.2	58.9	61.7	65.6	68.1		
		MCDB	83.6	80.8	76.3	71.5	64.5	60.2	57.1	61.9	69.0	72.8	78.8	82.3		
	10%	WB	68.5	69.5	65.9	60.6	56.6	53.1	49.9	51.9	56.9	59.9	64.1	66.9		
		MCDB	81.1	80.1	76.0	70.4	62.7	58.0	55.0	60.2	65.3	70.9	76.0	80.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	26.9	25.0	26.3	28.6	25.4	24.5	25.1	28.1	28.9	27.7	26.0	27.7		
		MCDBR	34.0	30.6	32.1	34.8	30.0	29.2	31.5	35.3	35.8	36.6	33.3	33.2		
		MCWBR	11.0	11.1	13.6	17.8	17.9	19.8	21.0	21.7	19.5	16.8	11.6	11.8		
	5% WB	MCDBR	25.8	22.0	22.0	26.7	20.8	23.5	22.1	28.9	30.0	27.0	23.8	26.5		
		MCWBR	11.4	9.3	11.1	15.1	13.2	17.1	16.0	19.0	19.8	14.8	10.2	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.351	0.349	0.321	0.302	0.285	0.280	0.275	0.284	0.316	0.331	0.352	0.344		
	taud		2.519	2.545	2.623	2.635	2.629	2.648	2.646	2.605	2.494	2.490	2.473	2.528		
	Ebn at Noon		313	308	307	297	287	282	288	299	303	310	311	317		
	Edh at Noon		36	34	29	26	23	22	23	26	33	35	37	36		
(44) All-Sky Solar Radiation	RadAvg		2356	2127	1792	1458	1122	889	1016	1315	1726	2044	2208	2389		
	RadStd		137	162	128	87	65	66	60	80	110	160	227	159		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+1.04	N/A	N/A	+2.27	N/A	N/A	-32	-151	+382	+261

Nomenclature: See separate page