

COONABARABRAN NAMOI, Australia

WMO: 947280

Lat: 31.2711S

Lon: 149.2714E

Elev: 510

StdP: 95.35

Time Zone: 10.00 (AUS)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.8	-2.5	-6.1	2.4	1.3	-4.9	2.7	2.0	11.9	10.3	9.1	11.8	0.1	270	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	34.9	19.4	33.1	18.9	31.4	18.9	22.3	28.2	21.4	27.7	20.6	27.3	3.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	16.4	24.3	19.6	15.2	23.7	18.7	14.4	23.1	68.1	28.1	64.8	27.9	61.9	27.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.1	5.5	-5.6	37.5	1.4	1.7	-6.6	38.7	-7.4	39.7	-8.2	40.6	-9.3	41.9		
			-6.3	25.7	1.4	2.6	-7.2	27.6	-8.0	29.1	-8.8	30.6	-9.8	32.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	22.4	22.2	19.4	14.9	11.4	8.5	7.2	8.5	11.5	14.8	18.1	21.0
	DBStd	6.02	2.86	2.92	2.47	2.48	2.72	2.40	2.16	2.54	2.87	2.90	3.85	2.95
	HDD10.0	244	0	0	0	1	15	59	91	62	15	1	0	0
	HDD18.3	1666	2	4	16	106	215	296	346	306	204	116	50	7
	CDD10.0	2048	383	341	291	147	58	13	4	14	61	149	243	342
	CDD18.3	429	127	112	49	2	0	0	0	0	6	43	91	
	CDH23.3	5522	1523	1166	646	103	3	0	0	2	34	194	602	1249
CDH26.7	2148	688	473	176	9	0	0	0	0	2	44	239	517	
Wind	WSAvg	1.8	2.0	1.9	1.7	1.5	1.4	1.5	1.6	1.8	2.0	2.1	2.2	2.0
Precipitation	PrecAvg	826	121	75	63	51	60	48	57	56	55	70	77	74
	PrecMax	1358	365	255	202	254	215	176	246	171	146	226	317	229
	PrecMin	414	1	1	0	0	3	1	0	0	0	6	1	0
	PrecStd	192	98	62	52	60	52	37	47	43	40	48	54	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	36.6	33.9	27.6	23.5	20.1	18.0	23.5	27.5	30.3	36.4	35.6
		MCWB	19.5	21.9	18.3	16.5	15.5	14.0	10.8	14.0	16.0	16.4	17.9	18.7
	2%	DB	34.9	33.6	30.6	25.9	21.3	18.1	16.6	20.4	24.6	27.9	32.8	33.4
		MCWB	19.6	20.3	18.0	15.7	13.9	12.9	10.5	12.3	15.2	15.9	17.5	18.5
	5%	DB	32.9	31.6	28.7	24.5	19.9	16.5	15.1	18.3	22.5	25.8	30.2	31.6
		MCWB	19.2	20.2	18.2	15.4	13.5	11.8	9.7	11.3	13.7	15.2	17.4	18.6
	10%	DB	30.8	29.9	27.0	22.9	18.3	15.0	13.7	16.4	20.4	23.6	27.2	29.9
		MCWB	19.0	19.4	17.2	15.0	12.9	10.9	9.5	10.3	12.8	14.5	16.8	18.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	24.2	21.8	19.4	17.2	15.3	13.4	15.7	19.0	18.9	20.6	23.2
		MCDB	31.4	33.2	27.0	23.2	20.6	18.1	15.2	20.7	24.1	26.1	27.8	28.0
	2%	WB	21.9	22.8	20.6	17.7	15.9	14.0	12.1	13.7	16.2	17.5	19.5	20.9
		MCDB	29.1	28.1	25.8	22.3	19.1	16.8	14.5	18.7	21.8	23.9	26.9	28.5
	5%	WB	21.1	21.7	19.7	16.7	14.7	12.9	11.0	12.3	15.0	16.5	18.6	20.1
		MCDB	28.7	27.1	24.6	22.0	18.1	15.6	14.0	16.6	20.5	22.7	26.0	27.9
	10%	WB	20.3	20.9	18.9	15.9	13.7	11.7	10.0	11.1	13.8	15.5	17.8	19.4
		MCDB	27.3	26.7	24.4	21.3	17.1	14.4	12.8	15.7	18.5	21.6	24.5	27.2
Mean Daily Temperature Range	5% DB	MDBR	14.9	13.9	14.6	15.9	14.1	13.6	13.9	15.6	16.0	15.4	14.5	15.4
		MCDBR	18.9	17.0	17.8	19.3	16.6	16.2	17.5	19.6	19.9	20.3	18.5	18.4
		MCWBR	6.1	6.2	7.5	9.9	10.0	11.0	11.7	12.0	10.9	9.3	6.5	6.6
	5% WB	MCDBR	14.3	12.2	12.2	14.8	11.6	13.0	12.3	16.1	16.7	15.0	13.2	14.7
MCWBR		6.3	5.2	6.2	8.4	7.4	9.5	8.9	10.6	11.0	8.2	5.7	7.1	
Clear-Sky Solar Irradiance	taub	0.351	0.349	0.321	0.302	0.285	0.280	0.275	0.284	0.316	0.331	0.352	0.344	
	taud	2.519	2.545	2.623	2.635	2.629	2.648	2.646	2.605	2.494	2.490	2.473	2.528	
	Ebn at Noon	988	971	968	937	906	888	909	943	956	978	980	999	
	Edh at Noon	112	106	92	82	73	68	71	82	103	111	117	112	
All-Sky Solar Radiation	RadAvg	7.43	6.71	5.65	4.60	3.54	2.80	3.20	4.14	5.44	6.45	6.96	7.53	
	RadStd	0.43	0.51	0.41	0.28	0.20	0.21	0.19	0.25	0.35	0.50	0.72	0.50	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.58	N/A	N/A	+1.26	N/A	N/A	-18	-84	+212	+145

Nomenclature: See separate page