

MOUNT BOYCE, AustraliaWMO: **947430**Lat: **33.619S**Lon: **150.274E**Elev: **3543**StdP: **12.91**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	32.6	18.8	16.2	52.4	23.0	19.8	47.9	37.8	40.4	31.4	39.9	13.2	260	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.0	85.7	62.5	81.8	61.7	78.3	61.0	67.4	76.6	65.7	74.5	64.3	72.4	10.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.8	104.9	69.9	63.2	98.9	68.1	61.8	94.1	66.7	34.0	76.7	32.6	74.5	31.4	72.5	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.5	25.0	21.9	28.1	91.5	1.3	3.7	27.2	94.2	26.5	96.3	25.7	98.4	24.8	101.1		
(5)			26.4	71.0	1.2	2.1	25.6	72.5	24.8	73.7	24.2	74.9	23.3	76.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	65.0	63.7	60.0	54.7	49.0	44.1	42.3	44.2	49.5	54.1	58.4	62.1	(6)	
(7)		DBStd	9.76	7.01	6.43	5.64	5.42	5.17	4.73	3.88	5.01	6.18	6.90	7.50	6.97	(7)	
(8)		HDD50	852	0	1	1	17	80	185	241	192	84	36	12	3	(8)	
(9)		HDD65	4308	89	93	174	310	496	626	705	645	465	342	224	139	(9)	
(10)		CDD50	2266	464	383	312	159	49	9	1	12	70	164	265	378	(10)	
(11)		CDD65	247	88	55	20	2	0	0	0	0	0	5	27	50	(11)	
(12)		CDH74	1913	734	386	104	6	0	0	0	0	2	31	230	420	(12)	
(13)		CDH80	519	238	106	13	0	0	0	0	0	1	55	106		(13)	
(14)	Wind	WSAvg	9.3	7.6	7.1	7.1	7.6	9.6	10.1	11.6	11.7	11.3	9.9	9.0	8.5	(14)	
(15)	Precipitation	PrecAvg	46.6	5.8	5.4	5.2	3.8	3.5	3.3	2.1	3.0	2.4	3.3	4.1	4.1	(15)	
(16)		PrecMax	78.6	15.0	15.9	17.4	16.2	10.3	18.6	10.4	17.9	7.1	9.6	13.9	12.6	(16)	
(17)		PrecMin	26.2	1.4	0.6	0.3	0.2	0.1	0.0	0.0	0.2	0.3	0.3	0.6	0.0	(17)	
(18)		PrecStd	13.1	3.7	3.7	3.7	4.1	2.8	3.6	1.9	3.5	1.8	2.3	3.1	3.3	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	88.9	81.6	73.9	65.8	64.2	56.5	62.9	71.8	78.0	86.5	88.0	(19)	
(20)			MCWB	63.3	64.5	61.7	57.2	54.9	62.9	47.0	50.4	53.4	56.1	59.8	61.0	(20)	
(21)		2%	DB	86.5	82.8	76.8	69.2	62.0	56.0	53.2	58.7	67.1	73.6	80.2	83.0	(21)	
(22)			MCWB	63.9	63.4	60.7	55.9	52.9	49.9	45.8	47.6	51.3	54.4	58.3	60.8	(22)	
(23)		5%	DB	81.8	78.6	72.8	66.1	59.2	53.0	50.8	55.5	63.4	69.9	75.6	78.7	(23)	
(24)			MCWB	63.0	62.8	60.4	54.8	51.4	47.9	44.6	46.0	49.7	53.9	58.4	59.4	(24)	
(25)		10%	DB	77.6	74.6	69.3	63.1	56.7	50.6	48.5	52.5	60.2	66.4	71.5	74.9	(25)	
(26)			MCWB	62.0	62.5	59.1	53.8	50.5	46.7	43.6	44.5	48.9	52.8	57.0	58.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	70.3	67.3	61.1	58.5	63.0	50.8	52.6	56.1	62.1	65.0	66.8	(27)	
(28)			MADB	80.1	78.6	73.6	67.8	62.8	64.5	53.5	59.5	65.3	68.2	74.3	76.9	(28)	
(29)		2%	WB	67.5	67.3	64.6	58.7	55.4	52.1	47.9	49.7	53.9	58.7	62.6	64.4	(29)	
(30)			MADB	77.9	75.6	70.7	64.5	58.7	53.9	50.6	55.3	61.5	66.2	72.1	73.6	(30)	
(31)		5%	WB	65.9	65.5	62.5	57.2	53.3	49.2	46.0	47.7	52.2	56.5	60.8	62.8	(31)	
(32)			MADB	75.9	73.7	68.3	62.2	57.1	51.3	48.7	53.0	59.8	64.5	70.3	71.8	(32)	
(33)		10%	WB	64.3	63.9	60.8	55.6	51.5	47.5	44.6	45.8	50.3	54.8	59.0	61.3	(33)	
(34)			MADB	72.9	71.4	66.7	60.7	55.2	49.8	47.5	51.1	57.5	62.8	68.0	70.5	(34)	
(35)	Mean Daily Temperature Range		MDBR	18.0	16.0	14.7	14.0	11.9	10.0	11.1	13.6	15.6	17.1	17.5	18.5	(35)	
(36)		5% DB	MADB	24.9	22.1	19.7	17.4	14.9	12.7	14.0	17.1	19.5	21.2	23.4	23.7	(36)	
(37)				MCWBR	10.2	9.4	9.3	8.0	7.8	7.8	8.4	9.1	9.1	9.7	9.7	9.8	(37)
(38)			5% WB	MADB	20.8	18.3	16.7	14.6	11.5	9.8	10.8	15.0	16.6	18.1	19.5	20.2	(38)
(39)				MCWBR	10.3	9.5	9.3	8.0	7.0	7.4	7.8	9.1	8.7	10.4	10.2	10.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.331	0.310	0.290	0.275	0.265	0.259	0.264	0.291	0.309	0.328	0.327	(40)		
(41)		taud	2.528	2.566	2.604	2.636	2.632	2.676	2.681	2.669	2.569	2.535	2.515	2.540	(41)		
(42)		Ebn at Noon	318	313	309	298	287	284	292	304	310	317	318	322	(42)		
(43)		Edh at Noon	35	33	29	25	22	20	21	24	30	33	36	35	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2082	1770	1515	1234	979	766	892	1177	1578	1838	1944	2141	(44)		
(45)		RadStd	161	172	144	109	68	66	64	79	104	192	189	204	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-202	+189	N/A
(47) Regional (39 neighbors)		+0.77	N/A	N/A	+1.40	N/A	N/A	-4	-155	+333	+178

Nomenclature: See separate page