

MOSS VALE, Australia

WMO: 947460

Lat: 34.5253S

Lon: 150.4217E

Elev: 679

StdP: 93.43

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.5	-0.1	-5.4	2.6	11.4	-3.8	3.0	8.9	15.1	8.0	14.1	7.8	1.0	250	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	32.3	17.7	29.7	17.3	27.4	17.0	20.6	25.9	19.7	24.9	19.0	23.8	6.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	15.2	22.1	18.3	14.3	21.2	17.5	13.6	20.4	62.7	26.0	59.5	25.1	56.7	23.9	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	11.9	10.4	-3.9	36.7	0.8	2.1	-4.4	38.2	-4.8	39.4	-5.3	40.6	-5.8	42.1		
(5)			-4.3	22.4	0.8	1.3	-4.9	23.4	-5.3	24.1	-5.8	24.9	-6.3	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	19.6	18.6	16.7	13.6	10.0	7.8	7.1	7.9	10.7	13.3	15.7	17.7		
	DBStd	5.30	3.69	3.34	3.06	2.95	2.48	2.19	2.26	2.54	3.13	3.57	3.80	3.68		
	HDD10.0	316	0	0	0	3	31	73	95	76	27	9	2	0		
	HDD18.3	2066	29	34	69	145	258	317	349	323	230	161	96	56		
	CDD10.0	1483	299	241	208	111	31	6	4	11	48	111	174	239		
	CDD18.3	191	69	41	19	3	0	0	0	0	1	4	18	37		
	CDH23.3	1798	659	300	117	27	0	0	0	0	8	72	227	389		
	CDH26.7	646	286	113	21	4	0	0	0	0	1	11	77	134		
(14) Wind	WSAvg	4.9	5.0	4.8	4.5	4.0	4.5	4.7	5.2	5.2	5.4	5.2	5.1	5.1		
(15) Precipitation	PrecAvg	928	85	92	95	83	74	80	47	65	57	76	92	70		
	PrecMax	1516	222	311	464	431	230	342	154	351	218	226	326	196		
	PrecMin	494	13	3	6	2	2	1	2	2	6	5	2	1		
	PrecStd	269	53	70	80	86	59	79	38	82	42	55	69	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	34.2	29.0	26.8	20.6	16.6	16.7	19.0	24.1	28.1	32.7	33.8		
		MCWB	18.7	19.1	17.5	15.5	12.6	10.7	10.5	10.6	12.7	14.3	16.5	17.6		
	2%	DB	32.9	30.0	26.5	23.2	18.4	14.5	14.3	16.5	21.7	25.3	28.7	30.3		
		MCWB	18.4	17.7	17.0	14.5	11.9	10.2	9.0	9.8	12.1	14.0	15.7	17.0		
	5%	DB	30.1	26.9	24.2	20.7	16.8	13.1	12.7	14.9	19.1	23.1	25.6	27.6		
		MCWB	18.1	18.1	17.2	14.3	11.5	9.5	8.4	9.1	11.3	13.1	15.6	16.6		
	10%	DB	26.9	24.2	21.9	18.9	15.1	11.8	11.4	13.2	16.9	20.6	23.1	25.1		
		MCWB	18.0	17.7	16.6	13.9	10.9	9.0	7.8	8.2	10.4	12.8	15.6	16.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	22.1	20.2	17.6	15.0	12.7	12.8	12.7	14.7	17.1	19.8	20.2		
		MCDB	28.4	26.7	24.4	21.6	17.2	14.4	14.1	16.6	20.4	22.1	24.0	25.9		
	2%	WB	20.8	20.6	19.2	16.2	13.5	11.2	10.6	11.0	13.4	15.7	18.2	19.1		
		MCDB	26.9	25.3	23.0	19.8	16.2	13.1	12.7	14.6	18.4	21.0	24.0	24.9		
	5%	WB	19.9	19.5	18.2	15.5	12.4	10.5	9.3	10.0	12.5	14.8	17.2	18.1		
		MCDB	25.5	24.2	21.7	18.8	15.5	12.3	11.4	13.4	16.9	20.3	23.0	23.9		
	10%	WB	19.1	18.6	17.4	14.7	11.6	9.7	8.3	8.9	11.5	13.8	16.2	17.4		
		MCDB	24.4	22.6	20.7	17.8	14.5	11.5	10.6	12.4	15.7	19.1	21.4	22.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	9.1	8.8	9.3	9.6	7.8	8.3	9.4	10.2	10.7	10.5	10.9		
		MCDBR	17.1	14.3	12.5	12.2	12.4	10.3	10.3	12.1	14.2	15.0	16.0	15.8		
	5% WB	MCWBR	5.3	4.8	4.9	5.3	6.9	6.9	6.2	6.5	6.1	5.6	5.2			
		MCWBR	13.0	11.3	10.4	9.3	10.3	7.9	7.9	10.0	11.5	12.5	12.9	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.357	0.349	0.326	0.302	0.288	0.278	0.271	0.279	0.305	0.321	0.345	0.351		
		taud	2.492	2.543	2.583	2.630	2.622	2.656	2.670	2.634	2.551	2.529	2.492	2.491		
	Ebn at Noon		979	967	953	924	886	871	899	938	960	984	985	989		
		Edh at Noon	115	105	94	79	70	64	66	77	95	105	114	116		
(44) All-Sky Solar Radiation	RadAvg		6.43	5.42	4.66	3.79	3.01	2.35	2.74	3.63	4.88	5.71	6.01	6.60		
	RadStd		0.51	0.51	0.41	0.34	0.18	0.20	0.21	0.24	0.32	0.52	0.55	0.59		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.43	N/A	N/A	+0.76	N/A	N/A	-1	-85	+182	+93

Nomenclature: See separate page