

BELLAMBI, Australia

WMO: 947490

Lat: 34.3692S

Lon: 150.9292E

Elev: 33

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	47.2	48.5	26.4	20.4	58.8	28.8	22.8	57.0	35.9	58.1	31.7	55.6	10.1	260	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.5	83.8	64.7	79.7	67.6	77.4	68.5	73.2	77.1	72.1	76.1	71.1	75.1	15.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.9	118.1	75.6	70.7	113.1	74.8	69.6	109.0	74.1	36.9	77.3	35.9	76.3	35.0	75.3	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.8	26.7	23.7	43.6	95.8	1.8	4.6	42.3	99.1	41.3	101.9	40.3	104.5	39.0	107.8		
(5)			37.7	75.1	1.5	1.6	36.6	76.3	35.8	77.2	35.0	78.2	33.9	79.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	70.9	71.0	69.6	65.8	61.4	57.8	56.4	57.4	60.6	63.2	65.5	68.7
	DBStd	6.41	3.53	3.42	3.47	3.83	3.72	3.10	3.11	3.67	4.59	4.98	4.31	3.97
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1179	2	1	5	34	121	216	268	239	149	92	43	9
	CDD50	5105	649	588	606	473	355	234	198	229	318	410	464	581
	CDD65	809	186	169	146	57	11	0	1	2	16	38	57	126
	CDH74	1885	431	392	245	85	8	0	2	4	77	184	152	305
	CDH80	371	82	39	28	9	0	0	0	0	17	64	47	85
Wind	WSAvg	11.3	11.7	11.7	11.5	10.3	10.3	10.9	10.8	11.6	11.6	11.8	11.8	11.8
Precipitation	PrecAvg	50.7	5.4	5.4	5.9	4.5	4.1	4.4	2.2	3.5	2.4	3.9	4.8	3.7
	PrecMax	80.0	19.0	17.9	19.4	24.1	13.5	21.2	10.0	30.9	8.1	15.4	31.1	14.4
	PrecMin	25.4	1.1	0.5	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.5	0.4
	PrecStd	15.9	4.1	4.4	4.3	5.0	3.9	4.5	2.2	5.5	2.0	3.6	5.1	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.8	84.3	83.2	80.8	75.0	69.5	70.3	73.5	81.7	87.6	86.3	89.9
		MCWB	67.0	69.1	68.1	63.2	59.1	57.1	54.9	55.4	58.2	60.7	62.7	62.5
	2%	DB	80.0	79.8	78.2	76.1	71.7	66.8	66.3	68.7	75.0	78.6	77.5	80.4
		MCWB	70.8	71.1	69.9	65.1	60.1	57.1	54.0	54.8	57.0	60.0	64.0	65.9
	5%	DB	77.4	77.7	76.3	73.7	69.4	65.0	64.1	65.9	70.8	73.4	73.7	76.3
		MCWB	70.6	70.8	68.8	64.8	59.9	56.0	53.5	54.8	57.1	60.0	65.7	68.0
	10%	DB	75.9	76.2	74.8	71.8	67.7	63.3	62.2	63.9	67.5	70.1	71.4	74.3
		MCWB	69.9	70.0	68.3	64.4	59.4	55.2	52.7	54.4	58.0	61.2	64.9	67.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.0	74.7	73.3	69.9	66.0	62.0	60.2	61.2	64.3	66.8	70.2	73.7
		MCDB	77.9	79.2	77.1	75.4	69.0	66.5	65.4	65.7	70.3	72.6	74.7	76.6
	2%	WB	72.9	73.4	71.7	68.2	64.2	59.6	58.0	59.3	62.4	65.4	68.5	71.0
		MCDB	76.8	77.5	75.8	72.9	68.0	64.0	62.5	64.4	67.7	70.7	72.9	75.2
	5%	WB	71.9	72.3	70.6	67.0	62.4	58.4	56.3	57.6	61.2	64.3	67.3	69.8
		MCDB	75.9	76.4	74.7	71.6	67.5	62.8	61.0	63.2	66.5	69.7	71.4	74.0
	10%	WB	70.9	71.1	69.6	65.6	60.7	57.2	54.8	56.0	59.9	63.1	66.0	68.6
		MCDB	74.9	75.1	73.8	70.4	66.3	61.8	60.0	61.9	65.6	68.3	70.2	72.8
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.5	8.9	10.0	10.5	10.0	10.9	11.5	11.8	11.3	9.5	9.6
		MCDBR	11.3	10.8	11.1	12.1	12.4	12.0	13.5	14.2	17.7	18.5	14.7	14.6
		MCWBR	6.7	6.5	7.4	7.8	8.4	7.6	8.1	8.6	9.2	9.3	8.2	7.7
	5% WB	MCDBR	9.2	8.9	9.3	10.0	10.2	9.3	10.2	11.0	12.4	12.4	10.9	10.3
MCWBR		6.2	6.1	6.6	7.2	8.0	7.0	7.6	8.4	8.7	7.8	7.5	7.0	
Clear-Sky Solar Irradiance	taub	0.400	0.392	0.364	0.337	0.318	0.310	0.301	0.309	0.343	0.360	0.387	0.404	
	taud	2.435	2.480	2.539	2.587	2.590	2.610	2.618	2.587	2.494	2.476	2.437	2.400	
	Ebn at Noon	297	293	290	281	269	264	273	286	292	299	299	297	
	Edh at Noon	39	36	31	27	23	22	22	26	32	35	38	40	
All-Sky Solar Radiation	RadAvg	2067	1758	1499	1208	945	739	868	1152	1549	1818	1941	2115	
	RadStd	153	154	126	102	59	69	69	62	90	149	171	164	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-2	-153	+329	+169

Nomenclature: See separate page