

NULLO MOUNTAIN, AustraliaWMO: **947540**Lat: **32.7244S**Lon: **150.2289E**Elev: **3707**StdP: **12.83**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.0	32.6	19.1	16.4	49.7	22.7	19.6	47.5	20.1	44.1	18.3	42.2	8.4	270	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.3	84.9	62.7	81.6	61.8	78.4	61.0	67.4	76.3	65.7	74.4	64.3	72.4	7.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	106.8	69.7	63.4	100.4	67.8	61.9	95.0	66.5	34.2	76.3	32.7	74.9	31.5	72.6	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	17.5	16.0	DB	28.2	90.3	1.2	3.9	27.3	93.1	26.6	95.4	25.9	97.6	25.0	100.5	(4)
(5)			WB	26.2	70.8	1.3	3.5	25.2	73.3	24.4	75.3	23.7	77.3	22.7	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	65.4	63.8	60.1	54.4	48.3	43.6	42.1	44.0	49.5	54.0	58.3	62.6
	DBStd	9.85	6.83	6.41	5.42	5.13	4.60	4.13	3.87	5.03	6.06	6.69	7.42	6.83
	HDD50	872	0	0	1	17	85	197	246	196	83	34	11	2
	HDD65	4345	80	91	172	319	516	643	710	650	466	345	226	127
	CDD50	2258	479	387	313	148	34	3	1	12	67	159	261	394
	CDD65	255	93	57	19	1	0	0	0	0	1	5	25	54
	CDH74	1886	755	399	99	2	0	0	0	0	1	18	203	409
	CDH80	460	216	104	12	0	0	0	0	0	0	0	45	83
Wind	WSAvg	8.3	8.8	9.0	8.4	7.7	7.6	8.3	8.2	8.3	8.2	8.5	8.5	8.4
Precipitation	PrecAvg	28.7	3.1	3.2	2.2	1.9	1.7	2.2	2.1	1.8	2.2	2.3	3.0	3.0
	PrecMax	46.0	6.1	7.8	7.7	6.8	4.4	8.1	5.9	4.6	7.8	7.1	7.0	6.9
	PrecMin	15.7	0.6	0.1	0.2	0.0	0.2	0.6	0.2	0.0	0.1	0.1	0.3	0.7
	PrecStd	7.0	1.5	2.1	1.7	1.7	1.0	1.7	1.5	1.3	1.6	1.5	1.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	88.7	81.7	72.5	63.3	57.1	55.8	62.7	70.7	76.6	85.4	86.8
		MCWB	64.7	64.8	60.2	57.3	52.5	49.4	48.0	50.5	52.9	55.3	59.9	60.7
	2%	DB	85.5	82.8	76.5	68.5	60.0	53.9	52.4	58.3	66.6	72.2	79.4	82.3
		MCWB	63.6	63.4	61.0	56.1	51.4	48.5	45.7	47.2	51.5	54.6	58.4	60.8
	5%	DB	81.8	78.8	72.8	65.5	57.7	51.5	50.2	55.2	63.0	68.8	75.1	78.7
		MCWB	63.2	62.6	60.1	54.5	50.8	47.3	44.7	46.3	49.8	53.8	58.5	59.7
	10%	DB	78.0	74.9	69.5	62.7	55.5	49.7	48.4	52.4	60.1	65.5	71.1	75.2
		MCWB	62.4	61.9	59.2	53.7	50.0	46.2	43.9	44.9	48.9	52.8	56.7	59.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	70.1	67.4	61.2	56.5	52.5	51.7	52.7	56.3	60.7	64.8	67.2
		MCDB	74.1	79.9	72.7	66.2	58.5	54.0	53.1	58.1	64.8	67.7	73.9	75.8
	2%	WB	67.8	67.1	64.6	58.7	54.5	50.3	48.5	50.0	54.0	58.4	62.7	64.7
		MCDB	77.8	75.6	69.5	64.1	57.4	52.2	49.8	54.3	61.7	65.4	71.1	73.9
	5%	WB	66.0	65.3	62.7	57.0	52.5	48.6	46.5	47.9	52.2	56.6	60.8	63.0
		MCDB	75.9	73.1	67.5	62.2	55.8	50.6	48.8	53.3	59.4	63.6	69.4	71.9
	10%	WB	64.5	63.8	61.1	55.4	50.8	47.1	44.8	45.9	50.4	55.1	59.1	61.6
		MCDB	73.6	71.3	66.9	60.3	54.0	48.9	47.2	51.2	57.2	62.3	67.2	70.2
Mean Daily Temperature Range	5% DB	MDBR	17.3	15.6	14.1	13.1	11.2	9.4	10.3	12.7	14.7	15.8	16.4	17.6
		MCDBR	23.0	21.4	19.1	16.7	13.7	11.7	12.7	15.3	17.7	19.4	21.9	21.8
		MCWBR	10.1	9.2	9.2	8.5	8.0	7.9	8.4	8.8	9.2	9.8	9.4	9.5
	5% WB	MCDBR	18.8	17.4	15.1	13.6	10.6	9.4	9.5	12.8	14.5	16.1	17.4	18.1
MCWBR		10.5	9.0	8.9	8.0	7.3	7.3	7.7	8.7	9.0	10.0	9.6	9.6	
Clear-Sky Solar Irradiance	taub	0.334	0.328	0.305	0.287	0.268	0.263	0.257	0.264	0.290	0.308	0.332	0.323	
	taud	2.535	2.576	2.635	2.655	2.675	2.693	2.703	2.668	2.573	2.540	2.501	2.558	
	Ebn at Noon	319	314	311	301	292	286	294	305	311	317	317	323	
	Edh at Noon	35	32	29	25	22	20	21	24	30	33	36	35	
All-Sky Solar Radiation	RadAvg	2187	1900	1598	1299	1020	800	928	1225	1630	1903	2039	2233	
	RadStd	144	167	148	107	69	64	64	81	106	184	199	183	

Historical Trends

	DBAvg	
--	-------	--