

SYDNEY TERREY HILLS, Australia

WMO: 947590

Lat: 33.6908S

Lon: 151.2253E

Elev: 199

StdP: 98.96

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	6.4	-3.0	3.0	15.1	-1.6	3.4	13.1	8.9	13.2	7.8	12.6	3.5	280	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.4	32.4	19.7	29.9	20.3	28.0	20.1	23.5	27.5	22.6	26.4	21.9	25.3	3.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.6	24.6	21.6	16.7	23.8	20.9	16.0	23.2	71.0	27.8	67.8	26.8	65.1	25.4	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.4	5.8	DB	3.2	38.7	1.0	2.8	2.5	40.7	1.9	42.4	1.3	44.0	0.6	46.0	
			WB	1.6	25.1	0.8	1.1	1.0	25.9	0.6	26.5	0.1	27.1	-0.4	27.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	22.2	21.6	20.4	17.8	14.9	12.4	11.9	12.8	15.3	17.5	19.1	20.6
	DBStd	4.41	2.82	2.50	2.36	2.46	2.26	1.84	2.05	2.32	3.07	3.39	3.15	2.89
	HDD10.0	9	0	0	0	0	0	2	4	2	0	0	0	0
	HDD18.3	905	2	2	8	37	110	177	201	173	102	57	26	9
	CDD10.0	2631	377	325	324	235	151	75	62	88	159	232	274	329
	CDD18.3	486	120	94	73	22	2	0	0	1	11	32	51	81
	CDH23.3	2433	671	403	223	72	4	0	0	3	83	222	309	444
	CDH26.7	756	236	115	42	14	0	0	0	0	19	71	111	148
Wind	WSAvg	3.0	3.1	3.0	2.9	2.7	2.9	3.0	3.1	3.1	3.1	3.0	3.0	3.1
Precipitation	PrecAvg	1038	100	139	104	95	84	105	58	59	60	61	87	86
	PrecMax	1732	358	584	251	380	287	372	177	347	174	214	200	204
	PrecMin	654	6	8	18	0	4	14	1	0	8	12	21	30
	PrecStd	255	69	128	56	90	70	84	44	75	41	48	53	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	35.3	30.3	28.7	23.9	19.6	21.2	23.1	29.2	32.2	34.2	34.3
		MCWB	21.2	22.7	21.0	17.5	15.5	13.9	13.7	13.5	14.7	16.8	18.0	19.7
	2%	DB	31.6	29.8	27.4	25.2	21.8	17.8	18.6	20.7	25.7	28.5	29.6	30.4
		MCWB	21.6	22.0	21.3	18.1	15.3	13.3	11.9	12.5	14.4	16.5	19.5	20.3
	5%	DB	28.7	27.3	25.7	23.2	20.2	16.7	17.0	18.8	22.6	25.6	26.6	27.9
		MCWB	22.0	21.7	20.6	17.7	15.0	12.9	11.3	11.8	13.7	16.5	18.9	19.9
	10%	DB	26.7	25.5	24.1	21.7	18.9	15.7	15.7	17.2	20.5	23.0	24.2	25.5
		MCWB	21.3	20.8	19.9	17.3	14.4	12.6	11.0	11.2	13.6	16.4	18.6	19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	24.5	23.6	21.2	18.3	16.2	16.1	15.5	17.5	20.3	22.3	23.9
		MCDB	28.6	29.2	26.2	23.8	19.9	16.9	18.8	19.5	22.6	24.0	27.9	28.6
	2%	WB	23.6	23.1	22.2	19.9	17.4	14.9	14.1	14.3	16.6	19.2	21.0	22.3
		MCDB	27.4	27.3	24.9	22.2	19.3	16.2	16.0	17.6	21.0	23.0	26.1	26.6
	5%	WB	22.8	22.2	21.5	19.1	16.2	14.2	12.9	13.4	15.7	18.3	20.1	21.3
		MCDB	26.5	25.6	24.0	21.4	18.7	15.6	15.0	16.6	19.5	22.3	24.1	24.8
	10%	WB	22.0	21.5	20.7	18.3	15.4	13.5	11.9	12.5	14.9	17.5	19.3	20.6
		MCDB	25.5	24.5	23.1	20.5	18.2	14.9	14.3	15.7	18.7	21.2	22.7	23.6
Mean Daily Temperature Range	5% DB	MDBR	7.4	6.8	6.7	7.2	7.7	6.5	7.6	8.4	8.6	8.5	7.8	7.8
		MCDBR	12.5	10.2	9.0	9.0	9.1	7.7	9.1	10.3	12.3	13.4	12.8	12.5
		MCWBR	4.4	4.1	4.2	4.4	4.7	4.5	5.1	5.2	5.2	5.5	5.0	4.8
	5% WB	MCDBR	9.7	8.2	7.8	7.2	7.6	5.9	7.0	8.1	9.3	9.8	10.1	9.8
		MCWBR	4.2	3.8	4.0	4.0	4.5	4.1	4.7	4.9	5.3	5.1	4.5	4.6
Clear-Sky Solar Irradiance	taub		0.384	0.386	0.351	0.325	0.312	0.304	0.295	0.303	0.335	0.353	0.376	0.385
	taud		2.478	2.490	2.582	2.630	2.612	2.632	2.642	2.612	2.514	2.492	2.466	2.454
	Ebn at Noon		953	931	930	902	861	844	873	913	930	952	955	956
	Edh at Noon		117	111	95	81	73	67	69	80	99	110	117	120
All-Sky Solar Radiation	RadAvg		6.46	5.61	4.76	3.84	3.01	2.39	2.80	3.70	4.91	5.68	6.08	6.61
	RadStd		0.46	0.48	0.41	0.32	0.21	0.22	0.22	0.20	0.26	0.48	0.55	0.53

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.44	N/A	N/A	+0.77	N/A	N/A	-2	-86	+185	+99

Nomenclature: See separate page