

SYDNEY HOLSWORTHY, Australia

WMO: 947620

Lat: 33.979S

Lon: 150.925E

Elev: 131

StdP: 14.63

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.8	33.7	21.2	16.0	60.2	24.6	18.7	55.3	21.5	57.1	19.1	57.4	3.5	150	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	98.2	66.9	94.8	66.4	91.5	65.7	72.5	84.0	70.9	82.7	69.6	81.6	11.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	110.5	74.8	68.0	103.3	73.4	66.4	97.5	72.9	36.2	84.0	34.8	82.8	33.7	81.5	90.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.9	16.7	DB	26.4	103.6	3.6	4.0	23.8	106.5	21.7	108.8	19.6	111.0	17.0	113.9	(4)
(5)			WB	25.5	75.7	3.9	3.9	22.6	78.5	20.3	80.7	18.1	82.9	15.2	85.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.2	76.4	74.8	71.0	64.0	56.3	51.8	49.8	51.7	57.9	63.7	68.7	72.9		
	DBStd	10.57	5.71	5.54	4.65	4.86	4.85	4.44	4.32	4.55	5.16	5.85	6.61	5.76		
	HDD50	132	0	0	0	0	8	32	57	32	3	0	0	0		
	HDD65	1985	1	2	7	73	270	396	472	411	220	93	34	6		
	CDD50	4946	819	694	651	420	204	86	50	86	240	426	561	709		
	CDD65	1324	355	276	193	42	1	0	0	1	7	54	145	250		
	CDH74	14554	3871	2842	1745	507	27	0	0	10	233	850	1778	2691		
	CDH80	6430	1981	1363	633	95	0	0	0	1	46	272	782	1257		
(14) Wind	WSAvg	7.7	8.8	8.9	8.1	7.4	6.4	6.5	6.4	7.1	7.6	8.1	8.6	8.6		
(15) Precipitation	PrecAvg	34.5	3.9	3.7	4.0	3.3	2.7	2.8	1.6	2.2	1.8	2.4	3.0	2.5		
	PrecMax	53.9	9.8	18.9	12.5	15.9	7.8	12.6	6.0	14.1	7.0	6.9	8.3	9.3		
	PrecMin	18.0	0.2	0.5	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.4	0.1		
	PrecStd	9.9	2.6	3.6	3.1	3.6	2.2	3.0	1.5	3.1	1.5	2.0	2.0	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.4	101.8	93.9	86.8	77.1	69.8	69.9	74.6	85.2	91.4	99.5	100.3		
		MCWB	68.8	68.1	66.0	62.0	58.1	55.9	55.2	56.4	59.0	62.5	66.4	66.2		
	2%	DB	98.0	96.8	90.0	82.6	73.6	66.6	66.0	70.5	80.0	86.5	93.1	95.4		
		MCWB	67.6	66.9	64.9	61.8	57.3	54.3	53.2	54.4	57.9	61.3	64.1	65.3		
	5%	DB	94.6	92.4	86.6	79.6	71.2	64.7	63.1	67.6	76.2	82.6	88.4	91.5		
		MCWB	67.4	66.6	64.6	60.7	56.2	53.6	52.0	52.8	56.9	60.3	63.6	64.8		
	10%	DB	90.8	88.2	83.2	76.7	68.2	62.4	60.7	64.5	71.9	78.7	84.0	87.3		
		MCWB	67.2	65.9	64.1	60.1	55.7	52.7	50.9	51.8	56.1	59.7	62.3	64.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	74.7	72.3	70.1	64.1	59.6	60.2	62.4	63.9	67.6	72.2	73.6		
		MCDB	88.3	84.2	80.9	75.7	67.7	64.0	64.9	67.4	73.5	80.0	86.0	81.5		
	2%	WB	72.2	72.1	69.9	65.9	61.4	57.4	56.4	57.9	61.7	64.9	68.1	70.6		
		MCDB	85.6	83.5	78.1	73.5	67.9	62.1	60.6	64.0	72.0	77.1	82.2	82.2		
	5%	WB	70.7	70.4	68.3	64.0	59.4	55.8	54.4	55.4	60.0	63.2	66.4	69.0		
		MCDB	83.7	82.3	76.9	72.2	66.6	61.1	59.4	63.3	70.0	75.4	80.1	80.9		
	10%	WB	69.5	68.9	66.8	62.3	57.5	54.3	52.4	53.3	58.1	61.5	64.9	67.6		
		MCDB	82.6	80.9	76.3	71.6	65.4	60.3	58.9	61.8	67.9	73.6	78.2	79.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	23.8	23.1	24.2	24.4	21.7	22.8	25.5	26.7	26.1	25.0	24.0		
		MCDBR	30.8	30.9	28.6	28.7	28.0	24.7	27.3	30.9	34.4	33.4	33.1	31.5		
		MCWBR	8.8	9.0	9.8	11.8	14.2	14.4	15.9	16.7	16.0	13.7	11.3	9.8		
		MCDBR	23.9	22.6	20.5	21.2	20.7	19.1	19.8	23.5	25.5	26.6	25.3	23.1		
	5% WB	MCWBR	8.8	8.7	8.8	10.6	11.7	12.5	13.3	14.8	13.7	12.9	10.9	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.397	0.393	0.362	0.335	0.318	0.309	0.299	0.307	0.340	0.360	0.385	0.399		
	taud		2.439	2.468	2.537	2.588	2.585	2.607	2.615	2.585	2.492	2.467	2.436	2.410		
	Ebn at Noon		298	293	291	282	270	265	275	287	293	300	300	299		
	Edh at Noon		38	36	31	27	23	22	23	26	32	36	38	40		
(44) All-Sky Solar Radiation	RadAvg		2049	1753	1496	1211	956	753	883	1168	1558	1810	1925	2101		
	RadStd		154	157	131	103	64	69	69	67	90	161	175	179		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-2.25	+5.74	-1.24	-2.16	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	-4	-153	+331	+176

Nomenclature: See separate page