

SYDNEY BANKSTOWN, Australia

WMO: 947650

Lat: 33.9181S

Lon: 150.9864E

Elev: 25

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.9	40.0	26.1	20.1	62.5	29.3	23.3	59.0	23.1	59.8	21.0	61.1	2.3	340	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	93.8	68.7	89.5	68.9	85.9	68.2	73.9	85.1	72.5	82.4	71.3	80.3	12.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.8	113.7	77.7	69.6	109.0	76.3	68.4	104.6	75.3	37.5	85.3	36.2	82.4	35.1	80.4	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.6	19.0	17.0	DB	33.4	104.7	1.6	5.2	32.2	108.4	31.3	111.4	30.3	114.3	29.2	118.0	(4)
(5)			WB	32.4	76.4	1.6	1.6	31.2	77.6	30.3	78.5	29.4	79.4	28.3	80.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.7	73.7	73.0	70.2	64.5	58.8	54.3	52.6	54.7	59.6	64.1	67.7	71.3	(6)
(7)		DBStd	8.61	5.23	4.81	4.32	4.20	3.85	3.41	3.16	3.90	4.74	5.38	5.86	5.46	(7)
(8)		HDD50	17	0	0	0	0	0	4	9	4	0	0	0	0	(8)
(9)		HDD65	1584	1	1	6	56	194	320	384	321	175	84	34	8	(9)
(10)		CDD50	5002	735	644	625	436	274	134	90	149	288	436	532	659	(10)
(11)		CDD65	1095	271	225	166	42	3	0	0	1	13	55	116	203	(11)
(12)		CDH74	7880	1986	1484	871	270	29	0	2	26	204	593	929	1486	(12)
(13)		CDH80	2707	758	481	218	55	1	0	0	3	52	205	367	567	(13)
(14)	Wind	WSAvg	7.0	8.3	7.7	6.9	5.7	5.5	5.6	5.9	6.8	7.1	7.5	8.2	8.3	(14)
(15)	Precipitation	PrecAvg	35.9	3.7	4.2	4.6	3.7	2.6	3.2	1.8	1.5	1.7	2.5	3.2	2.7	(15)
(16)		PrecMax	55.0	9.2	17.3	13.1	16.4	6.8	12.8	5.9	7.6	6.4	7.5	8.4	10.3	(16)
(17)		PrecMin	19.4	0.2	0.6	0.5	0.2	0.1	0.3	0.0	0.1	0.0	0.0	0.5	0.3	(17)
(18)		PrecStd	10.6	2.7	3.9	3.3	4.0	2.0	3.0	1.7	1.9	1.5	2.4	2.0	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.9	98.1	90.8	86.3	77.5	70.0	72.1	77.4	86.2	92.0	96.8	98.1	(19)
(20)			MCWB	70.6	70.6	69.4	64.8	61.0	57.5	55.8	57.6	60.7	62.4	65.2	69.1	(20)
(21)		2%	DB	92.4	89.9	85.1	80.1	73.5	66.6	66.8	71.7	79.7	85.6	89.4	91.3	(21)
(22)			MCWB	70.9	71.7	69.0	64.3	60.3	56.4	53.4	55.4	58.8	62.2	67.0	68.6	(22)
(23)		5%	DB	87.8	85.2	81.8	76.7	70.4	64.6	64.0	68.2	75.0	80.6	83.4	86.2	(23)
(24)			MCWB	70.7	70.6	68.2	63.8	58.8	55.3	52.9	54.5	58.1	61.9	65.8	67.7	(24)
(25)		10%	DB	83.6	81.8	78.6	73.7	67.8	62.6	61.7	65.1	71.0	75.8	78.7	81.8	(25)
(26)			MCWB	69.4	69.4	67.2	62.9	58.1	54.2	51.8	53.0	57.0	61.0	64.7	67.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.9	76.1	73.8	69.2	65.5	61.4	59.9	61.1	64.5	68.1	71.8	74.1	(27)
(28)			MCDWB	90.1	88.1	82.4	77.9	70.0	65.5	65.8	70.8	75.1	78.9	85.2	86.8	(28)
(29)		2%	WB	73.8	74.0	71.5	67.3	63.6	59.1	56.7	58.5	62.5	66.0	69.8	71.9	(29)
(30)			MCDWB	86.2	83.8	79.5	75.3	68.3	63.3	61.7	66.7	72.3	76.9	80.9	83.4	(30)
(31)		5%	WB	72.4	72.4	70.1	65.9	61.8	57.6	55.1	56.6	60.9	64.4	68.1	70.3	(31)
(32)			MCDWB	82.9	80.9	77.6	72.7	67.0	61.9	60.4	64.7	70.1	74.1	78.3	80.9	(32)
(33)		10%	WB	71.1	71.1	68.9	64.5	59.9	56.2	53.5	54.8	59.1	62.9	66.4	69.0	(33)
(34)			MCDWB	80.1	78.8	76.0	71.3	65.9	60.6	59.4	62.5	68.1	72.1	75.6	78.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.6	15.6	16.0	18.0	18.9	17.6	20.0	21.5	21.5	20.1	17.7	17.3	(35)
(36)			MCDBR	25.8	22.7	22.1	23.5	22.8	20.8	24.4	27.2	30.0	30.5	28.3	26.7	(36)
(37)			MCWBR	8.3	7.6	8.3	9.9	11.0	11.5	13.1	13.2	12.2	11.0	9.6	8.6	(37)
(38)		5% WB	MCDWB	20.7	18.4	17.8	19.1	17.1	15.6	18.7	22.8	23.2	22.3	22.1	21.5	(38)
(39)	MCWBR		7.8	7.1	7.6	9.0	9.4	9.8	11.5	12.4	11.3	9.8	8.9	8.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.398	0.396	0.363	0.336	0.319	0.311	0.301	0.309	0.343	0.362	0.387	0.399	(40)	
(41)		taud	2.442	2.467	2.541	2.593	2.587	2.608	2.617	2.586	2.492	2.467	2.438	2.416	(41)	
(42)		Ebn at Noon	298	292	291	282	270	264	274	287	292	299	299	299	(42)	
(43)		Edh at Noon	38	36	31	26	23	22	23	26	32	36	38	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2051	1759	1500	1213	956	754	884	1170	1558	1809	1927	2102	(44)	
(45)		RadStd	153	156	131	103	65	69	69	66	89	159	175	177	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.94	N/A	N/A	N/A	N/A	N/A	-9	-184	+380	+202	(46)
(47)	Regional (34 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-4	-153	+331	+176	(47)

Nomenclature: See separate page